### **Controller**



# Controller

**PS-24 RCM-PM** PMEC/AMEC ACON PSEP/ASEP ROBONET

ERC2 **PSEL** PCON/ACON-ABU XSEI **SCON** 



PS241/PS242



RCM-PM-01



PMEC/AMEC





**ROBONET** 



ERC2



**ACON** 













**XSEL** 

461



# **Controller**

| PS-24                | DC24V Power Supply for ROBO Cylinder                                       | PS-241/242 <b>47</b>                                  | 71        |
|----------------------|--|---|-----------|
| RCM-PM               | Touch Panel Display for Position Controller                                | RCM-PM-01 <b>47</b>                                   | 73        |
| PMEC<br>AMEC         | 3 Position Controller for RCP3/RCP2 3 Position Controller for RCA2/RCA/RCL | PMEC-C 47   | 77        |
| PSEP<br>ASEP         | 3 Position Controller for RCP3/RCP2 3 Position Controller for RCA2/RCA/RCL | PSEP-C / CW<br>ASEP-C / CW                            | B7        |
| ROBONET              | Network Controller for RCP3/RCP2/RCA2/RCA/RCL                              | RGW-DV / CC / PR / SIO<br>RPCON / RACON / RABU / REXT | 03        |
| ERC2                 | ERC2 Controller  | ERC2 51   | 15        |
| PCON                 | Position Controller for RCP3/RCP2  | PCON-C / CG / CY / PL / PO / SE 52                    | 25        |
| ACON                 | Position Controller for RCA2/RCA/RCL                                       | ACON-C/CG/CY/PL/PO/SE 53                              | 35        |
| PCON-ABU<br>ACON-ABU | Simple Absolute Unit for PCON/ACON Controller                              | PCON / ACON-ABU 54                                    | 45        |
| SCON                 | Position Controller for RCS2   | SCON-C 54   | 47        |
| PSEL                 | Program Controller for RCP3/RCP2   | PSEL-C 55   | 57        |
| ASEL                 | Program Controller for RCA2/RCA/RCL  | ASEL-C 56   | <b>67</b> |
| SSEL                 | Program Controller for RCS2  | SSEL-C 57   | 77        |
| XSEL                 | Multiaxial Program Controller for RCS2                                     | X-SEL-J/K/P/Q 58                                      | 87        |

Controller 462

Controller

PMEC
PMEC
PSEP
ASEP
ROBO
NET
ERC2
PCON
ACON
SCON
PSEL
ASEL
XSEL










































# **Controller Overview**

The ROBO Cylinder model can be selected from an ultra-simple type, which is operable with the same controls as a solenoid valve, to a high functionality type compatible with networks; A variety of models are available according to the customer's usage.

Controller types can be categorized according to the 3 groups below based on their operations.























See page 469.



PMEC /AMEC /AMEC /PSEP /ASEP /ASEP /ASEP /ASEP /ASEP /ASEP /ASED NET /ASED N



































# **Positioner Type**


The positioner type controller stores positions to which the actuator is moved by specifying a target position number.

In particular, PMEC/AMEC, PSEP/ASEP controllers specify 2 or 3 positions and can be operated with the same signals used for an air cylinder.

#### No programming needed

The positioner type controller operates by selecting the target position number externally using I/O after teaching the position data.


Therefore, no operation programming is needed, allowing for immediate operation directly after mounting to the equipment.



#### Operation using the same signal as solenoid valve possible (PMEC/AMEC, PSEP/ASEP controllers)

Same as single solenoid-type valve, traveling between front/back ends is possible only by the single ON/OFF.

Furthermore, if the double solenoid-type valve signal (two signals) are used, positioning at 3 points including an intermediate position is possible.



#### Reasonable price

A reasonable price range is offered for the pulse motor type controllers which maintain the effective functionality of a servo motor.

The PMEC controller, including the power supply, PC software and communication cable, is sold as a set at a reasonable price.





#### No homing needed for absolute type and simple absolute type

A direct operation without homing upon power-on is possible if an absolutetype actuator and controller are used with the SCON Controller.

Other controllers(\*) are also operable without homing just like the absolutetype actuator by installing the simple absolute unit between the actuator and the controller.

(\*) Except PMEC/AMEC





#### PMEC/AMEC Controller

- ■Every element needed for operation such as the controller, power supply, PC software and communication cable, etc. are supplied in the set so that direct operation right after the purchase is possible.
- ■Intuitive operation is possible without the need for instruction. Acceleration/deceleration and speed can be programmed from the front panel of the controller.
- ■Operable with the same signals as a solenoid valve.
- ■Power supply of the controller is single-phase AC100V/AC200V (Only AC100V for AMEC)





See page

PSEP/ASEP Controller

- ■Operable with the same signals as a solenoid valve.
- ■Splash-proof type having good resistance to water splashes.
- ■Simple absolute type setting which eliminates the need for homing upon power-on.
- ■Controller power supply: DC24V





See page

#### PCON/ACON/SCON Controller

- ■Positioning is possible for up to 512 points.
- ■Compatible for pulse train input control.
- ■Incremental type and absolute type are available for the SCON. Same as the absolute type; no homing is needed for the PCON/ACON with an incremental type actuator using a simple absolute unit.
- ■Controller power supply is DC24V for PCON/ACON and single-phase AC100V/200V for SCON.



































## Program Type

The program type controller executes programs that are input to it.

Programs input to the controller are used to perform various tasks such as operating the actuator and communicating with external equipment. Ideal for small systems where a PLC is not required which leads to cost savings.


#### High-level control available using simple language.

A program is generated for the program type controller using the simple and easy Super SEL Language to execute operation of the actuator and communication between peripheral equipment. Expert knowledge is not needed to use the Super SEL Language, so it's easy to create programs even for beginners.

| No. | В | E | N | Cnd | Cmnd | Operand 1 | Operand 2 |
|-----|---|---|---|-----|------|-----------|-----------|
| - 1 |   |   |   |     | HOME | 100       |           |
| 2   | П |   |   |     | HOME | 11        |           |
| 3   |   |   |   |     | VEL  | 200       |           |
| 4   | П |   |   |     | WTON | 1         |           |
| 5   | П |   |   |     | MOYL | 1         |           |
| 6   | П |   |   |     | BTON | 301       |           |
| 7   | П |   |   |     | WTON | 2         |           |
| 8   | П |   |   |     | BTOF | 301       |           |
| 9   |   |   |   |     | MOVL | 2         |           |
| 10  |   |   |   |     | BTON | 302       |           |
|     |   |   |   |     |      |           |           |

#### Interpolation possible up to 2/6 axes


Simultaneous movement of the actuators are possible up to 2 axes for PSEL/ASEL/SSEL controllers and 6 axes for the XSEL controller. Depending on the program, interpolation is available to easily perform arc or path movements needed for dispensing jobs.



#### Controlling external equipment is possible

Multi-purpose I/O signals are available for the controller which makes communication with peripheral equipment possible.

Therefore, receiving signals from sensors and such through the controller or outputting signals from the controller to lamps or moving equipment, etc. to operate them is possible.



#### No homing needed for absolute type and simple absolute type

A direct operation without homing is possible upon power-on if an absolutetype actuator and controller are applied for ASEL/SSEL/XSEL Controllers. The PSEL controller is also operable without homing just like an absolutetype actuator by installing the simple absolute unit between the actuator and the controller.







#### PSEL/ASEL/SSEL Controller

- Program controller with reasonable price and compact body.
- Interpolation of up to 2 axes is possible which is applicable for dispensing jobs.
- By selecting the positioner mode, can be used in the same manner as the position controller.
- Communication via PC USB port and direct USB cable is possible with integrated USB port.
- Can store up to 1500 points for PSEL/ASEL and 20000 points for
- Absolute type available for ASEL/SSEL controllers. PSEL controller is available for the same operation if a simple absolute unit is connected.
- Controller power supply is DC24V for PSEL/ASEL and single-phase AC100V/200V for SSEL.



See page 557.



See page 567.



See page

#### **XSEL Controller**

- High-function controller with up to 6 axes that can be simultaneously controlled.
- Precise dispensing jobs are possible through high velocity uniformity and tracking accuracy.
- Absolute type available for selection.
- 20000 points can be stored for positioning.
- Expansion I/O is available up to a maximum of 384 points.
- P/Q type controls PCON/ACON/SCON/ROBONET via serial communication for up to 16 axes. ( $\rightarrow$  Refer to Gateway function p469)
- Controller power supply is single-phase AC100V/200V for XSEL-J/K type and three-phase AC200V for XSEL-P/Q type.



See page 587.





































# **Network Type**

The network type controller is available for field networks or serial communication.

Compatible with the majority of main field networks widely used over the world.

There is a large variety available for use with various kinds of FA equipment such as a PLC or touch panel, etc.

#### Compatible with main field networks

Direct connection is possible with main field networks such as DeviceNet or CC-Link, etc.

A position controller is available for an operation defined by movement specified with position number and direct coordinate value using the network. When defining coordinate values directly, there is no restriction for the number of positioning points.

#### Compatible Network and Function

| (         | Controller series                    | ROBONET                   | PCON           | ACON           | SCON       | PSEL        | ASEL         | SSEL         | XSEL         |
|-----------|--------------------------------------|---------------------------|----------------|----------------|------------|-------------|--------------|--------------|--------------|
|           | DeviceNet                            | 0                         | 0              | 0              | 0          | 0           | 0            | 0            | 0            |
|           | CompoNet                             |                           | 0              | 0              |            |             |              |              |              |
| Network   | CC-Link                              | 0                         | 0              | 0              | 0          | 0           | 0            | 0            | 0            |
| Туре      | MECHATROLINK                         |                           | 0              | 0              |            |             |              |              |              |
|           | PROFIBUS-DP                          | 0                         | 0              | 0              | 0          | 0           | 0            | 0            | 0            |
|           | Ethernet                             |                           |                |                |            |             |              |              | 0            |
| Appli     | icable ROBO Cylinder                 | RCP2/RCP3<br>RCA/RCA2/RCL | RCP2/RCP3      | RCA/RCA2/RCL   | RCS2       | RCP2/RCP3   | RCA/RCA2/RCL | RCS2         | RCS2         |
| Numbe     | er of positioning points             | 768 points (*)            | 768 points (*) | 768 points (*) | 512 points | 1500 points | 1500 points  | 20000 points | 20000 points |
| Operating | Movement by specifying positions     | 0                         | 0              | 0              | 0          | 0           | 0            | 0            | 0            |
| Method    | Movement by specifying direct values | 0                         | 0              | 0              | ×          | ×           | ×            | ×            | ×            |

<sup>(\*)</sup> When it is operated by movement by specifying direct values, the number of positioning points is unlimited.

#### RC Gateway function for XSEL controller

The ROBO cylinder gateway function controls the ROBO cylinder via serial communication from the XSEL controller. Wiring work is significantly reduced, comparing with PIO control. The ROBO cylinder can be operated using the XSEL controller via the SEL Language.

- ■ROBO Cylinder gateway function is available in the controller firmware (main CPU application)
- V0.68 or higher (for P/Q type), or V0.34 or higher (for PX/QX type).

  ■The version of the PC software (IA-101-X-MW) that is compatible with the ROBO Cylinder gateway function is V7.2.0.0 or later.

  The teaching pendants compatible v
- ching pendants compatible with the ROBO Cylinder gateway function are IA-T-X (XD) V1.4.6 or later, or SEL-T (TD) V1.0.1 or later.

#### ■Type

| Item   | Description                  |
|--|------------------------------|
| Number of maximum connected axes for ROBO Cylinder   | 16 axes                      |
| Number of maximum operation axes for XSEL Controller | 6 axes                       |
| Available ROBO Cylinder series                       | ERC2/RCP2/RCP3/RCA/RCA2/RCS2 |
| Connectible controller                               | ERC2/PCON/ACON/SCON/ROBONET  |
| Communication system                                 | Modbus                       |

#### (Comparison of PIO Control and Gateway function)

|                           | PIO control                                  | Gateway function                       |
|---------------------------|--|--|
| Wiring process            | Many wires                                   | Only two wires                         |
| Control method            | Only ON/OFF of I/O                           | Program available                      |
| Movement position         | Requires input into controller ahead of time | Can send command from XSEL controller  |
| Current actuator position | Verify with end position No.                 | Can numerically check current position |

#### **■Connectible Units**

The following units are required to use the ROBO Cylinder Gateway function. Please contact us for further details for wiring.

| Name                  | Model         | Notes   |
|-----------------------|---------------|---|
| RS232 conversion unit | RCB-CV-GW     | 1 unit needed for each XSEL controller.                           |
| Communication cable   | CB-RCB-SI0050 | 1 cable needed for each XSEL controller.                          |
| Controller link cable | CB-RCB-CTL002 | 1 cable needed for each ROBO Cylinder controller to be connected. |



#### **Connection with various types of FA equipment**

Available for direct connection with a touch panel, PLC (serial communication unit) or vision system of various manufacturers.

Main Connecting Equipment \* Please contact us for further details for connectable equipment, etc.

| Name of product            | Manufacturer  |
|----------------------------|---|
| Touch Panel                | Digital, Omron, Hakko Electronics, Keyence,<br>Mitsubishi Electric, Beijer, Proface, Red Lion |
| PLC (Serial communication) | Omron, Mitsubishi Electric, Keyence   |
| Vision System              | Omron, Cognex, Keyence  |

#### **ROBONET Controller**

- ■ROBONET is a controller dedicated for field networks. Wiring was reduced significantly as it can be connected with up to a maximum of 16 control units for a single gateway unit which is compatible with various networks.
- ■Operation is available with target position, speed or acceleration, etc. sent through a network by means of a value; this is effective when target position changes based on conditions.
- ■Simple absolute unit can be installed to make homing unnecessary.
- ■Controller power supply; DC24V



**SCON** 

See page 503.

Standard
Controller:
Integrated
Mini
Standard
Controller:
Integrated

See page **XSEL** 587.

Controller compatible with field network \* Network type set for each controller



**PSEL** 

See page 525.

See page

557.



See page 535.



See page 567.



See page 577.

See page

547.

■Can be connected to the main network directly.

■The position controller is able to be operated with the value of the target position, speed or acceleration etc. directly sent via the network.



# **PS-24**

■ Model PS-241/PS-242

DC24V Power supply for ROBO Cylinder



#### Features


#### 1 Maximum Momentary Output of 17A

Up to 17A of maximum momentary output current is possible at 8.5A rated output current. This lets you select an appropriate power-supply capacity based on the total rated current of actuators, without having to consider the maximum momentary current that may be generated by the actuators during acceleration. Because you no longer need to use an expensive high-capacity power supply, cost can be reduced substantially.

\* The maximum momentary output current must be considered if the actuator operating conditions are tight. See the "Selection Guide" at right for details.

#### 2 Parallel Operation Enabled

Up to 5 units can be operated in parallel. Therefore, even if the power capacity is insufficient with one unit, this can be easily remedied by adding one unit, without the need to replace the unit with a larger capacity power supply.



#### 3 Load Detection Function

Load percentage can be detected by the RDY (Ready) display lamp and the RDY output signal.




Table 1. PS-24 Rated Current and Allowable Maximum Momentary Electric Current

| No. of Connected units | Rated current [A] | Max. momentary current [A] |
|------------------------|-------------------|----------------------------|
| 1                      | 8.5               | 17                         |
| 2                      | 15.3              | 30.6                       |
| 3                      | 22.95             | 45.9                       |
| 4                      | 30.6              | 61.2                       |
| 5                      | 38.25             | 76.5                       |

Note: For the second and subsequent units, add a 10% safety buffer (loss).

#### Selection target Number of actuators connected

When selecting a power-supply unit for operating multiple actuators, normally a unit with a capacity equal to or exceeding the total maximum current of all actuators is chosen. However, actuators generate their maximum current only momentarily during acceleration, etc., and in many cases the power-supply is over-specified.

On the other hand, the PS-24 power supply provides the following advantages:

1. Supporting maximum momentary current of up to twice the rated current.

2. If you need more power-supply capacity, you can simply add an extra unit or units.

The above features let you select an optimal power-supply capacity.

#### Number of Power-Supply Units

Basically, how many power-supply units you need should be determined in such a way that the total rated current of all actuators will remain within the rated current of the PS-24. If the load condition is tight, however, the power-supply capacity may still become inadequate. In such cases, add an extra power supply or supplies.

#### "Severe load conditions" refers to

- Large load (load is approaching the rated load capacity)
- High acceleration/deceleration
- High speed
- Simultaneous operation of multiple axes
- Use of the RCS2-SRA7 series (Structurally these actuators allow maximum current to flow for a longer period).

Table 2. Actuator vs. Power Supply Current

| Controller Type       | Actuator Type  | Power supply        |              | for PS-24 (F   | Reference)*1   |
|-----------------------|--|---------------------|--------------|--|--|
|                       | ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,                          |                     | ent [A]      | If the servo is<br>on for all axes<br>simultaneously | If the servo is<br>NOT on for all<br>axes simultaneously |
| ERC2                  | ERC2   |                     |              |  |  |
| PSEP<br>RPCON<br>PCON | All models of RCP3/RCP2<br>(* Excluding the 5 models below)      | Rated<br>(=Maximum) | 2            | 8  | 8  |
| PCON-CF               | RCP2-HS8C / RCP2-HS8R<br>RCP2-RA10C<br>RCP2W-RA10C / RCP2W-SA16C | Rated<br>(=Maximum) | 6            | 2  | 2  |
|                       | 044 045 (00)40   | Rated               | 1.3          | 3  | 6  |
|                       | SA4, SA5 (20W)   | Maximum             | 4.4          |  |  |
|                       |  | Rated               | 1.3          | 4  | 6  |
| ASEP                  | SA6 (30W)  | Maximum             | 4            |  |  |
|                       |  | Rated               | 1.7          | _  | 5  |
| RACON                 | RA3 (20W)  | Maximum             | 5.1          | 3  |  |
| ACON                  |  | Rated               | 1.3          |  | _  |
|                       | RA4 (20W)  | Maximum             | 4.4          | 3  | 6  |
|                       |  | Rated               | 1.3          | 4  | 6  |
|                       | RA4 (30W)  | Maximum             | 4            |  |  |
| 1 The figures         | in "Number of Connectable Uni                                    | ts for PS-2         | 4 (Reference | are calculated                                       | hased on the   |

\*1 The figures in "Number of Connectable Units for PS-24 (Reference)" are calculated based on the following: When supplying power to multiple controllers, make sure that the sum of the rated current for the individual axes stays LOWER than the PS-24's <u>rated</u> current (8.5A). Exceptions: For RCP3/RCP2/RCP2W, make sure that the sum of the rated current for the individual axes is LOWER than the PS-24's <u>maximum momentary</u> current (17A).
For PSEL/ASEL, this varies with number of axes used and the model. Please ask for details.

#### Names

plash-Proor
Controller
PMEC
/AMEC
PSEP
/ASEP
ROBO
NET
PCON
ACON
SCON
PSEL
ASEL

1 Ready indicating light (RDY)

2 Level setting dial for over load detection (LF.DET)

\*Appropriate value settled at shipment. Operation not needed.

3 Ready output signal (RDYOUT)

4 5 + 24V Output terminal ( + 24V)

\*45 connected internally.

6 7 0V Output terminal (0V)

\*67 connected internally.

8 Frame ground terminal (FG)

Terminal for ground.

9 AC input terminal (AC (N))

10 AC input terminal (AC100V) (AC100 (L))

11 AC input terminal (AC200V) (AC200 (L))

\*AC100V input type should be connected to ⑨ and ⑩ interval, AC200V to⑨ and⑪. Unavailable for combined use.

471

PS-24




#### List of Models

| Model          | PS-241 | PS-242 |
|----------------|--------|--------|
| Standard Price | =      | -      |

#### Specification List

| Item                              | PS-241 PS-242   |                          |  |  |  |
|-----------------------------------|---|--------------------------|--|--|--|
| Rated DC output voltage           | 24V±10% (varied depending on the load)                                  |                          |  |  |  |
| Rated DC output current           | 8.5A  |                          |  |  |  |
| Instantaneous max. output current | 17A   |                          |  |  |  |
| Rated output capacity             | 204   | 4W                       |  |  |  |
| Efficiency                        | 80%   | 80%                      |  |  |  |
| Rated input (frequency)           | AC100~115V (50/60Hz)  | AC200~230V (50/60Hz)     |  |  |  |
| Input voltage range               | AC85~125V   | AC170~250V               |  |  |  |
| Input current                     | 3.50A (100VAC full load)  | 1.80A (200VAC full load) |  |  |  |
| Output holding time               | 20 [msec] (Ambient temperature 25°C under rated input/output condition) |                          |  |  |  |
| Protection circuit                | Protection from overcurrent, overvoltage, overheating and overload.     |                          |  |  |  |
| Parallel operation                | Possible  |                          |  |  |  |
| Operating temperature             | 0~50°C (derated)  |                          |  |  |  |
| Operating humidity                | 30~85%RH (non-condensing)   |                          |  |  |  |
| Cooling method                    | Natural, air cooling  |                          |  |  |  |
| Voltage registance                | Between input/output···2.0kVA per minute (20mA)                         |                          |  |  |  |
| voitage resistance                | Itage resistance Between cabinets2.0kVA per minute (20mA)               |                          |  |  |  |
| Insulation resistance             | Output - 100MΩ or more between cabinets at 500 VDC                      |                          |  |  |  |
| Circuit method                    | Separate excitation type flyback converter                              |                          |  |  |  |
| Weight                            | Aprox. 0.9kg  |                          |  |  |  |

#### **Outer dimensions**



⚠ Caution:

- The PS-24 is not a constant voltage power supply. The output voltage changes with the load (voltage decreases according to the load percentage). Therefore, do not connect any equipment other than ROBO Cylinder actuators. Up to 5 units can be operated in parallel. Do not use any power supplies other than the PS-24 at the same time for parallel operation.
- Note that serial operations are not possible.
- As a rule, when operating multiple units in a row, allow at least 20mm space between each power supply.

  This is a natural air-cooled power supply. Please give due consideration to natural convection so that heat does not build up around the power supply.
- The case of this product also has heat a dissipating effect. Do not touch the case after installation as it may result in severe burns.

Silder Type

Mini
Standard
Controllers Integrated
Rod Type
Mini
Standard
Controllers Integrated
Table/Arm
/Flat Type
Mini
Standard

PS-24 **472** 



#### Characteristics

ontrollers
Integrated

Rod
Type

Mini

Standard

Controllers
Integrated

PMEC /AMEC
PSEP /ASEP
ROBO NET
ERC2
PCON
ACON
SCON
PSEL
ASEL
XSEL

1 Controller data is easy to enter, amend or monitor.

Entering, changing and monitoring (of actual position, speed or input/output condition, etc.) controller position data is possible without connecting teaching box or computer software if touch panel display is installed on the device. (\*1) Easy-to-use even for beginners as the display is interactive.

(\* 1) Teaching box or software for PC is needed to reset error or change parameter.



2 Able to check the current condition at a glance with 3 back lights of good visibility.









Normal (white)

Alarm activated (pink)

Emergency stop (red)

3 Able to display current position, speed, electric current value and alarm up to 4 axes simultaneously when connected with ROBONET.

Displays controller condition of ROBONET simultaneously up to 4 axes when connected with ROBONET Gateway unit. (Able to display up to 16 axes by switching the panel.)

The details of the display show the actual position of the operating actuator, speed, electric current value, alarm code, etc.




#### Model/Price


| Model          | RCM-PM-01 |
|----------------|-----------|
| Standard Price | -         |


473 RCM-PM-01











RCM-PM-01 474



# Mini Standard Controllers Integrated Rod Type Mini Standard Controllers Integrated Table/Arm //Flat Type Mini Standard






























#### Model/Specification


| Model  |                                  | RCM-PM-01   |  |  |
|--|----------------------------------|---|--|--|
| Standard Price   |                                  |   |  |  |
|  | Rated Voltage                    | DC24V   |  |  |
| ations   | Operational Voltage Range        | DC21.6~26.4V  |  |  |
| Specifications   | Power Consumption                | 2W or less (80mA or less)   |  |  |
| Spe  | Operating Ambient Temp./Humidity | 0∽50°C 20∽85% RH (non-condensing)   |  |  |
| Basic  | Environment resistance           | IP65 (initial state) dust- and splash-proof, only from front side of the panel  |  |  |
|  | Mass                             | Approx. 160g  |  |  |
| Suc  | Communications Standard          | RS485 Compliant   |  |  |
| icatio   | Communication Conditions         | Transfer speed: 115.200bps, Data bit: 8-bit, Non-parity, Stop bit; 1-bit  |  |  |
| Communications Standard   RS485 Compliant                                  |                                  | Modbus/RTU  |  |  |
| ပ် လွ  | Connectible Controllers          | PCON/ACON/SCON/ERC2/ROBONET *Connectible up to 16 controllers max.  |  |  |
|  | Monitor                          | Current position, current speed, alarm code, alarm message PIO status bit, speed wave form, current wave form, current, rated current ratio   |  |  |
|  | Alarm list                       | History: 16 entries (code, detailed code, address occurred, message)  |  |  |
|  | Position table edit              | Target position, position, acceleration, positioning width, pushing, separate zone±, incremental setting, threshold, accel/decel. mode Stop mode, importing current position via JOG/inching/direct teaching, warning function for abnormal input value |  |  |
| function   | Move function                    | Position movement, direct movement, JOG movement, jump-to-screen function when alarm is triggered   |  |  |
| Ē  | Edit parameters                  | Zone signal, software limit, select PIO pattern, JOG speed, inching distance, pushing force, safety speed   |  |  |
|  | Backlight                        | White (normal), Pink (alarm triggered), red (emergency stop)  |  |  |
|  | Display adjustments              | Adjustable contrast and brightness for the backlight  |  |  |
| Gal ay In tor rul pils Cur for all a , alar nor r for lixes, Ga ay systems |                                  |   |  |  |

#### Dimensions



#### Example of body installation

#### ■ Dimensions for Cutting and Drilling Holes




Caution Never block the slits on the actuator.

#### ■ Mounting Method (Using Supplied 4 Mounting Brackets)

- 1 Insert the RCM-PM-01 to the mounting plate.
- $\ensuremath{{\mathbb Z}}$  Attach the mounting brackets to the slots on RCM-PM-01, and secure the RCM-PM-01 onto the mounting place by tightening the screw.
- Note 1) Screw tightening torque 0.1 N·m~0.25N·m

Note 2) Excessive tightening of the screws may warp the front panel, causing the touch switches to malfunction. Please mount using appropriate torque.



475 RCM-PM-01



■ Vertical type Model: RCB-TU-SIO-A

■ Horizontal type Model: RCB-TU-SIO-A 

Controllers

PMEC
AMEC

PSEP
ASSEP

ROBO
NET

ERC2

PCON

ACON

SCON

PSEL

ASSEL

XSEL

# Serial Communication Option

Please use the options below to connect controller by link through serial communication.

SIO Converter


RS232 communication available transformer with serial communication cable of power supply and I/O cable(SGA, SGB) connected and pin-cross cable D-Sub9 for connecting PC used.

Characteristics Able to separate the connecting point for teaching box or PC connection cable from the body and install them anyway.

Able to operate through PC serial communication by connecting multiple axes.

type

| Item                             | type                                      |
|----------------------------------|---|
| Power supply voltage             | DC24V±10%                                 |
| Ambient Operating Temp./Humidity | 0 ~ 50°C, 85% RH or less (Non-condensing) |
| Terminator                       | 120Ω(Integrated)                          |



RCM-PM-01 476



3-position, AC100/200V controller for RCP2/RCP3 Series





3 position, AC100V controller for RCA/RCA2/RCL Series

#### ROBO Cylinder 3-position controller MEC (Mechanical Engineer Control)

Feature

#### **Low Cost**

The PMEC package, which comes with a controller, power supply, acceleration/speed change function and PC connection cable, among others, is at an affordable price. The MEC PC software can be downloaded free of change from IAI's website.




#### **Easy Operation**

Even a beginner can set up the controller without reading the operation manual. The acceleration and speed can be changed using the knobs on the controller.


Setting range for acceleration/speed varies depending on the actuator.

Please refer to the instruction manual for further detail.




#### Easy Replacement from your Air-cylinder System

Operation signals are exactly the same as those used to operate air cylinders. This means that you can use the program of your current PLC directly.



#### Push-motion Operation/Intermediate Stopping

Push-motion operation can be performed in the same manner as you would with any air-cylinder system. Also, you can cause the actuator to stop at any desired intermediate point between the home position and stroke end by changing the setting of the intermediate point using the MEC PC software.





477 PMEC/AMEC



| Series               | PM   | EC       | AMEC             |
|----------------------|--|----------|------------------|
| External View        |  |          |                  |
| Applicable actuators | RCP2   | RCP3     | RCA / RCA2 / RCL |
| Power supply voltage | 100V   | 100-240V | 100V             |
| Price                | -  | -        | _                |
| Accessories          | AC power supply cable (2m) USB cable (3m) I/O cable (2m) I/O connector EMG connector Standard mounting bracket |          |                  |

#### Model





Splash-Proof

Controllers

PMEC
/AMEC

PSEP
/ASEP

ROBO
NET

ERC2

PCON

ACON

SCON

PSEL

ASEL

XSEL














































#### System Configuration



#### I/O Signal Table

| Motion Pattern |            |             | 2-Position Travel  | 3-Position Travel  |
|----------------|------------|-------------|--|--|
| Pin No.        | Wire Color | Signal Type | Signal Name  | Signal Name  |
| 1              | Brown      | PIO power   | 24V  | 24V  |
| 2              | Red        | PIO power   | 0V   | 0V   |
| 3              | Orange     |             | ST0 (Solenoid A: ON moves to end position, OFF moves to home position) | ST0 (Solenoid A: Move signal 1)  |
| 4              | Yellow     |             | -  | ST1 (Solenoid B: Move signal 2)  |
| 5              | Green      | Input       | RES (Alarm reset)  | RES (Alarm reset)  |
| 6              | Blue       |             | -  | _  |
| 7              | Purple     |             | LS0 (home position detection)/PE0 (home positioning complete)*1        | LS0 (home position detection)/PE0 (home positioning complete)*1              |
| 8              | Gray       | 0.44        | LS1 (end position detection)/PE1 (end positioning complete)*1          | LS1 (end position detection)/PE1 (end positioning complete)*1                |
| 9              | White      | Output      | HEND (Homing complete)   | LS2 (intermediate point detection)/PE2 (intermediate positioning complete)*1 |
| 10             | Black      |             | * ALM (alarm)*2  | * ALM (alarm)*2  |

<sup>\*1:</sup> Signals PE0 through PE2 will be output if the pushing motion was enabled in the initial setting. Otherwise, LS0 through LS2 will be output.
\*2: \*ALM is ON when normal, and OFF when it is activated.

#### MEC PC software

By using the MEC PC software you can change the stop position data or run a test operation.

In addition, you can change the setting on the intermediate stop function, pushing function or change the coordinates.




#### **Explanation of PIO Patterns**

#### PIO Pattern (2-position travel)

This motion pattern is between two positions, the home position and the end position. The home and end position can be configured numerically (using the MEC PC software or the optional touch panel teaching pendant).

Two motions are possible: A positioning motion moves the rod or the slider to the specified position, and a pushing motion presses the rod against a workpiece.

#### Positioning



| Input Signal  |            |    |  |  |
|---|------------|----|--|--|
| ST0   | Solenoid A | ON |  |  |
| When ST0 is turned ON, the slider/rod               |            |    |  |  |
| moves at 50mm/s to the end position (30mm position) |            |    |  |  |

| End Position Data |     |  |
|-------------------|-----|--|
| Position          | 30  |  |
| Speed             | 50n |  |
|                   |     |  |

| Position      | 30mm   |
|---------------|--------|
| Speed         | 50mm/s |
| Pushing Force | -      |
| Width         | ·      |

Controllers Integrated

Rod
Type

Mini

Standard

Controllers
Integrated

Table/Arm
/Flat Type

Controllers

PMEC
AMEC

PSEP
AOSEP
ROBO
NET

ERC2


PCON

ACON

SCON

PSEL

ASEL



| Input Signal  |            |     |  |
|---|------------|-----|--|
| ST0   | Solenoid A | OFF |  |
| When ST0 is turned OFF, the slider/rod returns to the home position (0mm position) at 20mm/s. |            |     |  |


| Home | Position | Data |
|------|----------|------|
|      |          |      |

| nomo i comon bata |        |  |
|-------------------|--------|--|
| Position          | 0mm    |  |
| Speed             | 20mm/s |  |
| Pushing Force     | _      |  |
| Width             | -      |  |

#### PIO Pattern (2-position travel)

This motion pattern is between two positions, the home position and the end position, which enables a pushing motion of the rod against a workpiece.

#### Push



#### Input Signal

| \$10  | Solenoid A        | ON               |   |
|---|-------------------|------------------|---|
| When the input 0 is turned ON, the actuator moves |                   |                  |   |
| the rod to the 20r                                |                   |                  |   |
| there, pushes it a                                | t slower speed to | the 30mm positio | ı |

#### **End Position Data**

| Position      | 30mm   |
|---------------|--------|
| Speed         | 80mm/s |
| Pushing Force | 50%    |
| Width         | 10mm   |


\* The pushing motion is performed when there is a numerical value in the controller's push force data. (If there is no numerical value, a positioning motion is performed instead.)

#### PIO Pattern (3-position travel)

This motion pattern enables moves between three positions: the end position and the home position, as well as an intermediate position.

The positions are switched by combining two signals, ST0 and ST1.

#### Positionina



#### Input Signal

| ST0 | Solenoid A | ON  |
|-----|------------|-----|
| ST1 | Solenoid B | OFF |

When only the ST0 is turned ON, the actuator moves to the starting position at a set acceleration and speed.

(Intermediate position)


(10mm)

#### Input Sign ST0

| nai |            |     |
|-----|------------|-----|
|     | Solenoid A | ON* |
|     | Solenoid B | ON* |

\* By default, you can configure the MEC where you turn both signals OFF to move to the intermediate position, or both ON to stop at the current position.

When both ST0 and ST1 are turned ON, it will move to the diate position at the set acceleration and speed When both are turned OFF, it stops at the current position.



#### Input Signal ST0

ST1

| • |            |     |
|---|------------|-----|
| 1 | Solenoid A | OFF |
|   | Solenoid B | ON  |

When only ST1 is turned ON, the actuator moves to the end position at a set acceleration and speed.



# PMEC / AMEC Controller

PMEC //AMEC

PSEP //ASEP

ROBO NET 
ERC2


PCON 
ACON 
SCON 
PSEL 
SSEL

#### Specifications Table

| Item                          | Туре                |  |                               |  |  |  |
|-------------------------------|---------------------|--|-------------------------------|--|--|--|
| Controller Type               | PMEC AMEC           |  |                               |  |  |  |
| Connectible Actuators         | RCP2/RCP3 Se        | eries Actuators  | RCA/RCA2/RCL Series Actuators |  |  |  |
| Number of Controllable Axes   |                     | Single axis  |                               |  |  |  |
| Operation Method              |                     | Positioner Type  |                               |  |  |  |
| Number of Positions           |                     | 2 positions / 3 positions  |                               |  |  |  |
| Backup Memory                 |                     | EEPROM   |                               |  |  |  |
| I/O Connector                 |                     | 10-pin terminal block  |                               |  |  |  |
| I/O Points                    |                     | 4 input points / 4 output points   |                               |  |  |  |
| Power for I/O                 |                     | Externally supplied DC24V±10%  |                               |  |  |  |
| Serial Communication          | RS485: 1ch/USB: 1ch |  |                               |  |  |  |
| Position Detection Method     | Incremental encoder |  |                               |  |  |  |
| Power Supply Voltage          | AC100V-115V±10%     | AC90V~264V   | AC100V-115V±10%               |  |  |  |
| Rated Current                 | 1.3A                | 0.67A (AC100V)/0.36A (AC200V)  | 2.4A                          |  |  |  |
| Rush Current                  | 30A                 | 15A (AC100V)/30A (AC200V)  | 15A                           |  |  |  |
| Leak Current                  | 0.50mA max          | 0.50mA max   |                               |  |  |  |
| Dielectric Strength Voltage   |                     | DC500V 1MΩ   |                               |  |  |  |
| Vibration Resistance          | XYZ direction       | XYZ directions 10-57Hz One-side amplitude 0.035mm (continuous), 0.075mm (intermittent) 57-150Hz 4.9m/s² (continuous), 9.8m/s² (intermittent) |                               |  |  |  |
| Ambient Operating Temperature |                     | 0~40°C   |                               |  |  |  |
| Ambient Operating Humidity    |                     | 10~85% RH (non-condensing)   |                               |  |  |  |
| Ambient Operating Atmosphere  |                     | Free from corrosive gases  |                               |  |  |  |
| Protection Class              |                     | IP20   |                               |  |  |  |
| Weight                        | 500g                | 508g   | 614g                          |  |  |  |

Note: The minimum/maximum speeds vary depending on the actuator model. For more information, see the instruction manual, or contact IAI.


#### **Outer Dimensions**



481 PMEC / AMEC



# Names of Parts and Functions



PIO connector ······ Connects with a PLC or other external controllers to communicate inputs and outputs (I/O).

Power LED ..... When the power is ON, it illuminates in green.

3 Control panel ·····See below

4 Brake switch Release Used to release the brake of the actuator Normal The controller automatically controls the brake of the actuator

5 USB connector ..... When using MEC PC software, connect to the computer via USB.

6 AC inlet ..... Insert the power supply cable.

**IDENTIFY and SET IDENTIFY** EMG connector .... Connect the emergency stop button. Short-circuit it if you will not be using an emergency stop button.

8 M/PG connector ···· Insert the motor / encoder cable that connects with the actuator.

9 Status LED

RUN Indicates the servo status. On = Servo ON, Off=Servo OFF (Energy-saving) status (Green) Flashing (1Hz)=Auto servo OFF ALM (Red) The LED illuminates if an alarm is turned ON or if the EMG (Red) controller has come to an emergency stop.

10 SIO Connector ······ Connects with the teaching pendant (CON-PT, SEP-PT).

#### **Explanation of the Control Panel**



When starting, homing is performed first to confirm the 0mm coordinate.

#### Manual button

PMEC

Press this button to set the acceleration and/or speed, or to run a test operation. (Press for at least 1 second)

#### AUTO button

Press this button when operating from the MEC PC software or the PLC commands. (Press for at least 1 second)

#### Acceleration/Speed Settings Configure the actuator's motion.

button

Switch the motion you want to configure (see types below). FWD POS: Motion toward the end position

BACK POS: Motion toward the home position Middle: Motion toward an intermediate position (Enabled from the MEC PC software. simultaneously press "FWD POS" and "BACK

POS" to switch. During a 2-position stop, simultaneous pressing is disabled.)

#### Acceleration / Speed knob

By turning the knob, you can change the speed between 1%~100% of the actuator's maximum speed or rated acceleration / deceleration.

\* The minimum speed may be less than 1% in some cases

#### **SAVE** button

Saves the speed and acceleration adjusted above.

#### **Test Operation**

Confirm the saved motion by physically running the actuator.

#### FWD button

In a 2-position travel, the actuator moves from the BACK position to the FWD position. In a 3-position travel, the actuator moves from the BACK position to the intermediate position, then to the FWD position.

#### **BACK** button

The actuator returns to the starting position.

#### **RUN** button


In a 2-position travel, the actuator moves back and forth between the FWD and BACK positions. In a 3-position travel, the actuator repeats its movement from the BACK position, intermediate position, FWD position, then BACK position.

#### STOP button

Stops the above operation.

#### Explanation of Terms

IAI



FWD POS
- - - Names of movements



PMEC (AMEC PSEP ASEP ROBO NET ERC2 PCON ACON SCON PSEL ASEI

# Option

# Teaching pendant for position controller

Data input device easy-to-operate even for beginners with a simple interactive menu screen. Operation arrangements such as positioning of home, end or intermediate position, setting of speed or push force and movement to jog/inching/order position are available.





#### ■ Model/specifications


|                          | Item                | Description  |  |
|--------------------------|---------------------|--|--|
|                          | Japanese edition    | CON-PT-M   |  |
| Model                    | English edition     | CON-PT-M-ENG   |  |
| Туре                     |                     | Standard   |  |
| Function                 |                     | Input/edit position data<br>Mwovement functions<br>(move to a specified position, jog, inch)<br>Test input and output signals<br>Edit parameters<br>Switch language (Japanese/English) |  |
| Label                    |                     | 3-color LED with backlight   |  |
| Ambient opera            | ting temp./humidity | 0 ~ 50°C 20 ~85%RH (no condensation)   |  |
| Environmental            | resistance          | IP40   |  |
| Weight (including cable) |                     | 750g   |  |
| Accessories              |                     | Touch pen  |  |
| Standard price           | )                   | =  |  |



#### ■ Part names / dimensions











Strap model STR-1



#### • DIN Rail Mounting Bracket MEC-AT-D

■ Dimensions





#### Maintenance cable

#### ■ List of maintenance cable models

| Type                           |                                 |                        | Cable length | Model              | Standard price |
|--------------------------------|---------------------------------|------------------------|--------------|--------------------|----------------|
|                                | PMEC ←→ RCP3<br>RCP2-GRSS/GRLS/ |                        | 1m           | CB-APSEP-MPA010    | -              |
|                                |                                 | GRST/<br>SRA4R/SRGS4R/ | 3m           | CB-APSEP-MPA030    | -              |
|                                | AMEC ←→                         | SRGD4R<br>RCA2/RCL     | 5m           | CB-APSEP-MPA050    | -              |
| luda awada d                   |                                 |                        | 1m           | CB-PSEP-MPA010     | -              |
| Integrated motor-encoder cable | PMEC ←→                         | RCP2                   | 3m           | CB-PSEP-MPA030     | -              |
|                                |                                 |                        | 5m           | CB-PSEP-MPA050     | -              |
|                                | PMEC ←→ RCP2-RTBS/RTBSI         | RCP2-RTBS/RTBSL        | 1m           | CB-RPSEP-MPA010    | -              |
|                                | TWEO                            | -RTCS/RTCSL            | 3m           | CB-RPSEP-MPA030    | -              |
|                                |                                 |                        | 5m           | CB-RPSEP-MPA050    | -              |
|                                | AMEC ←→                         | DCA                    | 1m           | CB-ASEP-MPA010     | -              |
|                                | AMEC C RCA                      |                        | 3m           | CB-ASEP-MPA030     | -              |
|                                |                                 |                        | 5m           | CB-ASEP-MPA050     | -              |
|                                |                                 |                        | 2m           | CB-APMEC-PIO020-NC | -              |
|                                | I/O cable                       |                        |              | CB-APMEC-PIO030-NC | -              |
|                                |                                 |                        | 5m           | CB-APMEC-PIO050-NC | -              |
|                                | USB cable                       |                        | 3m           | CB-SEL-USB030      | _              |

Slider Type

Mini

Standard

Rod

Type

Mini

Controllers

Table/Arm /Flat Type

Mini

Standard

Gripper/

Linear Servo Type

Splash-Proof

Controllers

PMEC /AMEC

ROBO NET

PCON

ACON

PSEL

ASEL


XSEL

Pulse Moto

Servo Motor (24V)

Servo Moto (200V)

Linear Servo Moto




485 PMEC/AMEG



[RCP2 small rotary]-[PMEC] Motor encoder integrated cable for indirect connection \*Enter cable length (L) required in  $\square$  (compatible for up to max. 20m). Example: 080=8m **CB-RPSEP-MPA** Model Mechanical side Pin number Black [ ØA ] White [ VMM ] Brown [ Ø/A ] A1 B1 A2 B2 A3 Green [ØB] Yellow [VMM] Red [Ø/B] ВЗ Orange [LS+]
Gray [LS-]
Red [A+]
Green [A-]
Black [B+] A6 B6 A7 B7 # 15 16 A8 B8 A4 B4 A5 Brown [B-] Controller side Mechanical side Brown (label)[BK-] Green (label)[GNDLS] 10 20 18 17 19 Min. bend radius r=68mm or larger (when movable unit is used) Red (label)[VPS]
White (label)[VCC]
Yellow (label)[GND] B10 Shield [ FG ](FG) I/O cable for PMEC-C/AMEC-C CB-APMEC-PIO ....-NC \*The 3 types differ in cable length: 020=2m, 030=3m, 050=5m Model Electric wire colo Pin NO. Signal Brown Orange Yellow Green 6 Blue Purple Grey Flat cable (10 pin) White Output 10 Black

Model C/CW 3-position controller for RCP2/RCP3





Model C/CW 3-position controller for RCA/RCA2/RCL **Position Controller** 

When mounting the absolute battery unit,

#### Feature

Controllers
Integrated

Rocallers
Mini

Standard
Controllers
Integrated

Table/Arm
/Flat Type


Mini

Standard

Gripper
Rotary Type

#### 1 Can operate with same signal as a solenoid valve.

The signal that operates the actuator is the same as the signal that operates the air cylinder. Therefore, the PLC program currently in use can be used without modification even if the air cylinder is replaced by an electric-powered cylinder. Either a single solenoid or a double solenoid may be used.




#### 2 Establishes a dustproof type that supports IP53.

We provide dustproof type controllers with an IP53 equivalent (\*1) protection structure, so that the controller can be mounted outside the control panel.

(1) Bottom surface excluded.





#### 3 Provides the simple absolute type that can be operated immediately upon power-ON without homing.


Since the simple absolute type can store the current position with the assistance of the absolute battery unit during power-up or after the emergency stop is deactivated; it can start the next operation at that position.

(Note 1) When the actuator is connected to the simple absolute type controller, the model is considered an incremental model.
(Note 2) It can not be used for the linear servo type.

#### 4 Pushing and intermediate stop operation is available.

Like air cylinders, the pushing operation is available. In this operation, you can stop with a rod being pushed to a workpiece.

Since the force for the push operation is adjustable within a range between 20 to 70  $\,\%$  of the maximum pushing force and a signal is generated when it reaches the specified pushing force, it can be used to determine clamping or size of workpieces.



Push force is adjustable within the range of 20 to 70% of the maximum pushing force

PMEC /AMEC PSEP /ASEP ROBO NET ERC2 PCON ACON SCON PSEL



#### 5 Easy data entry with the dedicated touch panel teaching unit.

Data, such as setting target positions or pushing force, are easily entered with the optional touch panel teaching model: CON-PT.

Since the touch panel teaching unit provides an interactive menu and can be controlled directly on the screen, you can operate intuitively with no assistance from operation manuals.




487 PSEP/ASEP




#### Model List

| Series name         |  | PS                         | EP   |  | ASEP   |                            |  |                            |
|---------------------|--|----------------------------|--|--|--|----------------------------|--|----------------------------|
| Type                | С  |                            | CW   |  | С  |                            | CW   |                            |
| Name                | Stan   | dard                       | Dustproof  |  | Standard   |                            | Dust proof   |                            |
| Positioning method  | Incremental<br>encoder   | Simple<br>absolute<br>type | Incremental<br>encoder   | Simple<br>absolute<br>type   | Incremental<br>encoder   | Simple<br>absolute<br>type | Incremental<br>encoder   | Simple<br>absolute<br>type |
| External View       |  |                            |  | THE STATE OF THE S |  |                            |  |                            |
| Description         | Position controller, for pulse motors, specialized to 2 positions / 3 positions positioning and easier control |                            | PSEP-C dustproof type with an<br>IP53 equivalent protection<br>structure |  | Position controller, for servo motors,<br>specialized to 2 positions / 3 positions<br>positioning and easier control |                            | ASEP-C dustproof type with an<br>IP53 equivalent protection<br>structure |                            |
| Number of positions |  |                            |  | 2 positions  | / 3 positions  |                            |  |                            |
| Standard price      | -  | -                          | -  | -  | -  | -                          | -  | -                          |

#### Model





IAI

PSEP / ASEP 488



Splash-Proo

Controllers

PMEC
/AMEC

PSEP
/ASEP

ROBO
NET

ERC2

PCON

ACON

SCON


PSEL

ASEL

#### Slider Type

#### System structure

#### [PSEP]




489 PSEF



#### System structure

#### [ASEP]



Pulse Moto

PMEC AMEC PSEP ASEP ROBO NET PCON ACON SCON PSEL

Mini
Standard
Controllers
Integrated
Rod
Type
Mini
Standard
Controllers
Integrated
Table/Arm
Plat Type

Servo Motor (24V)

> ervo Motor !00V)

Linear Servo Moto

IAI

PSEP / ASEP **490** 

#### PSEP / ASEP Controller

#### PIO Pattern Description

Mini
Standard
Controllers
Integrated
Roc
Type
Mini
Standard
Controllers
Integrated
Table/Arm
/Flat Type
Mini
Standard

The SEP controller provides the following six PIO patterns from which you can choose for operation. Also, PIO patterns 0 to 2 support both the single solenoid and double solenoid signal configurations.

| PIO<br>Pattern Nu       | mber | (                         | )                                 | 1                         | l                 | 2                         | 2                               | 3   | 4   | 5  |
|-------------------------|------|---------------------------|-----------------------------------|---------------------------|-------------------|---------------------------|---------------------------------|---|---|--|
| PIO<br>Pattern Na       | ame  |                           | 2-position<br>ement               | Moving spe                | eed change        |                           | n Data<br>inge                  | 2-input 3-position travel                   | 3-input 3-position travel                   | Continuous cycle operation                       |
|                         |      |                           | ous cycle<br>ation                | 2-positio                 | n motion          | 2-positio                 | n motion                        | 3-position motion                           | 3-position motion                           | Continuous motion between 2 positions            |
| Feature                 | e    | Pu                        | ısh                               | Pu                        | sh                | Pu                        | sh                              | Push  | Push  | Push   |
|                         |      | -                         | -                                 | Changin<br>during         | g speed<br>motion |                           | position<br>hange               | -   | -   | -  |
| Supported so configurat |      | Single                    | Double                            | Single                    | Double            | Single                    | Double                          | -   | -   | -  |
|                         | 0    | Motion signal             | Motion signal 1                   | Motion signal             | Motion signal 1   | Motion signal             | Motion signal 1                 | Motion signal 1                             | Retract motion signal                       | Continuous operation signal                      |
| lanua                   | 1    | Pause<br>signal           | Motion signal 2                   | Pause<br>signal           | Motion signal 2   | Pause<br>signal           | Motion signal 2                 | Motion signal 2                             | Extend<br>motion signal                     | Pause signal                                     |
| Input                   | 2    | (Reset                    | -<br>signal)                      | Moving spe<br>signal (res |                   |                           | tion change<br>et signal)       | -<br>(Reset signal)                         | Intermediate motion signal (reset signal)   | -<br>(Reset signal)                              |
|                         | 3    | /Servo-C                  | -<br>DN signal                    | /Servo-C                  | -<br>ON signal    | /Servo-C                  | -<br>DN signal                  | -<br>/Servo-ON signal                       | -<br>/Servo-ON signal                       | -<br>/Servo-ON signal                            |
|                         | 0    |                           | motion<br>signal                  | Retract<br>output         |                   |                           | motion<br>signal                | Retract motion output signal                | Retract motion output signal                | Retract motion output signal                     |
| Outrout                 | 1    |                           | motion<br>signal                  | Extend output             |                   |                           | motion<br>signal                | Extend motion output signal                 | Extend motion output signal                 | Extend motion output signal                      |
| Output                  | 2    | Homing comp<br>Servo-ON o | oletion signal /<br>output signal | Homing comp               |                   | Homing com<br>/Servo-ON c | pletion signal<br>output signal | Midpoint position output signal             | Midpoint position output signal             | Homing completion signal /Servo-ON output signal |
|                         | 3    | Alarm out                 | put signal<br>output signal       | Alarm out<br>/Servo-ON o  |                   |                           | put signal<br>output signal     | Alarm output signal /Servo-ON output signal | Alarm output signal /Servo-ON output signal | Alarm output signal /Servo-ON output signal      |

<sup>\*</sup> For the signals above, see the controller manuals (downloadable from our website).


#### PIO Pattern 0 (Standard 2-Position travel)

This PIO pattern involves movements between two positions—the end position and the home position.

The positions can be set numerically to any position (by inputting to the controller using the optional touch panel teaching pendant).

Two motions are possible: A "positioning motion" moves the rod or the slider to the specified position, and a "pushing motion" pushes the rod against a workpiece.

#### Positioning Motion (Single Solenoid)



| Position      | 30          |         |
|---------------|-------------|---------|
| Speed         | 100         |         |
| Pushing force | -           |         |
| Width         | -           |         |
| (Home p       | Speed Speed | l: 50mr |

m/s

| Home Position Data |    |  |  |  |
|--------------------|----|--|--|--|
| Position 0         |    |  |  |  |
| Speed              | 50 |  |  |  |
| Pushing force      | -  |  |  |  |
| Width              | -  |  |  |  |
|                    |    |  |  |  |

# Input Signals Input 0 ON Input 1 Input 2 -

Input 3

When Input 0 is turned ON, the slider/rod moves to the end position (30mm coordinate) at a speed of 100mm/s.

#### Input Signals

| Input 0 | OFF |
|---------|-----|
| Input 1 | -   |
| Input 2 | -   |
| Input 3 | 1   |


When input 0 is turned OFF, the slider/rod returns to the home position (0mm coordinate) at a speed of 50mm/s.

491


PSEP / ASE



#### Positioning Motion (Double Solenoid)



| End Position Data |     |  |  |  |  |
|-------------------|-----|--|--|--|--|
| Position 30       |     |  |  |  |  |
| Speed             | 100 |  |  |  |  |
| Pushing force     | -   |  |  |  |  |
| Width –           |     |  |  |  |  |



| Home Position Data |    |
|--------------------|----|
| Position           | 0  |
| Speed              | 50 |
| Pushing force      | -  |
| Width              | -  |

#### Innut Signals

| iliput olyllais |     |
|-----------------|-----|
| Input 0         | OFF |
| Input 1         | ON  |
| Input 2         | -   |
| Input 3         | -   |


When Input 1 is turned ON and Input 0 is turned OFF, the slider/rod moves to the end position (30mm coordinate) at a speed of 100mm/s.

| ais |
|-----|
| ON  |
| OFF |
| -   |
| -   |
|     |

s turned ON and Input 1 is turned OFF, eturns to the home position (0mm a speed of 50mm/s.

| put 0 | ON  | When Input 0 is<br>the slider/rod r<br>coordinate) at a |
|-------|-----|---|
| put 1 | OFF |   |
| put 2 | -   |   |
| put 3 | -   |   |
|       |     |   |

#### Push motion (single solenoid)




| End Position Data |     |
|-------------------|-----|
| Position          | 30  |
| Speed             | 100 |
| Pushing force     | 50  |
| Width             | 10  |

| input Oigii | uio |
|-------------|-----|
| Input 0     | ON  |
| Input 1     | -   |
| Input 2     | -   |
| Input 3     | _   |

When Input 0 is turned ON, the rod moves to the 20mm position at 100mm/s, and then starts pushing from the 20mm position to the 30mm position at slow speed.

\* The pushing motion is performed only if there is a numerical value for the pushing force in the controller's position data. (If there is no numerical value for the pushing force, a positioning motion will be performed instead.)

#### Push motion (double solenoid)



| End Position Data |     |
|-------------------|-----|
| Position          | 30  |
| Speed             | 100 |
| Pushing force     | 50  |
| Width             | 10  |

#### Input Signals

| OFF |
|-----|
| ON  |
| -   |
| _   |
|     |

When Input 1 is turned ON and Input 0 is turned OFF, the rod moves to the 20mm position at 100mm/s, and then starts pushing from the 20mm position to the 30mm position at slow speed.

\* The pushing motion is performed only if there is a numerical value for the pushing force in the controller's position data. (If there is no numerical value for the pushing force, a positioning motion will be performed instead.)

IAI




















































ntrollers ntegrated Rod Type Mini


#### PIO Pattern 1 (Speed Change During Movement)

This PIO pattern involves movements between two positions—the end position and the home position.

The speed can be changed in 2 stages. (The speed can be either increased or decreased.)

The speed change occurs when the rod/slider passes the speed change position, specified in the position values.

# Speed (mm/s) Home position (0) (End position 1)



| Input Signals |         |    |
|---------------|---------|----|
|               | Input 0 | ON |
|               | Input 1 | 1  |
|               | Input 2 | ON |
|               | Input 3 | _  |

When Input 0 is turned ON while Input 2 is turned ON, the rod moves at the initial speed up to the trigger point.

After it passes the trigger point, the speed changes. If Input 2 is not turned ON, the speed will not change.

| Home Position Data |     |
|--------------------|-----|
| Position           | 0   |
| Speed              | 50  |
| Trigger point      | 12  |
| Trigger speed      | 100 |
| Pushing force      | -   |
| Width              | -   |


| End Position Data |     |
|-------------------|-----|
| Position          | 30  |
| Speed             | 100 |
| Trigger point     | 12  |
| Trigger speed     | 50  |
| Pushing force     | 1   |
| Width             | _   |


#### PIO Pattern 2 (Position Change)

This PIO pattern involves movements between two positions—the end position and the home position.

You can set 2 sets of data for the end / home positions, speed, pushing force, and pushing width.

Switching between the 2 sets of data can be done by turning ON/OFF Input 2, which is the signal for switching the target position.





Input Signals

Input 0 ON

Input 1 
Input 2 ON

Input 3 -

If Input 2 (position change signal) is OFF when Input 0 is turned ON, the rod moves according to the position and speed set in "End Position Data 1" (position: 30 / speed: 100).

If Input 2 is ON when Input 0 is turned ON, the rod's movement changes to the position and speed set in "End Position Data 2" (position: 20 / speed: 50). If Input 2 is OFF when the movement starts, but is turned ON in transit, the target position and speed is changed from that position.

| P | socialist and opera is orial god from that |     |
|---|--|-----|
|   | End Position Data 1                        |     |
|   | Position                                   | 30  |
|   | Speed                                      | 100 |
|   | Pushing force                              | 1   |
|   | Width                                      | -   |
|   |  |     |


| End Position Data 2 |    |  |  |  |  |
|---------------------|----|--|--|--|--|
| Position            | 20 |  |  |  |  |
| Speed               | 50 |  |  |  |  |
| Pushing force       | -  |  |  |  |  |
| Width               | -  |  |  |  |  |
|                     |    |  |  |  |  |

493 PSEP


This PIO pattern involves movements between 3 positions-the end position, the home position, and an intermediate position.

Changing between the positions is done by a combination of 2 signals, Input 0 and Input 1.

Positioning Motion
(Home position)



| (Intermediate position) |
|-------------------------|
| (10)                    |



#### Input Signals

| Input 0 | ON  |  |
|---------|-----|--|
| Input 1 | OFF |  |
| Input 2 | 1   |  |
| Input 3 | -   |  |

When only Input 0 is turned ON, the rod moves to the home position at the specified speed.

| iiput Signais |    |  |  |  |
|---------------|----|--|--|--|
| Input 0       | ON |  |  |  |
| Input 1       | ON |  |  |  |
| Input 2       | -  |  |  |  |
| Input 3       | -  |  |  |  |

When Input 0 and Input 1 are both turned ON, the rod moves to the intermediate position at the specified speed.

#### Input Signals

| input Oignais |    |  |  |
|---------------|----|--|--|
| Input 0 OFF   |    |  |  |
| Input 1       | ON |  |  |
| Input 2       | -  |  |  |
| Input 3 -     |    |  |  |

When only Input 1 is turned ON, the rod moves to the end position at the specified speed.


#### PIO Pattern 4 (3-Input 3-Position Travel)


This PIO pattern involves movements between 3 positions—the end position, the home position, and an intermediate

position.

Changing between positions is done by three signals—Input 0, Input 1 and Input 2, which are commanded to move to the home, end and intermediate positions, respectively.

#### **Positioning Motion**





#### Input Signals

| Input 0 | ON  |  |
|---------|-----|--|
| Input 1 | OFF |  |
| Input 2 | OFF |  |
| Input 3 | _   |  |

moves to the home position at the specified speed.

#### Input Signals

| Input 0 | OFF |  |
|---------|-----|--|
| Input 1 | OFF |  |
| Input 2 | ON  |  |
| Input 3 | _   |  |

When Input 2 is turned ON, the rod moves to the intermediate position at the specified speed.

When Input 0 is turned ON, the rod

#### Input Signals

| Input 0 | OFF |
|---------|-----|
| Input 1 | ON  |
| Input 2 | OFF |
| Input 3 | -   |
|         |     |

When Input 1 is turned ON, the rod moves to the end position at the specified speed.

#### PIO Pattern 5 (Continuous Cycle Operation)


This PIO pattern involves continuous cycling between 2 positions—the end and home positions.

When Input 0 (continuous operation signal) is turned ON, the rod continuously moves between the specified 2

If Input 0 is turned OFF while in motion, it stops after reaching the current destination.

(Intermediate position)

#### Positioning Motion



#### Input Signals

| Input 0 | ON |
|---------|----|
| Input 1 | -  |
| Input 2 | _  |
| Input 3 | 1  |

When Input 0 is turned ON, the rod moves continuously between the end and home positions at the specified speed.

IAI



















































#### PSEP / ASEP Controller



































#### I/O Signal

| Pin<br>No. | Cable color | PIO pattern      |   | 0                             |           | 1            |        | 2               |         | 3                            | 4                            | 5                          |  |
|------------|-------------|------------------|---|-------------------------------|-----------|--------------|--------|-----------------|---------|------------------------------|------------------------------|----------------------------|--|
|            |             | PIO pattern name |   | Standard<br>2-position motion |           | Speed change |        | Position change |         | 2-input<br>3-position travel | 3-input<br>3-position travel | Continuous cycle operation |  |
|            |             | Solenoid type    |   | Single                        | Double    | Single       | Double | Single          | Double  | -                            | ı                            | -                          |  |
| 1          | Brown       | сом              |   | 24V                           |           | 24V          |        | 24V             |         | 24V                          | 24V                          | 24V                        |  |
| 2          | Red         | сом              |   | ov                            |           | ov           |        | 0V              |         | 0V                           | 0V                           | 0V                         |  |
| 3          | Orange      |                  | 0 | ST0                           | ST0       | ST0          | ST0    | ST0             | ST0     | ST0                          | ST0                          | ASTR                       |  |
| 4          | Yellow      | Input            | 1 | *STP                          | ST1(-)    | *STP         | ST1(-) | *STP            | ST1 (-) | ST1                          | ST1(-)                       | -/*STP                     |  |
| 5          | Green       |                  | 2 | -(RES)                        |           | SPDC(RES)    |        | CN1(RES)        |         | -(RES)                       | ST2(RES)                     | -(RES)                     |  |
| 6          | Blue        |                  | 3 | -/8                           | ON        | -/SON        |        | -/SON           |         | -/SON                        | -/SON                        | -/SON                      |  |
| 7          | Purple      |                  | 0 | LS0                           | /PE0 LS0/ |              | /PE0   | LS0/PE0         |         | LS0/PE0                      | LS0/PE0                      | LS0/PE0                    |  |
| 8          | Grey        | Output           | 1 | LS1                           | /PE1      | LS1/PE1      |        | LS1/PE1         |         | LS1/PE1                      | LS1/PE1                      | LS1/PE1                    |  |
| 9          | White       |                  | 2 | HEN                           | D/SV      | HEND/SV      |        | HEND/SV         |         | LS2/PE2                      | LS2/PE2                      | HEND/SV                    |  |
| 10         | Black       |                  | 3 | *ALI                          | M/SV      | *ALM/SV      |        | *ALM/SV         |         | *ALM/SV                      | *ALM/SV                      | *ALM/SV                    |  |

Note: The above signals marked with \* are normally ON and turn OFF when active.

#### Specification Table


| Position    |                                  | Item                            | Туре   |                              |          |                     |       |               |                  |  |  |  |
|--|----------------------------------|---------------------------------|--|------------------------------|----------|---------------------|-------|---------------|------------------|--|--|--|
| C  |                                  |                                 | PSEI   | •                            |          |                     |       |               |                  |  |  |  |
| Number of control   xes   Position=Type  | Controller type                  |                                 | С  | CW                           |          | C CW                |       |               |                  |  |  |  |
| Number of position   Supposition   Suppos    | Connected actua                  | ators                           | RCP2/RCP3 ser  | RCA/RCA2/RCL series actuator |          |                     |       |               |                  |  |  |  |
| Number of positions   3 positions   4 positions   2 positions   3 positions   4 positions   3 positions   4 pos    | Number of contr                  | ol axes                         | 1  |                              |          |                     |       |               |                  |  |  |  |
| Backup memory   Connector   10 pin connector   1    | Operating metho                  | od                              | Positioner Type  |                              |          |                     |       |               |                  |  |  |  |
| 10   | Number of positi                 | ions                            | 2 positions/3 positions (4 positions*2)  |                              |          |                     |       |               |                  |  |  |  |
| Number of I/O points   Stempt points   4 citput points   4 citp    | Backup memory                    |                                 | EEPROM   |                              |          |                     |       |               |                  |  |  |  |
|  |                                  |                                 | 10 pin connector   |                              |          |                     |       |               |                  |  |  |  |
| Dedicated type for serial communication  | Number of I/O po                 | oints                           | 4 input points / 4 output points   |                              |          |                     |       |               |                  |  |  |  |
| CB-APSEP-PIO   CB-APSEP-PIO   CB-APSEP-PIO   CB-APSEPW-PIO     | I/O power supply                 | 1                               | External power supply DC24V±10%  |                              |          |                     |       |               |                  |  |  |  |
| Position detection   Incremental encoder (Attaching an absolute battery unit makes the simple absolute specification possible "3)  | Dedicated type f                 | or serial communication         | RS485 1ch  |                              |          |                     |       |               |                  |  |  |  |
| Motor-encoder cable   For RCP2 connection   CB-PSEP-MPA       (Connection not possible)   (CB-ASEP-MPA   | Communication ca                 | ble for peripheral equipment    | CB-APSEP-PIO CB-APSEPW-PIO CB-APSEP-PIO CB-APSE  |                              |          |                     |       |               |                  |  |  |  |
| Motor-encoder cable   For RCA connection   (Connection not possible)   CB-ASEP-MPA   | Position detection               | on method                       | Incremental encoder (Attaching an absolute battery unit makes the simple absolute specification possible *3) |                              |          |                     |       |               |                  |  |  |  |
| Cable For RCP3/RCA2 connection   CB-RPSEP-MPA   (Connection not possible)  Input voltage   DC24±10%  Controlled power supply capacity   0.5A (0.8A for the simple absolute specification)    Note   Pated value   Max.('4)   Motor power output   Pated value   Max.('4)   Power-saving'(5)   Motor power output   Pated value   Max.('4)   Motor power output   Pated value   Power-saving'(5)   Motor power output   Pated value   Max.('4)   Motor power output   Power-saving'(5)   Motor power ou |                                  | For RCP2 connection             | CB-PSEP-M  | (Connection not possible)    |          |                     |       |               |                  |  |  |  |
| Toput voltage  | Motor-encoder                    | For RCA connection              | (Connection no   | t possible)                  |          | CB-ASEP-I           | ИРА□□ |               |                  |  |  |  |
| DC24V±10%   O.5A (0.8A for the simple absolute specification)  | cable                            | For RCP3/RCA2 connection        | CB-APSEP-MPA 🗆 🗆   |                              |          |                     |       |               |                  |  |  |  |
| Motor size   Rated value   Max.(*4)   Motor power output   Rated value   Power saving (*5)   Standard (*6) high-acceleration (**)  |                                  | For RCP2 mini rotary connection | CB-RPSEP-N   | CB-RPSEP-MPA 🗆 (Connec       |          |                     |       |               | on not possible) |  |  |  |
| Motor size   Rated value   Max.(*4)   Motor power output   Rated value   Power saving (*5)   Standard (*6) high-acceleration (*5)  | Input voltage                    |                                 | DC24V±10%  |                              |          |                     |       |               |                  |  |  |  |
| Motor size   Rated value   Max.(*4)   Motor power output   Rated value   Power saving (*5)   Standard (*6) high-acceleration (*5) section (*5) sec   | Controlled power supply capacity |                                 | 0.5A (0.8A for the simple absolute specification)  |                              |          |                     |       |               |                  |  |  |  |
| 20P   0.4A   2.0A   2W   0.8A   Not specified   4.6A   | Motor power capacity             |                                 |  |                              | Max.(*4) | <b></b>             | Rated |               |                  |  |  |  |
| 20P   0.4A   2.0A   2W   0.8A   Not specified   4.6A   28P   0.4A   2.0A   5W   1.0A   Not specified   6.4A   2.0A   5W   1.0A   Not specified   6.4A   2.0A   10W (for RCL)   1.3A   Not specified   6.4A   2.0A   10W (for RCA/RCA2)   1.3A   2.5A   4.4A   2.0A   2.0A   20W   1.3A   2.5A   4.4A   2.0A   2.0A   2.0B     |                                  |                                 | Motor size   | Hated value                  |          | Motor power output  | value |               | acceleration /   |  |  |  |
| Motor power capacity    28P   0.4A   2.0A   5W   1.0A   Not specified   6.4A     35P   1.2A   2.0A   10W (for RCL)   1.3A   Not specified   6.4A     42P   1.2A   2.0A   10W (for RCA/RCA2)   1.3A   2.5A   4.4A     56P   1.2A   2.0A   20W   1.3A   2.5A   4.4A     20W (for 20S motor)   1.7A   3.4A   5.1A     30W   1.3A   2.2A   4.4A  |                                  |                                 | 20P  | 0.4A                         | 2.0A     | 2W                  | 0.8A  |               |                  |  |  |  |
| Motor power capacity  35P 1.2A 2.0A 10W (for RCL) 1.3A Not specified 6.4A 42P 1.2A 2.0A 10W (for RCA/RCA2) 1.3A 2.5A 4.4A 56P 1.2A 2.0A 2.0W 1.3A 2.5A 4.4A  |                                  |                                 | 28P  | 0.4A                         | 2.0A     | 5W                  | 1.0A  | Not specified |                  |  |  |  |
| 56P         1.2A         2.0A         20W         1.3A         2.5A         4.4A           -         -         -         20W (for 20S motor)         1.7A         3.4A         5.1A           -         -         -         30W         1.3A         2.2A         4.4A   |                                  |                                 | 35P  | 1.2A                         | 2.0A     | 10W (for RCL)       | 1.3A  |               | 6.4A             |  |  |  |
| -         -         20W (for 20S motor)         1.7A         3.4A         5.1A           -         -         -         30W         1.3A         2.2A         4.4A  |                                  |                                 | 42P  | 1.2A                         | 2.0A     | 10W (for RCA/RCA2)  | 1.3A  | 2.5A          | 4.4A             |  |  |  |
| 30W 1.3A 2.2A 4.4A   |                                  |                                 | 56P  | 1.2A                         | 2.0A     | 20W                 | 1.3A  | 2.5A          | 4.4A             |  |  |  |
|  |                                  |                                 | -  | -                            | -        | 20W (for 20S motor) | 1.7A  | 3.4A          | 5.1A             |  |  |  |
| Inrush current (*1) Max. 10A   |                                  |                                 | _  | -                            | -        | 30W                 | 1.3A  | 2.2A          | 4.4A             |  |  |  |
|  | Inrush current (*1)              |                                 | Max. 10A   |                              |          |                     |       |               |                  |  |  |  |
| Amount of heat generated 8.4W 9.6W   | Amount of heat g                 | generated                       | 8.4W 9.6W  |                              |          |                     |       |               |                  |  |  |  |
| Dielectric strength voltage DC500V 1MΩ   | Dielectric strength voltage      |                                 | DC500V 1MΩ   |                              |          |                     |       |               |                  |  |  |  |
| XYZ directions 10-57Hz One-side width 0.035mm (continuous), 0.075mm (intermittent)   | Resistance to vibration          |                                 | XYZ directions 10~57Hz One-side width 0.035mm (continuous), 0.075mm (intermittent)                           |                              |          |                     |       |               |                  |  |  |  |
| Hesistance to vibration 58~150Hz 4.9m/s² (continuous), 9.8m/s² (intermittent)  |                                  |                                 | 58~150Hz 4.9m/s <sup>2</sup> (continuous), 9.8m/s <sup>2</sup> (intermittent)                                |                              |          |                     |       |               |                  |  |  |  |
| Ambient operating temperature 0~40°C   | Ambient operating temperature    |                                 | 0~40°C   |                              |          |                     |       |               |                  |  |  |  |
| Ambient operating humidity 10~85%RH (non-condensing)   | Ambient operating humidity       |                                 | 10~85%RH (non-condensing)  |                              |          |                     |       |               |                  |  |  |  |
| Ambient operating environment No corrosive gases   | Ambient operating environment    |                                 | No corrosive gases   |                              |          |                     |       |               |                  |  |  |  |
| Protection level         IP20         IP53 (*7)         IP20         IP53 (*7)   | Protection level                 |                                 | IP20   | IP53 (*                      | 7)       | IP20                |       | IP53 (*7)     |                  |  |  |  |
| Weight         About 130g         About 160g         About 130g         About 160g   | Weight                           |                                 | About 130g   | About 1                      | 60g      | About 130g Abo      |       |               | bout 160g        |  |  |  |


- (\*1) Upon power-ON, an electrical current of 5 to 12 times as much as the rated current, called "in rush current" flows for 1 to 2 ms. Note that the amount of inrush current

- (\*1) Upon power-ON, an electrical current of 5 to 12 times as much as the rated current, called "in rush current" flows for 1 to 2 ms. Note that the amount of inrush current varies based on the impedance of power source lines.
  (\*2) This applies to the case where two position data points are set at each of the end and home positions during a "position change" motion pattern process.
  (\*3) The simple absolute type controllers cannot be used for the linear servo type.
  (\*4) The current reaches its maximum level during the servo motor excitation phase detection performed during the initial servo ON process after the power has been turned on. (Usually: Approx. 1 to 2 seconds, max. 10 seconds.)
  (\*5) When power to the motor is turned ON after shutting it OFF, current of about 6.0 A flows (for aprox.1~2ms).
  (\*6) The max. value of current can be detected in the magnetic pole detection process or during collision or constraint. The condition continues for up to 10 seconds in the magnetic pole detection process. In this process the above current is required.
  (\*7) The bottom surface is excluded.


PSEP / ASEP


#### Names





#### Outer dimensions





IAI

**496** 





Mini
Standard
Controllers
Integrated
Rod
Type
Mini
Standard
Controllers
Integrated
Mini
Standard
Standard

## Option

## **Touch Panel Teaching Pendant for Position Controller**

A data input device with an intuitive touch panel menu Feature 1 screen that is easy to operate, even for first-time users. You can use it to configure settings such as home / end positions, intermediate position, speed, and pushing force, or to run an adjustment operation such as jogging, inching, and moving to a specified position.





Large, easy to read display

Monitor

Position Edit

Parameter Edit

Data Back-up

Easy configuration with the touch panel Backlight color changes when an error occurs

Return

Message No. 112

Input data error

Axis No. 00

Inquiry

## ■ Model & Specifications

| Item                             |  | Desci              | ription  |                               |  |  |
|----------------------------------|--|--------------------|--|-------------------------------|--|--|
| Model                            | CON-PT-M-ENG   | CON-PD-M-ENG       | CON-PG-M-S-ENG   | SEP-PT-ENG                    |  |  |
| Туре                             | Standard type  | Enable switch type | Safety compliant type  | SEP controller dedicated type |  |  |
| Connectible controllers          |  | PSEP<br>ASEP       |  |                               |  |  |
| 3-position enable switch         | ×  | 0                  | 0  | ×                             |  |  |
| Functions                        | Input and edit position data<br>Movement functions (move to specified position, jog, inch)<br>Test input and output signals<br>Edit parameters |                    |  |                               |  |  |
| Display                          |  | 3-color LED        | with backlight   |                               |  |  |
| Operating ambient temp./Humidity |  | 0~50°C 20~85% RI   | H (non-condensing)   |                               |  |  |
| Environmental resistance         |  | IP                 | 40   |                               |  |  |
| Weight (incl. 5m cable)          | Approx. 750g   | Approx. 780g       | Approx. 780g   | Approx. 550g                  |  |  |
| Accessories                      | • Touch pen  | • Touch pen        | TP Adapter (Model: RCB-LB-TG) Dummy Plug (Model: DP-4) Controller connection cable (Model: CB-CON-LB005) | • Touch pen                   |  |  |
|                                  |  |                    | Touch pen  |                               |  |  |

(\*) If an ERC2 type controller does not have "4904" on the serial number label, it cannot be connected.

If you have a "CON" type controller (i.e. PCON, RPCON, ACON, RACON, SCON, ERC2) and an "SEP" type controller (PSEP or ASEP) linked together, you cannot connect the teaching pendant to it.

**497** PSEP/ASEP



Mini
Standard
Controllers
Integrated
Rod
Type
Mini
Standard
Controllers
Integrated
Table/Arm
//Flat Typ
Mini
Standard

Controllers

PMEC /AMEC

PSEP //ASEP

ROBO NET

ERC2

PCON

ACON

SCON

PSEL


ASEL








## Absolute battery unit for SEP controllers



## **CON-PG-M-S Wiring Drawing**



ler e

Mini

Mini

Controllers

Rod Type

Mini

Standard

Controllers Integrated

Table/Arm /Flat Type

Mini

Gripper/ Rotary Type

Linear Servo Type

Splash-Proof

Controllers

PMEC /AMEC

ROBO NET

ERC2

ACON

SCON

PSEL

SSEL

XSEL

Pulse Motor

Servo Motor (24V)

Servo Motor (200V)

Linear Servo Moto

IAI

PSEP / ASEP 498





ntegrated


Roc
Type

Mini

# Option

## PC Software (Windows Only)


Features A startup support software for inputting positions, performing test runs, and monitoring. With enhancements for adjustment functions, the startup time is shortened.






■ Model RCM-101-MW


(External device communication cable + RS232 conversion unit)







(External device communication cable + USB adapter + USB cable)



499 PSEP/ASEP



## Absolute battery unit for SEP controllers

Supplied with the PSEP and ASEP simple absolute controllers. Description


This is a battery unit used for backing up the current position data.

SEP-ABU (standard type) Model SEP-ABU-W (dustproof type)

### Specifications

| Item   | Specifications   |                  |                  |                 |  |
|--|--|------------------|------------------|-----------------|--|
| Ambient operating temp./Humidity                 | 0~40°C (around 20°C preferred), 95% RH or below (non-con |                  |                  | non-condensing) |  |
| Ambient operating environment                    | No corrosive ga  | osive gases      |                  |                 |  |
| Absolute battery (*1)                            | Model: AB-7 (Ni-MH battery/Approx. 3-year life)          |                  |                  |                 |  |
| Controller-absolute battery unit cable (*1)      | Model: CB-APSEP-AB005 (0.5m long)                        |                  |                  |                 |  |
| Weight   | Standard type:   | Approx. 230g; Dι | stproof type: Ap | prox. 260g      |  |
| Allowable encoder RPM during data retention (*2) | 800rpm 400rpm  |                  | 200rpm           | 100rpm          |  |
| Position data retention duration (*2)            | 120h   | 240h             | 360h             | 480h            |  |


(\*1) The absolute battery unit comes with a cable to connect the controller and the absolute battery unit. (\*2) Position data retention time changes with the allowable encoder RPMs during data retention. (800rpm→120h, 400rpm→240h, 200rpm→360h, 100rpm→480h)



## **Cautions on Controllers and Options**

- When mounting the controller to a DIN rail, use the supplied spacer between the controllers to prevent them from contacting each other, to deal with heat dissipation. (See Fig. 1)
- · When mounting the absolute battery units and controllers, place the absolute battery units below the controllers. (See Fig. 2)


If there is not enough space below the controllers, mount the absolute battery units in such a way that the temperature around the controllers stays at 40°C or below.




- Teaching pendants for PCON, ACON, and SCON (e.g. CON-T, RCM) cannot be used with PSEP or ASEP. For PSEP and ASEP, use the SEP-PT.
- The SEP-PT cannot communicate to the linked controllers. (Please connect them directly to the controller.)

IAI

PMEC /AMEC PSEP /ASEP ROBO NET ERC2 PCON ACON SCON PSEL ASEL



501 PSEP/ASEP



IAI

PSEP / ASEP **502** 




■ Model :RGW-□/RACON/RPCON/RABU/REXT

For RCA2/RCA/RCL/RCP3/RCP2 **Network Controller** 




ROBONET is a new type of control unit that freely operates ROBO Cylinders via a field network. They have less wiring and are more compact than past controllers, and by DIN rail mounting make it possible to vastly reduce wiring and installation labor.


### **Features**



# **Reduced Wiring**

By connecting each line of the I/O cables to lines wired to the PLC terminals with the field network, wiring processing is completed with one dedicated cable. Also, since the unit can be coupled by just connecting with the unit connection board, the controller wiring work is greatly simplified.





**503** ROBONET



Controllers
Integrated

Roo
Type

Mini

Standard

Controllers
Integrated

## The robot can be moved by directly specifying numeric values for the move position/velocity/acceleration and other data.

Besides the conventional method of moving the robot to pre-taught positions it is also possible to operate the robot by sending information as a string of numeric data that contains position, velocity, acceleration, etc. values. This is effective for cases such as when the move position changes with each piece or when one wants to move the robot to an arbitrary position.

|                                      | ROBONET controller | Standard controller (ACON/PCON)            |
|--------------------------------------|--------------------|--|
| Movement by specifying positions     | 0                  | 0  |
| Movement by specifying direct values | 0                  |  |
| Specifying speed/acceleration        | (Not for PIO)      |  |
| Current value output                 | 0                  | (Connectable with<br>serial communication) |

\*ROBONET operates through a field network,

## **Ultra-compact**


Each unit is an ultra-compact size of 34mm wide by 100mm high x 73mm deep. Also, since there is no base unit and the main unit is coupled with connectors, the controller takes up little space for installation even if there are many units.



## Can operate with a maximum of 16 axes.

Up to 16 controllers can be connected to one communication unit (Gateway R unit).


RACON units (controllers for RCA) and RPCON units (controllers for RCP2) can also be used together.



## Controllers can be multiplexed.

Controllers can be multiplexed using an optional extension unit, so many axes can be connected even if there isn't much horizontal space.

Also, non-ROBONET controllers (SCON, PCON-CF, ERC2) can be connected to a ROBONET Gateway unit using the same extension unit.



# Simple absolute unit, when home return is not required

The simple absolute R unit allows operation for incremental specification axes without home return. Users can back up actuator encoder data even if the power is shut off, by installing a simple absolute R unit to a RACON unit (controller for RCA) or RPCON unit (controller for RCP2).





## Mounting the DIN rail

The controller is installed with DIN rails, so it can be fastened and removed with one touch.

IAI

Controllers

PMEC
/AMEC
PSEP
/ASEP

ROBO
NET

ERC2

PCON


ACON

SCON

sales@electromate.com



### System configuration



## **ROBONET Extension Unit**

If multiple ROBONET extension units (optional) are linked together they can reduce the lateral width needed. It is also possible to connect individual controllers, such as SCON, etc. via the ROBONET.


[Unit Multiplex Set]

**Model: REXT-SIO** 

(Set Contents)

ROBONET Extension Unit (Model: REXT) 2 pc Unit Link Cable 1 pc

(Model: CB-REXT-SIO010)




[Controller Connecting Set]

Model: REXT-CTL

(Set Contents)

ROBONET Extension Unit (Model: REXT) 1 pc Controller Connection Cable 1 pc

(Model: CB-REXT-CTL010)



505 ROBONET



### Configuration unit

Required ROBONET units are ordered individually, and assembled as you see fit. If actuators are added later, they can be easily added simply by adding a RACON/RPCON unit.




| Unit Name              | Description   |              |  |  |  |
|------------------------|---|--------------|--|--|--|
| Gateway<br>R unit      | This unit is for connecting to a field network.  Users can select from 4 types: DeviceNet, CC-Link, ProfiBus, and SIO.  *This unit is required for using ROBONET.   | P508<br>P509 |  |  |  |
| RACON<br>unit          | This controller operates the RCA actuator. (One unit is necessary per actuator axis.)  The incremental specification is the standard, but the simple absolute specification can also be used if the simple absolute R unit is used with it. | P510         |  |  |  |
| RPCON<br>unit          | This controller operates the RCP2 actuator. (One unit is necessary per actuator axis.) The incremental specification is the standard, but the simple absolute specification can also be used if the simple absolute R unit is used with it. | P510         |  |  |  |
| Simple absolute R unit | This is the back-up battery unit that retains actuator encoder data when the power is turned off.   | P511         |  |  |  |
| Extension unit         | This unit makes it possible to reverse ROBONET connections, connect unit controllers (SCON/PCON-CF) to ROBONET, and conduct operation from a network.   | P511         |  |  |  |

## Ordering Method/Precautions

Required ROBONET units are ordered individually and assembled by the customer. Consequently, they can be added to or changed later.

<Ordering example> The following 2 actuator axes can be operated through CC-Link. The models that would be best operated with the absolute specification are as follows.



■ Gateway Parameter **Setting Tool** 

A gateway parameter setting tool is necessary to set up the network when ROBONET is connected to a field network. This tool can be acquired at no cost.

- (1) Download from the IAI website, or
- (2) Acquire PC compatible software (included on CD).

A cable (cable included with PC software, model: CB-RCA-SIO050+RCB-CV-MW) is required to connect the PC to the controller when using the gateway parameter setting tool. If you do not have the PC software, please purchase a cable.

■ PC Compatible **Software Teaching** Pendant

Compatible PC software or a teaching pendant is required to enter position data, etc. to a ROBONET controller unit. ROBONET compatible PC software (Model: RCM-101-MW/USB) version is Ver. 6.00.04.00 or later. Teaching pendant compatible models and versions include: RCM-T and Ver. 2.06 and later, model: RCM-E/RCM-P and Ver. 2.08 and later. Model: CON-T is compatible with all versions from the earliest version.

Consult with our Sales Division if the version your equipment has needs to be updated.

IAI













































































## Operation Mode

ROBONET operates upon receiving commands from the PLC via the field network.

The following four operating modes are available. Select the most suitable mode for the operation or the control method.

|   | Name  | Description   |
|---|---|---|
| 1 | Positioner mode (1,2)  In this mode, operation is done by specifying position numbers, whose position data, speed, and acceleration have been entered to the position table in advance.  A maximum of 768 position points can be saved. |   |
| 2 | Simple direct input mode  | The position data is specified directly using a numerical value; the other settings, such as speed, acceleration, deceleration, positioning band, and pushing current limit are specified using a predefined position number.  A maximum of 768 position points can be saved. |
| 3 | Direct input<br>mode  | The position data, speed, acceleration, deceleration, positioning band, and pushing current limit are all specified directly using numerical values. Since the settings are specified by their numerical values, there is no limit to the number of points that can be set.   |
| 4 | Solenoid valve<br>mode (1,2)  | The number of positioning points is limited for a simpler operation.  You can operate it using the same controls as a solenoid valve, just by sending a command with the target position number (start signal not required).  |

## List of functions for operation modes

| Item          | Operation mode                                      | Positioner 1<br>Mode              | Simple immediate data Mode | Direct number designation mode           | Positioner 2<br>Mode                   | Solenoid Valve<br>Mode 1 | Solenoid Valve<br>Mode 2 |
|---------------|---|-----------------------------------|----------------------------|--|--|--------------------------|--------------------------|
| Each axis fi  | eld (both input and output)                         | 4 words                           |                            | 8 words                                  | 2 words                                | 2 wo                     | ords                     |
| Fixed field ( | both input and output)                              | 8 words<br>(Command field usable) |                            | 8 words<br>(Command field<br>not usable) | 8 words<br>(Command field<br>usable)   | 8 wo<br>(Command         | ords<br>field usable)    |
| Number of s   | set positions                                       | 768 positions/axis                | 768 positions/axis         | -  | 768 positions/axis                     | 7 positions/axis         | 3 positions/axis         |
| Position No   | designation operation                               | 0                                 | 0                          | ×  | 0                                      |                          |                          |
| Position da   | ta direct designation                               | ×                                 | 0                          | 0  | ×                                      | ,                        | •                        |
| Direct desig  | nation of speed and acceleration/deceleration speed | ×                                 | ×                          | 0  | ×                                      | ,                        | •                        |
| Direct desig  | gnation of positioning band                         | ×                                 | ×                          | 0  | ×                                      | ,                        | •                        |
| Pushing op    | eration   | 0                                 | 0                          | 0  | 0                                      |                          | )                        |
| Completed     | position No. monitor                                | 0                                 | 0                          | ×  | 0                                      |                          | )                        |
| Zone outpu    | t monitor   | 0                                 | 0                          | 0  | 0                                      |                          | )                        |
| Position zor  | ne output monitor                                   | 0                                 | 0                          | ×  | 0                                      |                          | )                        |
| Teaching fu   | nction  | 0                                 | ×                          | ×  | 0                                      | ,                        | •                        |
| Jog operati   | Jog operation                                       |                                   | 0                          | 0  | 0                                      | ,                        | •                        |
| Incrementa    | Incremental operation                               |                                   | 0                          | 0  | 0                                      | ,                        | •                        |
| Status signa  | al monitor (*1)                                     | 0                                 | 0                          | 0  | 0                                      | >                        | •                        |
| Current pos   | sition monitor (*1)                                 | 0                                 | 0                          | 0  | 0                                      | ,                        | •                        |
| Alarm code    | monitor (*1)  | 0                                 | 0                          | 0  | 0                                      | ,                        | •                        |
| Speed and     | current monitor (*1)                                | ×                                 | ×                          | 0  | ×                                      | ,                        | •                        |
| Each axis m   | nonitoring function in<br>ode (*2)                  | 0                                 | 0                          | 0  | 0                                      |                          |                          |
|               | Hand shake  | 0                                 | 0                          | ×  | 0                                      |                          |                          |
| Command       | Position table<br>Reading/writing of data           | 0                                 | 0                          | ×  | 0                                      | (                        | )                        |
|               | Reading the current position                        | ×                                 | ×                          | ×  | ×                                      | ,                        | •                        |
|               | Broadcast   |                                   | ×                          | ×  | 0                                      |                          |                          |
| Max. value    | Max. value for position data designation            |                                   | 9999.99mm                  | 9999.99mm                                | 9999.99mm<br>(When command<br>is used) |                          | 99mm<br>nand is used)    |
| Number of a   | axes that can be connected                          | 16                                | 16                         | 8  | 16                                     | 1                        | 6                        |

- Each status signal monitor, current position monitor, alarm code monitor, and speed/current monitor can be viewed by accessing to each \*1: address of Gateway unit via PLC.
- \*2: Traditionally, monitoring each axis in AUTO mode is unavailable. However, monitoring each axis with Mode switch at "AUTO" is available with ROBONET by connecting the special touch panel to the TP connector.
- Independent acceleration and deceleration settings are not available. The setting applies to both accelerating and decelerating speeds.

507 ROBONET

## Configuration unit (Gateway R unit)

## Gateway R Unit for DeviceNet

A communications unit to operate ROBONET via DeviceNet.


## Model RGW-DV

Specifications

| s  |  | Item           | Specifications                             |                              |                | Item  | Specifications                   |                                       |                              |                        |                       |                        |
|--|--|----------------|--|------------------------------|----------------|---|----------------------------------|---------------------------------------|------------------------------|------------------------|-----------------------|------------------------|
|  | Po   | wer            | DC24V ±10%                                 |                              | DC24V ±10%     |   | 2                                |                                       | Comm.<br>Speed               | Max.<br>network length | Max.<br>branch length | Total<br>branch length |
|  | Current consumption                        |                | 600mA max.                                 |                              | catio          | Comm.   | 500kbps                          | 100m                                  |                              | 39m                    |                       |                        |
|  | Standard Standard                          |                | DeviceNet 2.0-cer                          | tified interface module      | Specifications | cable<br>length (*1)  | 250kbps                          | 250m                                  | 6m                           | 78m                    |                       |                        |
|  |  |                | Group 2 only serve                         | er                           |                |   | 125kbps                          | 500m                                  |                              | 156m                   |                       |                        |
| 3  |  |                | Insulated node opera                       | ting on network power supply | DeviceNet      |   | Note: Whe                        | hen using a large cable for DeviceNet |                              |                        |                       |                        |
|  |  | Comm.<br>Spec. |  | Bit strobe                   | _              | No. occupied nodes 1 node   |                                  |                                       |                              |                        |                       |                        |
|  | eNet                                       |                |  | Polling                      | ent<br>ints    | Ambient op.<br>temperature  | 0~40°C                           |                                       |                              |                        |                       |                        |
| 1:   | DeviceNet                                  | ·              |  | Cyclic                       | onme           | Ambient op.<br>temperature<br>Ambient op.<br>humidity<br>Ambient op.<br>environment | 95% RH or below (non-condensing) |                                       |                              |                        |                       |                        |
| ľ.   |  | Comm.<br>Speed | 500k/250k/125kbps (switchable by software) |                              |                | Ambient op.   | No corrosi                       | ve or flammabl                        | e gasses, oil i              | nist, or dust.         |                       |                        |
| *1 If you wish to use T-junction communication, see the instructions manual for your master unit or PLC. |  |                |  | Protection class IP20        |                |   |                                  |                                       |                              |                        |                       |                        |
|  | mondono manda io. you musici unit oi i Eo. |                |  |                              | Weight 140g    |   |                                  |                                       |                              |                        |                       |                        |
|  |  |                |  |                              | Ac             | cessories   | Terminal re<br>Network c         | esistor board (r<br>onnector, Eme     | nodel TN-1)<br>rgency stop o | onnector               |                       |                        |

#### Network cable

MSTBA2.5/5-G-5.08 ABGY AU (Made by: Phoenix Contact)



Connector on Cable Side MSTB2.5/5-ST-5.08 ABGY AU Black Blue (Made by: Phoenix Contact)

= Standard accessory

| Pin Color | Description                   |
|-----------|-------------------------------|
| Black     | Power cable negative (-) side |
| Blue      | Comm. data Low side           |
| -         | Shield                        |
| White     | Comm. data High side          |
| Red       | Power cable plus (+) side     |

A communications unit to operate ROBONET via CC-Link.

#### Cable connector-compatible wiring

| Cable Collicator Compatible Willing |  |  |  |  |
|-------------------------------------|--|--|--|--|
| Item                                | Description                            |  |  |  |
| Wire diameter                       | Twisted wire:<br>AWG24-12 (0.2~2.5mm²) |  |  |  |
| Stripped wire length                | 7mm                                    |  |  |  |

## Gateway R Unit for CC-Link






| ns 🗌 | Item  |                  | Specifications                                       |                            | Item  |                                  | Spe      | cificati | ons       |           |          |
|------|---|------------------|--|----------------------------|---|----------------------------------|----------|----------|-----------|-----------|----------|
|      | Power Supply  |                  | DC24V ±10%   | εrror Control Method       |   |                                  |          |          |           |           |          |
|      | Cur   | rent consumption | 600mA max.   | ecifications               | Station occupancy                               | Remote device                    | e statio | ns: ×1,  | 4 st.; ×4 | l, 2 st.; | ×8, 2 st |
|      |   | Comm. Standard   | CC-Link Ver2.0 (*1)                                  | िक्र                       | Comm. Cable                                     |                                  | 10M      | 5M       | 2.5M      | 625k      | 156k     |
|      | Suc   | Comm. Speed      | 10M/5M/2.5M/625k/156kbps<br>(switchable by software) | į                          | Length (*2)                                     | Total Cable<br>Length (m)        | 100      | 160      | 400       | 900       | 1200     |
| 1    | Specifications  | Comm. Method     | Broadcast polling method                             | ပ္ပ                        | Comm.<br>Cable                                  | Dedicated CC-Link cable          |          |          |           |           |          |
|      | Speci   | Sync. Method     | Frame synchronization method                         | ま                          | Ambient op. temperature                         | 0~40°C                           |          |          |           |           |          |
| 1    | CC-LINK   | Encoding Method  | NRZI   | Invironment<br>equirements | Ambient op.<br>humidity                         | 95% RH or below (non-condensing) |          |          |           |           |          |
| 8    | 3   | Transf. Type     | Bus format (EIA RS485 compliant)                     | Envir<br>Begui             | Ambient op.<br>environment                      | No corrosive o                   | or flamm | able ga  | sses, oi  | l mist, o | or dust. |
|      | Transf. Format HDLC compliant  1 Certification acquired  2 If you wish to use T-junction communication, see the instruction manual for your master unit or PLC. |                  | _  | otection class             | IP20  |                                  |          |          |           |           |          |
|      |   |                  | We   | eight                      | 140g  |                                  |          |          |           |           |          |
| *2   |   |                  | Ac   | cessories                  | Terminal resis<br>Network con<br>Terminal resis | nector,                          | Emèrge   | ency st  | op coni   | nector    |          |

#### **Network cable**

Connector on Gateway Side: Connector on Cable Side: MSTBA2.5/5-G-5.08AU MSTB2.5/5-ST-5.08 ABGY AU (Made by Phoenix Contact) (Made by Phoenix Contact) = Standard accessory



| Signal Name | Description   |
|-------------|---|
| DA          | Communication line A  |
| DB          | Communication line B  |
| DG          | Ground  |
| SLD         | The shield and cable's shield are connected, then they are connected to "FG" and the chassis. |
| FG          | Frame ground Connected to "SLD" and the chassis.  |

Cable connector-compatible wiring

| Oabic connector-compatible wiring |  |  |  |  |  |
|-----------------------------------|--|--|--|--|--|
| Item                              | Description                            |  |  |  |  |
| Wire diameter                     | Twisted wire:<br>AWG24-12 (0.2~2.5mm²) |  |  |  |  |
| Stripped wire length              | 7mm                                    |  |  |  |  |

IAI













































## Configuration unit (Gateway R unit)

## **Gateway R Unit for ProfiBus**

(A)

A communications unit to operate ROBONET via ProfiBus.

#### Model RGW-PR

Specifications

| s  | Item                    | Specifications |       |                             | Item                    | Specifications   |
|----|-------------------------|----------------|-------|-----------------------------|-------------------------|--|
|    | Power Supply DC24V ±10% |                |       | Environment<br>Requirements | Ambient op. temperature | 0~40°C   |
|    | Current<br>Consumption  | 600mA max.     |       | ironn                       | Ambient op. humidity    | 95% RH or below (non-condensing)                                 |
|    | Comm. Standard          | DP slave       |       | Env                         | Ambient op. environment | No corrosive or flammable gases, oil mist, or dust.              |
|    | Comm. Speed             | 9.6kbps~12Mbps |       | Protection class            |                         | IP20   |
|    |                         | 9.6kbps        | 1500m | W                           | eight eight             | 140g   |
| Ι, | Comm. Speed             | 500kbps        | 400m  | A                           | ccessories              | Terminal resistor board (model TN-1)<br>Emergency stop connector |
| 9  | Cable Length            | 1.5Mbps        | 200m  |                             |                         |  |
|    |                         | 3Mbps          | 200m  |                             |                         |  |
| ľ  | -                       | 12Mbps         | 100m  |                             |                         |  |

## Network cable

Connector on Gateway Side: 5
D-Sub connector, 9-pin socket side



Description Pin No. Signal Name Pin No. Signal Name Description B-Line Communication line B (RS485) +5V output (insulated) Communication line A (RS485) RTS 4 Request send 8 A-Line Signal ground (insulated) Housing

# Gateway R Unit for SIO



A communications unit for operating ROBONET from an XSEL controller or a Modbus-compatible communications unit, via serial communication.

## Model RGW-SIO

Specification

| s              | Item                | Specifications   |     | Item                       | Specifications  |
|----------------|---------------------|--|-----|----------------------------|---|
|                | Power Supply        | DC24V ±10%   |     | Ambient op.<br>temperature | 0~40°C  |
| S              | Current consumption | 600mA max.   | nme | Ambient op. humidity       | 95% RH or below (non-condensing)  |
| Specifications | Comm. Type          | RS485-compliant (Modbus protocol) 1:1 communication connection | 2.≦ | Ambient op. environment    | No corrosive or flammable gases, oil mist, or dust.                                 |
| ecific         | Comm. Method        | Asynchronous method, half-duplex                               |     | Protection class           | IP20  |
| SIO Sp         | Comm. Speed         | 230.4kbps max.   |     | ight                       | 140g  |
| ľ              | Cable Length        | Cable Length 100m or less                                      |     | cessories                  | Terminal resistor board (model TN-1)<br>Network connector, Emergency stop connector |
|                | Recommended cable   | 2 pairs of twisted pair cables (shielded)                      |     |                            |   |

#### **Network cable**

Connector on Gateway Side MC1.5/4-G-3.5 (Made by Phoenix Contact)

Connector on Cable Side: MC1.5/4-ST-3.5 (Made by Phoenix Contact) = Standard accessory



| Signal Name | Description  |                          |  |  |
|-------------|--|--------------------------|--|--|
| SA          | Communication line A (+positive side)                          | Built-in RS485-compliant |  |  |
| SB          | Communication line B (-negative side) terminal resistor (2200) |                          |  |  |
| SG          | Signal ground  |                          |  |  |
| FG          | Frame ground connected to the chassis.                         |                          |  |  |

### Cable connector-compatible wiring

| Item                 | Description                             |
|----------------------|---|
| Wire diameter        | Twisted wire:<br>AWG28-16 (0.14~1.5mm²) |
| Stripped wire length | 7mm                                     |

**509** ROBONET



<sup>\*</sup> The matching connector (D-Sub 9-pin connector) is not included. \* Pins 1, 2, 7, and 9 are not connected

## Configuration unit (Controller unit)

## **RACON** unit

### Controller for RCA2/RCA series



Controller unit that is used for RCA2/RCA actuator operation with ROBONET.

Model RACON-12-3

- \* In Model ①, input a motor power output. (See the following table.)
  - ② will need the code "HA" or "LA" specified when a high acceleration/deceleration or power saving actuator is to be used. (Otherwise, leave it blank.)

    ③ input "ABU" only when a simple absolute unit is used. (Otherwise, leave it blank.)

| Model        | Compatible actuators   |  |  |  |  |  |
|--------------|--|--|--|--|--|--|
| RACON-22-3   | RCL-SA1L / SA4L / SM4L / RA1L  |  |  |  |  |  |
| RACON-52-3   | RCL-SA2L / SA5L / SM5L / RA2L  |  |  |  |  |  |
| RACON-102-3  | RCA2-SA3C / RN3N / RP3N / GS3N / GD3N / SD3N / TC3N / TW3N /<br>TF3N / TA4 RCL-SA3L / SA6L / SM6L / RA3L |  |  |  |  |  |
| RACON-202-3  | RCA-SA4 /SS4 /SA5 /SS5 /RA4 -20/RG 4 -20/A4R/A5R<br>RCACR-SA4C/SA5 RCAW-RA4 -20 RCA2-SA4 /SA5 /TA6       |  |  |  |  |  |
| RACON-20S2-3 | RCA-RA3 / RG 3 RCAW-RA3 RCA2-SA4 / TA5   |  |  |  |  |  |
| RACON-302-3  | RCA-SA6 / SS6 / RA4 -30 / RG 4 -30 / A6R<br>RCACR-SA6 RCAW-RA4 -30 RCA2-SA6C / TA7C                      |  |  |  |  |  |

#### **Specifications**

|         | Item                         | Specifications                      | Specifications Item   |                            | Specifications                                      |
|---------|------------------------------|-------------------------------------|-----------------------|----------------------------|---|
|         | Power Supply                 | DC24V ±10%                          | ts                    | Ambient op.<br>temperature | 0~50°C  |
| S       | Power Supply Capacity        | 5.1A max. (depends on the actuator) | ironment<br>uirements | Ambient op. humidity       | 95% RH or below (non-condensing)                    |
| ations  | Operable Actuators           | RCA series                          | inviro<br>equire      | Ambient op. environment    | No corrosive or flammable gases, oil mist, or dust. |
| li≌     | Positioning Points           | 768 points                          | ъã                    | Protection class           | IP20  |
| Speci   | Backup memory                | EEPROM                              | Weight                |                            | 200g  |
|         | Position Detection Method    | Incremental encoder                 | Ac                    | cessories                  | ROBONET connection board (model JB-1),              |
| General | Solenoid brake force-release | Brake release switch                |                       |                            | Power connection board (model PP-1)                 |
| 9       | Motor Cable                  | otor Cable Model: CB-ACS-MA         |                       |                            |   |
|         | Encoder Cable                | Model: CB-ACS-PA                    |                       |                            |   |

## **RPCON** unit

## Controller for RCP3/RCP2 series



Controller unit that is used for RCP3/RCP2 actuator operation with ROBONET.

Model **RPCON-1-2-3** 

- $^{\star}$  In Model  $\textcircled{\scriptsize 1}$  , input a motor type. (See the following table.)
  - ②input "ABU" only when a simple absolute unit is used. (Otherwise, leave it blank.)
  - ③should have the code "H" when an RCP3-SA4, SA5, SA6, or an RCP2(RCP2CR)-SA5 or SA6 is to be connected.

| Model         | Compatible actuators  |  |  |  |
|---------------|---|--|--|--|
| RPCON-20P-@   | RCP2-RA2C / GRSS / GRLS / GRS<br>RCP3-SA2A / SA2B / RA2A / RA2B   |  |  |  |
| RPCON-28P-2   | RCP2-GRM / GR3LS / GR3SS / RTB / RTC / RTBL / RTCL RCP3-SA3C  |  |  |  |
| RPCON-28SP-2  | RCP2-RA3C / RGD3C   |  |  |  |
| RPCON-35P-2-3 | RCP3-SA4 / TA5  |  |  |  |
| RPCON-42P-@3  | RCP2-SA5 / SA6 / SS7 / BA6 / BA7 / RA4C /<br>RG 4C / GR3LM / GR3SM RCP3-SA5 / SA6 / TA6 / TA7<br>RCP2CR-SA5C / SA6C / SS7C RCP2W-RA4C |  |  |  |
| RPCON-56P-2   | RCP2-SA7 / SS8 / RA6C / RG 6C /<br>RCP2CR-SA7C / SS8C RCP2W-RA6C  |  |  |  |

## Specifications

|                | Item  | Specifications      | ecifications Item           |                            | Specifications                                      |
|----------------|---|---------------------|-----------------------------|----------------------------|---|
|                | Power Supply                                      | DC24V ±10%          | t ti                        | Ambient op.<br>temperature | 0~50°C  |
|                | Power Supply Capacity                             | 2A max.             | me                          | Ambient op. humidity       | 95% RH or below (non-condensing)                    |
| Specifications | Operable Actuators                                | RCP2 series         | Environment<br>Requirements | Ambient op. environment    | No corrosive or flammable gases, oil mist, or dust. |
| ifica          | Positioning Points                                | 768 points          | <u>ڇ</u> س                  | Protection class           | IP20  |
| bec            | Backup memory                                     | EEPROM              | Weight                      |                            | 200g  |
|                | Position Detection Method                         | Incremental encoder | Accessories                 |                            | ROBONET connection board (model JB-1),              |
| General        | Solenoid brake force-release Brake release switch |                     |                             |                            | Power connection board (model PP-1)                 |
|                | Motor Cable                                       | Model: CB-RCP2-MA   |                             |                            |   |
|                | Encoder Cable Model: CB-RCP2-PB                   |                     |                             |                            |   |

IAI

ROBONET **510** 



## Configuration unit (Simple absolute R unit/Extension unit)

## Simple absolute R unit



A data backup battery unit that can be attached to an RACON or RPCON controller to use an incremental actuator as an absolute type.

\*1 One unit of the simple absolute R unit is required per RACON/RPCON unit.

#### Model RABU (for RACON and RPCON)

\* When preparing a simple absolute R unit together with a controller unit (RACON/RPCON), write down "-ABU" to the end of the controller model, of which the simple absolute unit is installed.

Specifications

| s |              | Item Specifications                        |  |            | Item | Specifications |                  |  |   |
|---|--------------|--|--|------------|------|----------------|------------------|--|---|
| : |              | Power Supply                               | DC24V ±1                                   | 0%         |      |                |                  | Ambient op.<br>temperature                   | 0~40°C  |
|   | us           | Current consumption                        | 300mA m                                    | 300mA max. |      |                | eme              | Ambient op. humidity                         | 95% RH or below (non-condensing)  |
|   | atio         | Battery used                               | Ni-MH battery, nickel-hydrogen cell batter |            |      | cell battery   | nviro            | Ambient op. humidity Ambient op. environment | No corrosive or flammable gases, oil mist, or dust.                                     |
|   | Specificatio | Charging time                              | Approx. 78 hours                           |            |      | шё             | Protection class | IP20   |   |
|   |              | Battery life                               | 3 yrs                                      |            |      |                | W                | eight  | 330g  |
|   | General      | Maximum rpm for absolute data retention    | 800  | 400        | 200  | 100            | Ac               | cessories                                    | ROBONET connection board (model JB-1)   |
|   |              | Absolute Data<br>Retention<br>Duration (h) | 120  | 240        | 360  | 480            | Accessories      |  | simple absolute connection board<br>(model JB-1)<br>power connection board (model PP-1) |

## **Extension Unit**



When too many ROBONET units are connected horizontally to fit into the controller board, use this unit to split them in the middle with a cable to create another row.

In addition, by attaching the extension unit to the end of the linked ROBONET units and using an external controller cable, you can operate a standalone controller SCON like any other ROBONET controller, over the network.

## Model REXT (for RPCON and RACON)

Specifications

|  | Item                        |                         | Specifications  |  |
|--|-----------------------------|-------------------------|---|--|
|  | General<br>Specifications   | Power Supply            | DC24V ±10%  |  |
|  | Ger<br>Specifi              | Current consumption     | 100mA max.  |  |
|  | Environment<br>Requirements | Ambient op. temperature | 0~40°C  |  |
|  |                             | Ambient op. humidity    | 95% RH or below (non-condensing)  |  |
|  |                             | Ambient op. environment | No corrosive or flammable gases, oil mist, or dust.                           |  |
|  |                             | Protection class        | IP20  |  |
|  | Wei                         | ght                     | 140g  |  |
|  | Accessories                 |                         | ROBONET connection board (model JB-1),<br>Power connection board (model PP-1) |  |

(Note) The cable used is different depending on whether you are creating a new row of linked units, or connecting a standalone controller.
For more information, see the ROBONET extension unit on P505.








## External dimensional drawing

External dimensions of Gateway R unit, RACON unit, RPCON unit, Simple Absolute R unit, and Extension unit are same.



#### Option


### **Teaching Pendant**

A teaching device with functions for Features inputting positions, performing test runs, and monitoring.

CON-PT-M (Touch panel teaching pendant) Model

CON-T (Standard type)

RCM-E (Simple teaching pendant) ■ Configuration



CON-T Options Wall-mounting hook Model HK-1

PC Software (CD)

Strap



# CON-PT-M CON-T RCM-E 48.5 **Specifications**

CON-T

0

RCM-E

0

| Item                 | CON-PT-M |
|----------------------|----------|
| Data Input           | 0        |
| Actuator motion      | 0        |
| Ameleiand On anatina |          |


| Actuator motion                     | 0   | 0                                 | 0                                 |  |  |  |
|-------------------------------------|---|-----------------------------------|-----------------------------------|--|--|--|
| Ambient Operating<br>Temp./Humidity | Temp: 0~40°C; Humidity: 85% RH or below   |                                   |                                   |  |  |  |
| Ambient Operating<br>Atmosphere     | No corrosive gases. Especially no dust.   |                                   |                                   |  |  |  |
| Protection class                    | IP40                                      | IP54                              | -                                 |  |  |  |
| Weight                              | Approx. 750g                              | Approx. 400g                      | Approx. 400g                      |  |  |  |
| Cable Length                        |   | 5m                                |                                   |  |  |  |
| Display                             | 3-color LED touch<br>panel with backlight | 20 char. × 4 lines<br>LCD display | 16 char. × 2 lines<br>LCD display |  |  |  |
| Standard Price                      | -   | -                                 | -                                 |  |  |  |

## **PC Software (Windows Only)**

A startup support software for inputting positions, performing test runs, and monitoring. ■ Features With enhancements for adjustment functions, the startup time is shortened.

RCM-101-MW (with external device communications cable + RS232 conversion unit) Model

Note:



Note: Only version 6.00.04.00 or later can be used with ROBONET. ■ Configuration USB adapter RCB-CV-USB 3m 5m

External device

communications cable

CB-RCA-SIO050 IAI

USB cable

CB-SEL-USB030







## Option

## **DC24V Power Supply**

#### Features

A 24V power supply for ROBO Cylinder that can output 17A of momentary current. Power supply units can be operated in parallel, and up to 5 units can be added if a unit runs out of capacity.

Model

ontrollers ntegrated Rod Type Mini Standard

PMEC /AMEC
PSEP /ASEP
ROBO NET
ERC2
PCON
ACON
SCON
PSEL
ASEL

**PS-241** 

(100V input model)

PS-242

(200V input model)

#### Actuator vs. Power Supply Current

|                 |                         |                             |     | No. of connectible units for each unit of PS-24 |  |  |
|-----------------|-------------------------|-----------------------------|-----|---|--|--|
| Controller type | Actuator type           | Power Supply<br>Current [A] |     | Simultaneous<br>servo ON for all axes*          | No simultaneous servo ON for all axes* |  |
| RPCON<br>PCON   | RCP2, all models (note) | Rated<br>(= Maximum) 2      |     | 8   | 8                                      |  |
|                 | SA4, SA5 (20W)          | Rated                       | 1.3 | 3   | 6                                      |  |
|                 | , (,                    | Maximum                     | 4.4 | 1 3   | 0                                      |  |
|                 | SA6 (30W)               | Rated                       | 1.3 | - 4 6   |  |  |
|                 | ,                       | Maximum                     | 4   |   | 0                                      |  |
| RACON           | RA3 (20W)               | Rated                       | 1.7 | 3   | 5                                      |  |
| ACON            | ,                       | Maximum                     | 5.1 | 3   | 5                                      |  |
|                 | RA4 (20W)               | Rated                       | 1.3 | 3 3   | 6                                      |  |
|                 | ,,                      | Maximum                     | 4.4 | 3   | U                                      |  |
|                 | RA4 (30W)               | Rated                       | 1.3 | 4   | 6                                      |  |
|                 | ,                       | Maximum                     | 4   | -   | U                                      |  |



#### Spare parts

When spare parts are necessary after purchasing the product, such as when replacing a cable, refer to a list of the models below.



ROBONET connection board (simple absolute connection board) Model JB-1



Terminal resistor board Model TN-1



Power connection board Model PP-1

## Motor cable for RCP2


The standard cable for the motor cable is the robot cable. Selection is available CB-RCP2-MA \* Enter the cable length (L) into

Min. bend radius r = 50 mm or larger (when movable type is used) (20) (20) (14) CN3 CN1 CN3 Mechanical side


## Encoder Cable/Encoder Robot Cable for RCP2

\*The standard encoder cable is the normal cable. The robot cable is selectable as an option.

\* Enter the cable length (L) into \( \sum \subseteq \subseteq \). Compatible to maximum of 20 meters. Ex.: 080 = 8m Model CB-RCP2-PB /CB-RCP2-PB -RB





Min. bend radius r = 50 mm or larger (when movable type is used)



## Motor-encoder integrated type cable for RCP3/RCP2 (Limited to RCP2-GRSS/GRLS/GRST/SRA4R/SRGS4R/SRGD4R types)

Enter the cable length (L) into  $\Box\Box\Box$  . Compatible to a maximum of 20 meters. Ex.: 080 = 8 m Model CB-PCS-MPA






513

<sup>\*</sup> Refers to the first servo ON after power-up. (Note) Excluding HS8C, HS8R, and RA10C \* For PSEL/ASEL, this is different depending Please inquire for details.


<sup>\*</sup> Only the robot cable is to be used in a cable track.

## ROBONET Controller Spare parts Motor Cable for RCA \* Enter the cable length (L) into $\Box\Box\Box$ . Compatible to a maximum of 20 meter Model CB-ACS-MA No. Signal Color Wire 1 U Red 2 V White Current Glack (crimped) | Wire | Color | Signal No AWG22 | Red | U | 1 (crimped) | White | V | 2 ¹**₽** □ Controller side Min. bend radius r = 50 mm or larger (when movable type is used) Encoder Cable/Encoder Robot Cable for RCA \*The standard encoder cable is the normal cable. The robot cable is selectable as an option. \* Enter the cable length (L) into \( \subseteq \subseteq \). Compatible to maximum of 20 meters. Ex.: 080 = 8m Model CB-ACS-PA /CB-ACS-PA -RB 0 () Min. bend radius r = 50 mm or larger (when movable type is used) Only the robot cable is to be used in a cable track. Housing: PHDR-18VR (JST) Contact : SPHD-001T-P0.5 (JST) Motor-Encoder Integrated Cable for RCA2 \* Enter the cable length (L) into . Compatible to a maximum of 20 meters. Model CB-ACS-MPA (012) <u>eII</u> (23) Min. bend radius r = 84 mm or larger (when movable type is used) Controller side Mechanical side Unit Link Cable for Extension Unit Model CB-REXT-SIO010 ¬xx 7XX **X** ¬xx



## Controller Connection Cable for Extension Unit

## Model CB-REXT-CTL010








## List of Models

Mini
Standard
Controllers
Integrated
Roc
Type
Mini
Standard
Controllers
Integrated
Table/Arr
//FlatTyp
Mini
Standard

Splash-Proof
Controllers
PMEC
//AMEC
PSEP
//ASEP
ROBO
NET
ERC2
PCON
ACON
SCON
SCON
SSEL
ASEL


| I/O type        | NP  | PN  | SE   |  |
|-----------------|---|---|--|--|
| Name            | PIO type (NPN Specification)  | PIO type (PNP Specification)  | Serial Communication Type  |  |
| External View   |   |   |  |  |
| Description     | Controller that moves by designating position numbers with NPN PIO via PLC. | Controller that moves by designating position numbers with PNP PIO via PLC. | Controller that is used by connecting to the field network via the gateway unit. |  |
| Position points | 16 points 16 points   |   | 64 points  |  |

## Model



515 ERC2





516









































## I/O specification (PIO type)

#### Input section External input specifications


| Item                                   | Specifications             |  |
|--|----------------------------|--|
| Input points                           | 6 points                   |  |
| Input voltage DC24V +/-10%             |                            |  |
| Input current 4mA/circuit              |                            |  |
| Leak current Max. 1mA/point            |                            |  |
| Operating ON voltage: Min. 18V (3.5mA) |                            |  |
| voltage                                | OFF voltage: Max. 6V (1mA) |  |






## ■ Output section External output specifications

| Item                                       | Specifications            |  |  |
|--|---------------------------|--|--|
| Input points                               | 4 points                  |  |  |
| Nominal load voltage                       | DC24V                     |  |  |
| Max. current                               | 60mA/point                |  |  |
| Remaining voltage                          | 2V or less                |  |  |
| Short-circuit, reverse voltage, protection | Fuse resistance (27Ω0.1W) |  |  |





## Table of I/O signals (PIO type)

| Parameter<br>(PIO pattern select)                                       | PIO pattern                                  | Pin No.  |
|---|--|--|
| 0 8-point type  |  | A standard specification providing eight positioning points, plus a home return signal, zone signal, etc. (The parameter has been set to this pattern prior to the shipment.)                        |
| 1 3-point type (Solenoid valve type) 2 16-point type (Zone signal type) |  | Simply turn ON three signals of ST0 to ST2 to move the actuator to the corresponding positions (0 to 2), just like you do with solenoid valves (This allows for easy conversion from air cylinders). |
|   |  | Can be positioned for up to 16 points. (Same as the 8-point type, except that this pattern provides no home return signal.)  |
| 3   | 16-point type<br>(Position zone signal type) | A 16-point pattern with a position zone signal instead of a zone signal.   |

|           |                |                      | Parameters (select PIO pattern) |                                       |                                     |  |
|-----------|----------------|----------------------|---------------------------------|---------------------------------------|-------------------------------------|--|
| Pin No.   | Classification | Wire color           | 0                               | 1                                     | 2                                   | 3  |
| r in rec. | Ciacomoation   | Wile color           | Conventional type               | 3-point type<br>(Solenoid valve type) | 16-point type<br>(Zone signal type) | 16-point type<br>(Position zone signal type) |
| 1A        | SIO            | Orange (Red 1)       |                                 | SC                                    | BA .                                |  |
| 1B        | 310            | Orange (Black 1)     |                                 | SG                                    | àВ                                  |  |
| 2A        | Signal         | Light Blue (Red 1)   |                                 | EM                                    | S1                                  |  |
| 2B        | Signal         | Light Blue (Black 1) |                                 | EM                                    | S2                                  |  |
| 3A        | 24V            | White (Red 1)        |                                 | 24                                    | ١V                                  |  |
| 3B        | 0V             | White (Black 1)      |                                 | Bl                                    | _K                                  |  |
| 4A        | 24V            | Yellow (Red 1)       |                                 | M                                     | PI                                  |  |
| 4B        | 0V             | Yellow (Black 1)     | GND                             |                                       |                                     |  |
| 5A        | 24V            | Pink (Red 1)         |                                 | M                                     | PI                                  |  |
| 5B        | 0V             | Pink (Black 1)       | GND                             |                                       |                                     |  |
| 6A        |                | Orange (Red 2)       | PC1                             | ST0                                   | PC1                                 | PC1  |
| 6B        |                | Orange (Black 2)     | PC2                             | ST1                                   | PC2                                 | PC2  |
| 7A        | Input          | Light Blue (Red 2)   | PC4                             | ST2                                   | PC4                                 | PC4  |
| 7B        | lliput         | Light Blue (Black 2) | HOME                            | _                                     | PC8                                 | PC8  |
| 8A        |                | White (Red 2)        | CSTR                            | RES                                   | CSTR                                | CSTR   |
| 8B        |                | White (Black 2)      | * STP                           | * STP                                 | * STP                               | * STP  |
| 9A        |                | Yellow (Red 2)       | PEND                            | PE0                                   | PEND                                | PEND   |
| 9B        | Output         | Yellow (Black 2)     | HEND                            | PE1                                   | HEND                                | HEND   |
| 10A       | Output         | Pink (Red 2)         | ZONE                            | PE2                                   | ZONE                                | PZONE  |
| 10B       |                | Pink (Black 2)       |                                 | * <b>A</b>                            | LM                                  | <u> </u>                                     |

Signals marked with an asterisk (\*) (ALM/STP) are negative logic signals so they are normally on.



## Signal names

| Classification | Signal Name                       | Signal abbreviations     | Function overview   |
|----------------|-----------------------------------|--------------------------|---|
| SIO            | Serial Communication SGA SGB      |                          | Used for serial communication.  |
| 24V<br>0V      | Emergency stop                    | EMS1<br>EMS2             | These signals are wired to enable the emergency stop switch on the teaching pendant (see P521).   |
| 00             | Brake release                     | BKR                      | By connecting to 0V (150mA needed) the brake is forcibly released.  |
|                | Command position No.              | PC1<br>PC2<br>PC4<br>PC8 | Designates the position number using 4-bit binary signals (or 3-bit binary signals if the 8-point PIO pattern is selected).  (Example) Position 3 → Input PC1 and PC2  Position 7 → Input PC1 and PC2 and PC4 |
| Input          | Position movement ST1 ST2         |                          | Turn the ST0 signal on to move the actuator to position 0. Same for ST1 and ST2 (Operation can be started with these signals alone. No need to input a start signal).   |
|                | Home return                       | HOME                     | Home-return operation starts at the leading edge of this signal.  |
|                | Start                             | CSTR                     | Input a command position number signal and turn this signal ON, and the actuator will start moving to the specified position.   |
|                | Reset                             | RES                      | Turning this signal ON resets the alarms that are present. When it is paused ("STP is off), it is possible to cancel the residual movement.   |
|                | Pause                             | * STP                    | Normal operation is allowed while this signal is ON (negative logic)  The actuator starts to decelerate to a stop at the ON → OFF leading edge of this signal.  |
|                | Positioning complete PEND         |                          | This signal turns ON once the actuator has moved to the target position and completed the positioning by entering the specified positioning band. Used to determine if positioning has completed.             |
| Output         | PE0 Complete position No. PE1 PE2 |                          | PE0 is output upon completion of movement to position 0. Same for PE1 and PE2. (These signals are valid only when the 3-point PIO pattern is selected.)   |
| Output         | Home return complete              | HEND                     | This signal turns ON upon completion of home return.  |
|                | Zone                              | ZONE                     | This signal turns ON upon entry into the zone signal range set by parameters.   |
|                | Position zone                     | PZONE                    | This signal turns ON upon entry into the zone signal range set in the position table.   |
|                | Alarm * ALM                       |                          | The signal remains ON in normal conditions and turns OFF upon generation of the alarm (negative logic). Synchronized with the LED at the top of the motor cover (green: normal state, red: alarm on).         |

Signals marked with an asterisk (\*) (ALM/STP) are negative logic signals, so they are normally on.

## Specification Table

|                      |                                      | _   |   |  |
|----------------------|--------------------------------------|---|---|--|
| Specification        |                                      | De  | tails   |  |
|                      | Туре                                 | PIO specification (NP / PN) SIO specification (SE)    |   |  |
|                      | Control method                       | Low field vector control (patent pending)             |   |  |
|                      | Positioning command                  | Position No. designation                              | Position No. designation / Direct value designation |  |
|                      | Position No.                         | Max. 16 points  | Max. 64 points                                      |  |
|                      | Dealum maman                         | Position number data and parameters are stored in     | n nonvolatile memory.                               |  |
|                      | Backup memory                        | Serial EEPROM with a rewrite life of 100,000 time     | s   |  |
|                      | PIO                                  | 6 dedicated input points/4 dedicated output points    | None  |  |
|                      | Electromagnetic brake                | Built-in circuit DC24V±10% 0.15A max.                 |   |  |
|                      | 2-color LED display                  | Servo ON (green), Alarm/motor drive power supply      | shut-down (red)                                     |  |
|                      | I/O power (Note 1)                   | Common to control power (non-isolated)                |   |  |
|                      | Serial Communication                 | RS485 1ch (External termination)                      |   |  |
|                      | Absolute function                    | None  |   |  |
| For                  | ced release of electromagnetic brake | Forced release when connected to 0V (NP), or 24V (PN) | Forced release when connected to 24V                |  |
|                      | Cabla Lawath                         | I/O cable: 10m max.                                   |   |  |
|                      | Cable Length                         | SIO connector communication cable: 5m or shorter      |   |  |
|                      | Dielectric strength voltage          | DC500V 10MΩ   |   |  |
|                      | EMC                                  | EN55011 Class A Group1 (3m)                           |   |  |
| Power supply voltage |                                      | DC24V ± 10%   |   |  |
|                      | Power supply current                 | 2A max.   |   |  |
| Jent                 | Ambient operating temperature        | 0 ∼ 40°C  |   |  |
| Environment          | Ambient operating humidity           | 85% RH or lower (non-condensing)                      |   |  |
| Ē                    | Ambient operating atmosphere         | Free from corrosive gases                             |   |  |
|                      | Protection class                     | IP20  |   |  |

Use the isolated PIO terminal block (option P522) to isolate the I/O power supply.

Slider Type

Mini

Standard

Controller: Integrated

Rod Type

Mini

Standard

Controllers

Table/Arm

/FlatType

Mini

Standard

Linear Servo

Cleanroom Type

Splash-Proof

Controllers

PMEC /AMEC

/ASEP

EDC2

PCON

ACON

.

SSFI

XSEL

Pulse Moto

Servo Moto (24V)

Servo Moto (200V)

Linear Servo Moto





## I/O wiring drawing















































## PIO Type NP (NPN Specification)




## PIO Type PN (PNP Specification)




519 ERC2



## SIO Type SE





Mini
Standard
Controllers
Integrated
Rod
Type
Mini
Standard
Controllers
Integrated
Table/Arm
VFlatType
Mini
Standard
Gripper/
Rotary Type Splash-Proof

Controllers

PMEC
/AMEC

PSEP
/ASEP

ROBO
NET

ERC2

PCON

ACON

SCON

PSEL

ASEL

SSEL







The ERC2 series has no built-in emergency stop circuit, so the customer must provide an emergency stop circuit based on the logic explained below.

(The circuit below is simplified for explanation purposes. Provide a ready circuit, etc., according to your specification.)

Single Axis: To provide an emergency stop circuit for a single-axis configuration, operate a relay using the EMS1 and EMS2 contacts of the power & I/O cable to cut off MPI (motor power).



To provide an emergency stop circuit for a multiple-axes configuration, operate a relay using the EMG1 and EMG2 Multiple Axis: contacts of the SIO converter to cut off MPI (motor power) for each axis.



**521** 



Mini
Standard
Controllers
Integrated

Rood
Type

Mini
Standard

Table/Arr
/FlatTyp

Mini
Standard

Controllers
PMEC /AMEC
PSEP //ASEP
ROBO NET /
ERC2
PCON ACON
ACON
SCON
ASEL
ASEL
XSEL

Controllers Integrated God Kype

Mini

Standard

Controllers Integrated God FlatType

Mini

## Isolated PIO Terminal Block

This terminal block is used to isolate the I/O power or simplify the wiring with a PLC.


\*When a terminal block is used, the optional power & I/O cable with connectors on both ends must be used.


Features - The input and output ports are non-polar, so both NPN and PNP are compatible with the I/O specifications on the PLC side.

- An input/output-signal monitor LED is equipped to check the ON/OFF status of signals.

Specification

| s | Item   |   | Specifications                                 |
|---|--|---|--|
|   | Power supply voltage   |   | DC24V±10%                                      |
| ĺ | Ambient Oper   | ating Temp./Humidity                    | 0 to 55°C, 85% RH or below<br>(non-condensing) |
|   |  | Input points                            | 6 points                                       |
|   |  | Input voltage                           | DC24V±10%                                      |
|   | Input Input current area Allowable leaked current Operating voltage (with respect to ground) |   | 7mA/circuit (bipolar)                          |
|   |  |   | 1mA/point (at room temperature, about 2mA)     |
|   |  |   | Input ON: Min. 16V (4.5mA)                     |
|   |  |   | OFF: Max. 5V (1.3 mA)                          |
|   |  | Output points                           | 4 points                                       |
|   |  | Rated load voltage                      | DC24V  |
|   | Output Max. current area Residual voltage  |   | 60mA/point                                     |
|   |  |   | 2V or less/60mA                                |
|   |  | Short circuit<br>Overcurrent protection | Fuse resistance (27Ω0.1W)                      |





### SIO Converter


This converter can be used for RS232 communication by connecting a serial communication wire (SGA, SGB) for the power-I/O cable, and using a D-sub 9-pin cross cable to connect a computer.


Features - The connection port for teaching-pendant or a PC cable can be installed at any position away from the actuator.

- Multiple axes can be connected and operated from a PC via serial communication.

## Specifications

| Item                     | Specifications   |
|--------------------------|--|
| Power supply voltage     | DC24V±10%  |
| Ambient Operating Temp./ | 0 to 55°C, 85% RH or below                             |
| Humidity                 | (non-condensing)                                       |
| Terminal resistor        | 120Ω (built-in)  |
|                          | Power supply voltage Ambient Operating Temp./ Humidity |







Controllers

PMEC
//AMEC

PSEP
//ASEP

ROBO
NET

ERC2

PCON


AGON

SCON

PSEL

ASEL






Servo Motor (24V)

> Linear Servo Motor

> > **523** EDC:





**524** 




### List of models

These are the position controllers that can be used with the RCP3/RCP2 Series actuators. Our line-up has 6 types, which are compatible with various control systems.

| I | Type            | С   | CG  | CF   | CY  | PL/PO                    | SE                        |
|---|-----------------|---|---|--|---|--------------------------|---------------------------|
|   | Name            | Positioner type   | Conforming to safety category compatible type       | High-thrust motor compatible type  | Solenoid valve type   | Pulse train control type | Serial communication type |
|   | External View   |   |   |  |   |                          |                           |
|   | Description     | Positioner capable of<br>a maximum of 512 points<br>Positioning | Conforming to type C safety category specifications | Dedicated controller for RCP2<br>high-speed type/high-thrust<br>type / waterproof type | Can be operated using the same control as the air cylinder type | For pulse train control  | For Serial communication  |
|   | Position points | 512 points  | 512 points  | 512 points   | 3 points  | -                        | 64 points                 |

(\*1) Network connection specifications are designated by the I/O type symbols for the model.

## Model



**525** PCON



Controller

PMEC /AMEC

PSEP /ASEP

ROBO NET

ERC2

PCON

ACON

SCON

PSEL

SSEL


Mini
Standard
Table/Ar
//FlatTyp
Mini
Standard
Sontrollers
Integrated

Pulse Moto

Servo Moto (24V

Servo Moto (200V

Linea Servo Motor



PCON **526** 













































## I/O Specifications

### ■ Input section External input specifications


| Item             | Specifications |
|------------------|----------------|
| Input voltage    | DC24V +/-10%   |
| Input current    | 4mA/circuit    |
| Leak current     | 1mA max./point |
| Isolation method | Photocoupler   |






### ■ Output section External output specifications

| Item              | Specifications |
|-------------------|----------------|
| Load Voltage      | DC24V          |
| Max. load current | 50mA/point     |
| Remaining voltage | 2V or less     |
| Isolation method  | Photocoupler   |





## I/O Specifications

The 4 types of controllers (C/CG, CY, PL/PO, and SE) are classified by their respective I/O specifications. In addition, with the positioner type and solenoid valve type, the I/O signal details can be changed via the controller settings. As a result, a number of functions can be used.

## ■ Control Function by Type

| Туре                | C/CG            | CY                  | PL/PO                      | SE                        | Features   |  |
|---------------------|-----------------|---------------------|----------------------------|---------------------------|--|--|
| Name                | Positioner type | Solenoid valve type | Pulse in-line control type | Serial communication type | reatures   |  |
| Positioner mode     | $\circ$         | ×                   | ×                          | (*1)                      | This is the basic operating mode, in which the user designates position numbers and inputs start signals.  |  |
| Teaching mode       | 0               | ×                   | ×                          | (*1)                      | In this mode, the slider (rod) moves based on an external signal, and the stopped positions can be registered as position data.  |  |
| Solenoid valve mode | 0               | 0                   | ×                          | (*1)                      | The actuator can be moved simply by ON/OFF of position signals. This mode supports the same control signals you are already familiar with on solenoid valves of air cylinders. |  |
| Pulse train mode    | ×               | ×                   | 0                          | ×                         | In this mode, you can operate the actuator freely using pulse trains without inputting position data.  |  |
| Network compatible  | (*2)            | ×                   | ×                          | (*3)                      | The controller can be connected to a DeviceNet or CC-Link network.   |  |

- \*1 Operates using network communications or serial communications.
- \*2 Can make a direct connection to a field network with the network specifications.
- \*3 Can be connected to a field network using a gateway unit.

527 PCON

## Explanation of I/O Signal Functions

The table below explains the functions allocated to the controller's I/O signal.

Since the signals that can be used vary depending on the controller type and settings, check the signal table for each controller to confirm the available functions.

## ■ Signal Function Description

| Classification | Signal abbreviations | Signal                                  | Function description  |  |  |
|----------------|----------------------|---|---|--|--|
|                | CSTR                 | PTP strobe signal (start signal)        | Input this signal to cause the actuator to start moving to the position set by the command position number signal.  |  |  |
|                | PC1 to PC256         | Command position number signal          | This signal is used to input a target position number (binary input).   |  |  |
|                | BKRL                 | Brake forced release signal             | This signal forcibly releases the brake.  |  |  |
|                | RMOD                 | Running mode switching signal           | This signal can switch the running mode when the MODE switch on the controller is set to AUTO. (AUTO when this signal is OFF, or MANU when the signal is ON)  |  |  |
|                | *STP                 | Pause signal                            | Turning this signal OFF causes the moving actuator to decelerate to a stop. The actuator will resume the remaining movement if the signal is turned ON during the pause.  |  |  |
|                | RES                  | Reset signal                            | Turning this signal ON resets the alarms that are present. If this signal is turned ON while the actuator is paused ("STP is OFF), the remaining movement can be cancelled.   |  |  |
|                | SON                  | Servo ON signal                         | The servo remains on while this signal is ON, or off while the signal is OFF.   |  |  |
|                | номе                 | Home return signal                      | Turning this signal ON performs home-return operation.  |  |  |
| Input          | MODE                 | Teaching mode signal                    | Turning this signal ON switches the controller to the teaching mode. (provided that CSTR, JOG+ and JOG- are all OFF and the actuator is not moving).  |  |  |
|                | JISL                 | JOG/INCHING switching signal            | When the main signal is off, the JOG operation will be conducted for JOG+ and JOG When the signal is on, the unit will do the inching operation for JOG+ and JOG  |  |  |
|                | JOG+, JOG-           | JOG signal                              | When the JISL signal is off and the JOG +/- signal turns on, the unit will jog in the + (positive) direction when the JOG + turns on and the - (negative) direction when the JOG - turns on. During the JOG operation, the unit slows to a stop when the JOG +/- signal turns off.  |  |  |
|                | PWRT                 | Teaching signal                         | In the teaching mode, specify a desired position number and then turn this signal ON for at least 20ms to write the current position to the specified position number.  |  |  |
|                | ST0 to ST6           | Start position command                  | Turning this signal ON in the solenoid valve mode causes the actuator to move to the specified position. (Start signal is not required)   |  |  |
|                | TL                   | Torque limit selection signal           | While this signal is ON, torque is limited by the value set by a parameter. The TLR signal turns on if torque has reached the specified value.  |  |  |
|                | DCLR                 | Deviation counter clear signal          | The position deviation counter is continuously cleared while this signal is ON.   |  |  |
|                | PEND/INP             | In position signal                      | This signal turns ON when the actuator has entered the positioning band after movement. If the actuator has exceeded the positioning band, PEND does not turn OFF, but INP does. PEND and INP can be swapped within parameters.   |  |  |
|                | PM1 to PM256         | Positioning complete signal             | This signal is used to output the position number achieved at the completion of positioning (binary output)   |  |  |
|                | HEND                 | Home return completion signal           | This signal turns ON upon completion of home return.  |  |  |
|                | ZONE1                | Zone signal                             | This signal turns ON when the current actuator position has entered the range specified by the parameters.  |  |  |
|                | PZONE                | Position zone signal                    | Turns ON when the actuator moves into a position within the range of the target position data that was set. PZONE can be used together with ZONE1, but PZONE is valid only during movement to a specified position.   |  |  |
|                | RMDS                 | Running mode status signal              | This outputs the operation mode status.   |  |  |
|                | *ALM                 | Controller alarm status signal          | This signal remains ON while the controller is not in the alarm condition, and turns OFF when an alarm has occurred.  |  |  |
|                | MOVE                 | Moving signal                           | Turns ON while the actuator is moving (home return), including when there is push force.  |  |  |
|                | sv                   | Servo ON status signal                  | This signal turns ON when servo is ON.  |  |  |
| Output         | *EMGS                | Emergency stop status signal            | This signal remains ON while the controller is not in the emergency stop mode, and turns OFF once an emergency stop has been actuated.  |  |  |
|                | MODES                | Mode status signal                      | The mode signal input turns it ON when it goes into teaching mode. It turns OFF when it goes into normal mode.  |  |  |
|                | WEND                 | Writing complete signal                 | This signal remains OFF after the controller has switched to the teaching mode. It turns ON upon completion of data write using the PWRT signal. If the PWRT signal is turned Off, this signal also turns OFF.  |  |  |
|                | PE0 to PE6           | Current position number signal          | This signal turns ON after the controller has completed moving to the target position in the solenoid valve mode.   |  |  |
|                | TLR                  | Torque limiting signal                  | This signal turns ON once the motor torque has reached the specified value in a condition where torque is being limited by the TL signal.   |  |  |
|                | LSO to LS2           | Limit switch output signal              | Each signal turns ON when the current actuator position has entered the positioning band before<br>or after the target position. If the actuator has already completed home return, these signals are<br>output even before a movement command is issued or while the servo is OFF. |  |  |
|                | LOAD                 | Load output determination status signal | This signal turns ON once the motor torque has reached the specified value. (*PCON-CF dedicated signal)   |  |  |
|                | TRQS                 | Torque level status signal              | Turns ON when the motor current reaches the threshold. ("PCON-CF dedicated signal)  |  |  |

(Note) Signals with asterisks (\*) are normally ON and OFF during operation.

Slider Type

Mini

Standard

Controllers

Rod Type

Mini

Standard

Controllers

/FlatType

Mini

Otandard

Linear Servo

Cleanroom Type

Splash-Proof

Controllers

PMEC /AMEC

ROBO

ERC2

ACON

=

SSEI

XSEL

Pulse Moto

ervo Moto

Servo Moto (200V)

Linear Servo Moto

PCON **528** 































## I/O Signal table

## ■ Positioner types (PCON-C / CG / CF)

|     |                |                    |                  |               | Parameters (sel | ect PIO pattern) |                       |                       |
|-----|----------------|--------------------|------------------|---------------|-----------------|------------------|-----------------------|-----------------------|
|     | <sub>E</sub>   |                    | 0                | 1             | 2               | 3                | 4                     | 5                     |
| Pin | atic           |                    | Positioning mode | Teaching mode | 256-point mode  | 512-point mode   | Solenoid Valve Mode 1 | Solenoid Valve Mode 2 |
| No. | Classification | Positioning Points | 64 points        | 64 points     | 256 points      | 512 points       | 7 points              | 3 points              |
|     | S S            | Zone signal        | 0                | ×             | ×               | ×                | 0                     |                       |
|     |                | P-zone signal      | 0                | 0             | 0               | ×                | 0                     | 0                     |
| 1A  | 24V            | , and the second   | _                | P24           |                 |                  |                       |                       |
| 2A  | 24V            |                    |                  |               | P               | 24               |                       |                       |
| 3A  | -              |                    |                  |               | N               | ic               |                       |                       |
| 4A  | -              |                    |                  |               | N               | IC               |                       |                       |
| 5A  |                | IN0                | PC1              | PC1           | PC1             | PC1              | ST0                   | ST0                   |
| 6A  | 1              | IN1                | PC2              | PC2           | PC2             | PC2              | ST1                   | ST1 (JOG+)            |
| 7A  |                | IN2                | PC4              | PC4           | PC4             | PC4              | ST2                   | ST2 (-)               |
| 8A  |                | IN3                | PC8              | PC8           | PC8             | PC8              | ST3                   | -                     |
| 9A  |                | IN4                | PC16             | PC16          | PC16            | PC16             | ST4                   | -                     |
| 10A |                | IN5                | PC32             | PC32          | PC32            | PC32             | ST5                   | _                     |
| 11A | 1              | IN6                | _                | MODE          | PC64            | PC64             | ST6                   | -                     |
| 12A | 1              | IN7                | _                | JISL          | PC128           | PC128            | _                     | -                     |
| 13A | Input          | IN8                | -                | JOG+          | -               | PC256            | _                     | _                     |
| 14A | 1              | IN9                | BKRL             | JOG-          | BKRL            | BKRL             | BKRL                  | BKRL                  |
| 15A |                | IN10               | RMOD             | RMOD          | RMOD            | RMOD             | RMOD                  | RMOD                  |
| 16A | 1              | IN11               | HOME             | HOME          | HOME            | HOME             | HOME                  | -                     |
| 17A |                | IN12               | *STP             | *STP          | *STP            | *STP             | *STP                  | _                     |
| 18A |                | IN13               | CSTR             | CSTR/PWRT     | CSTR            | CSTR             | -                     | -                     |
| 19A |                | IN14               | RES              | RES           | RES             | RES              | RES                   | RES                   |
| 20A |                | IN15               | SON              | SON           | SON             | SON              | SON                   | SON                   |
| 1B  |                | OUT0               | PM1              | PM1           | PM1             | PM1              | PE0                   | LSO                   |
| 2B  | 1              | OUT1               | PM2              | PM2           | PM2             | PM2              | PE1                   | LS1 (TRQS)            |
| 3B  | 1              | OUT2               | PM4              | PM4           | PM4             | PM4              | PE2                   | LS2 (-)               |
| 4B  | 1              | OUT3               | PM8              | PM8           | PM8             | PM8              | PE3                   | -                     |
| 5B  |                | OUT4               | PM16             | PM16          | PM16            | PM16             | PE4                   | -                     |
| 6B  | 1              | OUT5               | PM32             | PM32          | PM32            | PM32             | PE5                   | -                     |
| 7B  | 1              | OUT6               | MOVE             | MOVE          | PM64            | PM64             | PE6                   | -                     |
| 8B  | ]              | OUT7               | ZONE1            | MODES         | PM128           | PM128            | ZONE1                 | ZONE1                 |
| 9B  | Output         | OUT8               | PZONE            | PZONE         | PZONE           | PM256            | PZONE                 | PZONE                 |
| 10B |                | OUT9               | RMDS             | RMDS          | RMDS            | RMDS             | RMDS                  | RMDS                  |
| 11B | ]              | OUT10              | HEND             | HEND          | HEND            | HEND             | HEND                  | HEND                  |
| 12B | 1              | OUT11              | PEND             | PEND/WEND     | PEND            | PEND             | PEND                  | -                     |
| 13B |                | OUT12              | SV               | sv            | SV              | sv               | sv                    | sv                    |
| 14B |                | OUT13              | * EMGS           | * EMGS        | * EMGS          | * EMGS           | * EMGS                | * EMGS                |
| 15B |                | OUT14              | * ALM            | * ALM         | * ALM           | *ALM             | * ALM                 | * ALM                 |
| 16B |                | OUT15              | LOAD/TRQS        | -             | LOAD/TRQS       | LOAD/TRQS        | LOAD/TRQS             | -                     |
| 17B | _              |                    |                  |               | N               | ic               |                       |                       |
| 18B | _              |                    |                  |               | N               | IC               |                       |                       |
| 19B | ov             |                    |                  |               | 1               | N                |                       |                       |
| 20B | 0V             |                    | N                |               |                 |                  |                       |                       |

(Note) The names of signals above inside () are functions before the unit returns home. (Note) Signals with asterisks (\*) are normally ON, and OFF during operation.

## ■ Solenoid valve type (PCON-CY)

|     |                |                    | Parameters (sel       | ect PIO pattern)      |
|-----|----------------|--------------------|-----------------------|-----------------------|
|     | 5              |                    | 0                     | 1                     |
| Pin | Classification |                    | Solenoid valve mode 0 | Solenoid valve mode 1 |
| No. | issifi         | Positioning Points | 3 points              | 3 points              |
|     | ဗိ             | Zone signal        | ×                     | ×                     |
|     |                | P-zone signal      | ×                     | 0                     |
| 1   | 24V            |                    |                       |                       |
| 2   | 0V             |                    |                       |                       |
| 3   |                | IN0                | ST0                   | ST0                   |
| 4   | Input          | IN1                | ST1 (JOG+)            | ST1 (JOG+)            |
| 5   |                | IN2                | ST2 (RES)             | ST2 (RES)             |
| 6   |                | IN3                | SON                   | SON                   |
| 7   |                | OUT0               | LS0                   | PE0                   |
| 8   |                | OUT1               | LS1 (TRQS)            | PE1 (TRQS)            |
| 9   | Output         | OUT2               | LS2 (-)               | PE2 (-)               |
| 10  |                | OUT3               | sv                    | PZONE                 |
| 11  |                | OUT4               | HEND                  | HEND                  |
| 12  |                | OUT5               | * ALM                 | * ALM                 |

(Note) The names of signals above inside () are functions before the unit returns home. (Note) Signals with asterisks (\*) are normally ON, and OFF during operation.

## ■ Pulse Train Type (PCON-PL/PO)

|     |                |                    | Parameters (sel | ect PIO pattern) |
|-----|----------------|--------------------|-----------------|------------------|
|     | 5              |                    | 0               | 1                |
| Pin | catic          |                    | Standard mode   | Push mode        |
| No. | Classification | Positioning Points | -               | -                |
|     | ဗြ             | Zone signal        | ×               | ×                |
|     |                | P-zone signal      | ×               | ×                |
| 1   | 24V            |                    |                 |                  |
| 2   | 0V             |                    |                 |                  |
| 3   |                | IN0                | SON             | SON              |
| 4   | lanut          | IN1                | TL              | TL               |
| 5   | Input          | IN2                | HOME            | HOME             |
| 6   |                | IN3                | RES             | RES / DCLR       |
| 7   |                | OUT0               | SV              | SV               |
| 8   | Output         | OUT1               | INP             | INP / TLR        |
| 9   | Output         | OUT2               | HEND            | HEND             |
| 10  |                | OUT3               | * ALM           | * ALM            |
| 11  |                |                    | * PP            | * PP             |
| 12  |                |                    | PP              | PP               |
| 13  | Input          |                    | * NP            | * NP             |
| 14  |                |                    | NP              | NP               |


(Note) Signals with asterisks (\*) are normally ON, and OFF during operation.



## Pulse train input type wiring diagram

## ■ Differential Receiver Method (PCON-PL)

Max. input pulse frequency : Max. 200 kpps Cable Length : Max. 10m



## ■ Open Collector Method (PCON-PO)

Max. input pulse frequency : Max. 60 kpps Cable Length : Max. 2m

| Pin Number     | Classification         | Signal                 | / //   |
|----------------|------------------------|------------------------|--|
| 1              | External 24V           | 24V                    | <u> </u>   |
| 2              | External 0V            | 0V                     |  |
| 3              | Input                  | SON                    |  |
| 4              | Input                  | TL                     |  |
| 5              | Input                  | HOME                   |  |
| 6              | Input                  | RES                    |  |
| 7              | Output                 | SV                     |  |
| 8              | Output                 | INP                    |  |
| 9              | Output                 | HEND                   |  |
| 10             | Output                 | * ALM                  |  |
| 11             | Open collector input   | /PP                    |  |
| 12             | N.C                    | PP                     |  |
| 13             | Open collector input   | /NP                    |  |
| 14             | N.C                    | NP                     |  |
|                |                        |                        |  |
| Mounting p     | late                   | FG                     |  |
| * The shield o | the twisted pair cable | connected to the nulse | connector must be connected to the mounting plate. |

Mini
Standard
Controllers integrated
Mini
Standard
Controllers integrated
Table/Arm
(FlatType
Mini

Splash-Proof
Controllers

PMEC
(AMEC)
PSEP
(ASEP
ROBO
NET
ERC2
PCON
ACON
SCON
PSEL
ASEL



## Command Pulse Input State

|                | Command pulse train state    | Input terminal                   | During forward operation                      | During reversed operation                  |
|----------------|------------------------------|----------------------------------|---|--|
|                | Forward pulse train          | PP•/PP                           |   |  |
|                | Reversed pulse train         | NP•/NP                           |   |  |
|                | The forward pulse            | train causes the motor to rotat  | e forward, and the reverse pulse train causes | the motor to rotate in reverse.            |
| logic          | Pulse train                  | PP•/PP                           |   | +  |
| Negative logic | Symbols                      | NP•/NP                           | Low   | High                                       |
| Z              | The command p                | ulse is used for the amount of   | motor rotation, and the command symbol is u   | sed for rotational direction.              |
|                | A/B phase pulse train        | PP•/PP                           |   |  |
|                |                              | NP•/NP                           |   |  |
|                | An A/B phase pulse with a 90 | ° phase difference (multiplier i | s 4) is used to generate commands for the am  | ount of rotation and rotational direction. |
|                | Forward pulse train          | PP•/PP                           |   |  |
|                | Reversed pulse train         | NP•/NP                           |   |  |
| Positive logic | Pulse train                  | PP•/PP                           |   |  |
| Positiv        | Symbols                      | NP•/NP                           | High  | Low  |
|                | A/R phase pulse treits       | PP•/PP                           |   |  |
|                | A/B phase pulse train        | NP•/NP                           |   |  |

| lab | le of s | pecific | cations |
|-----|---------|---------|---------|

| Item  |   |  |         | Specifications           |                            |                         |                           |
|---|---|--|---------|--------------------------|----------------------------|-------------------------|---------------------------|
| Controller type                             | CF  | С  | CG      | CY                       | PL                         | PO                      | SE                        |
| Connected actuator (*1)                     | RCP2-RA10C<br>RCP2-HS8C (R)<br>RCP2W-SA16C  |  |         | RCP3 / RCP2 serie        | es actuator (Note 1)       |                         |                           |
| Number of control axes                      |   |  |         | 1-axis                   |                            |                         |                           |
| Operating method                            |   | Positioner type                                    |         | Solenoid valve type      | Pulse train                | input type              | Serial communication type |
| Positioning Points                          |   | 512 points   |         | 3 points                 | -                          | -                       | 64 points                 |
| Backup memory                               |   |  |         | EEPROM                   |                            |                         |                           |
| I/O connector                               |   | 40-pin connector 12-pin connector 14-pin connector |         |                          |                            | None                    |                           |
| Number of I/O                               | 16  | 16 input points/16 output points 4 in              |         |                          | 4 input points/            | 4 output points         | None                      |
| I/O power                                   |   | External supply DC24V±10% —                        |         |                          |                            |                         | -                         |
| Serial Communication                        | RS485 1ch   |  |         |                          |                            |                         |                           |
| Peripheral device communication cable       |   | CB-PAC-PIO   |         |                          | CB-PACPU                   | -PIO 🗆 🗆 🗆              | CB-RCB-CTL002             |
| Command pulse train input method            |   | - '  |         |                          | Differential line driver   | Open collector          | -                         |
| Max. input pulse frequency (Note 2)         |   |  | -       |                          | Max. 200 kpps              | Max. 60 kpps            | -                         |
| Position detection method                   |   |  |         | Incremental encoder      |                            |                         |                           |
| Drive-source cutoff relay at emergency stop | Integ   | rated  |         |                          | External                   |                         |                           |
| Forced release of electromagnetic brake     | Br  | ake release switch ON/O                            | FF      | ON/OFF                   | terminal signal inside the | power terminal for brak | ce release                |
| Input Supply Voltage                        |   |  |         | DC 24 V ± 10%            |                            |                         |                           |
| Power Supply Capacity                       | Max. 6A (*2)  |  |         | 2A r                     | nax.                       |                         |                           |
| Dielectric strength voltage                 |   |  |         | DC500V 1MΩ               |                            |                         |                           |
| Vibration resistance                        | XYZ directions 10 to 57Hz, One side amplitude: 0.035mm (continuous), 0.075mm (intermittent) 58 to 150Hz, 4.9m/s² (continuous), 9.8m/s² (intermittent) |  |         |                          |                            |                         |                           |
| Ambient operating temperature               |   |  |         | 0 ∼ 40℃                  |                            |                         |                           |
| Ambient operating humidity                  |   |  |         | 10 - 95% (non-condensing | 1)                         |                         |                           |
| Ambient operating atmosphere                |   |  |         | Without corrosion gases  |                            |                         |                           |
| Protection class                            |   |  |         | IP20                     |                            |                         |                           |
| Weight                                      | Approx. 320g  | Appro  | x. 300g |                          | Approx                     | c. 130a                 |                           |

(Note 1) The high-thrust type (RA10C), high-speed type (HS8C/HS8R) and waterproof type (RCP2W-SA16) cannot be operated.
(Note 2) With the open collector specification, keep the maximum input frequency to 60 kpps or below to prevent malfunction. For applications exceeding 60kpps, use the differential line driver.
(1) RCP2-RA10C/HS8C/HS8R and RCP2W-SA16C can only operate with PCON-CF.
Other RCP2 / RCP3 Series actuators can be operated with C / CG / CY / PL / PO / SE.
(2) Inrush current peak: 10A

531



Type

Mini

Standard

Controllers
Integrated

Flod

Type

Mini

Standard

Controllers
Integrated

Mini

Standard

Controllers
Integrated

Mini

Standard

Gripper/
Rotary Type

Cleanroom
Type

Cleanroom
Type

Controllers

PMEC
/MEC
/MEC
/MEC
PSEP
/ASEP

ROBO
NET

ERC2

POON

ACON


SCON


PSEL

ASEL


SSEL

## **External Dimensions**






### Name of Each Part



# C / CG / CF type



Type

Type \* PIO connectors are: CY: 12 pin PL/PO: 14 pin

## 1 LED display

These LED colors indicate the condition of the controller.

Lit (green) Servo ON Lit (red) Alarm activated Unlit Servo OFF Blinking (green) Automatic servo-off Emergency stop

#### 2 PIO connector

Connects a cable for communicating with a PLC or other external equipment.

### 3 Address-setting rotary switch

This switch sets the addresses for controllers used when the unit is linked with other controllers.

### 4 Mode switch

Switches between manual teaching operations (MANU) and automatic operations (AUTO).

### Operation details

| IVIAINO | I/O commands are not accepted. Data can be written from a teaching pendant or PC.   |
|---------|---|
| AUTO    | I/O commands are valid, while operations from a teaching pendant or PC are not accepted. However, monitoring is possible. |

## 5 SIO connector

Connects a teaching pendant, PC cable, controller, or gateway unit to a controller.

### Operation details

|   | Pin No. | Signal     | Name  | Remarks                     |
|---|---------|------------|---|-----------------------------|
| Γ | 1       | SGA        | Positive side, RS485 differential<br>signal         |                             |
| Г | 2       | SGB        | Negative side, RS485<br>differential signal         |                             |
|   | 3       | 5 <b>V</b> | +5V output  | For RS232/485<br>conversion |
|   | 4       | ENBL       | Enable signal                                       |                             |
|   | 5       | EMGA       | EMG line connection to<br>external equipment        |                             |
|   | 6       | 24V        | 24-V power for T/P                                  | For T/P                     |
| Γ | 7       | 0V         | GND   |                             |
| Г | 8       | EMGB       | EMG line connection to<br>external equipment        |                             |
|   | 9       | 0V         | EMG line connection to<br>external equipment ground |                             |

## 6 Encoder brake connector

Connects the encoder/brake cable for the actuator.

## 7 Brake release switch

This switch forces the brake to release

#### 8 Motor connector

Connects the motor cable for the actuator.

### 9 Power terminal block

Main power for controller(s), emergency stop

## C / CG type

| Terminal<br>number | Signal     | Name                                   |
|--------------------|------------|--|
| 7                  | S1         | External drive-source cutoff for TP_   |
| 6                  | S2         | EMG terminal                           |
| 5                  | MPI        | Motor drive-source cutoff terminal     |
| 4                  | MPO        | Motor drive-source cutoff terminal     |
| 3                  | 24V        | Positive side of the 24-V power supply |
| 2                  | 0 <b>V</b> | Negative side of the 24-V power supply |
| 1                  | EMG        | EMG signal (application of 24 V)       |


### CY / PL / PO / SE type

|  | Terminal<br>number | Signal | Name                                   |
|--|--------------------|--------|--|
|  | 6                  | вк     | BK release                             |
|  | 5                  | MPI    | Motor drive-source cutoff terminal     |
|  | 4                  | MPO    | Motor drive-source cutoff terminal     |
|  | 3                  | 24V    | Positive side of the 24-V power supply |
|  | 2                  | 0V     | Negative side of the 24-V power supply |
|  | 1                  | EMG    | EMG signal (application of 24 V)       |
|  |                    |        |  |


Controllers


PMEC
AMMEC
PSEP
ASEP
ROBO
NET
ERG2
PCON
ACON
SCON
PSEL











PCON **534** 




#### List of models

This position controller enables movement of the RCA2/RCA series actuators. A line-up of 5 types to support various controlling methods.

| Туре            | С  | CG  | CY  | PL/PO                    | SE                        |
|-----------------|--|---|---|--------------------------|---------------------------|
| Name            | Positioner type  | Safety category compatible type                     | Solenoid valve type   | Pulse train control type | Serial Communication Type |
| External view   |  |   |   |                          |                           |
| Description     | Positioner capable of a maximum of 512 points of Positioning | Conforming to type C safety category specifications | Can be operated using the same control as the air cylinder type | For pulse train control  | For serial communication  |
| Position points | 512 points   | 512 points  | 3 points  | (-)                      | 64 points                 |


#### Model



**535** ACON







ACON 536

Standard 1m / 3m / 5m For a replacement cable, see P544.



Actuator: RCA2 series


# I/O Specifications


#### ■ Input section External input specifications


| Item             | Specifications |
|------------------|----------------|
| Input voltage    | DC24V ±10%     |
| Input current    | 4mA/circuit    |
| Leak current     | 1mA max./point |
| Isolation method | Photocoupler   |
|                  |                |


| Output section | on External output specifications |
|----------------|-----------------------------------|
| Item           | Specifications                    |

| Item              | Specifications |
|-------------------|----------------|
| Load Voltage      | DC24V          |
| Max. load current | 50mA/point     |
| Remaining voltage | 2V or less     |
| Isolation method  | Photocoupler   |









# I/O Specifications

The 4 types of controllers (C/CG, CY, PL/PO, and SE) are classified by their respective I/O specifications. Also, for the positioner type and solenoid valve type, the I/O signal information can be changed in the controller settings, so multiple functions can be effectively used.

# ■ Control Function by Type

| Туре                   | C/CG            | CY                  | PL/PO                    | SE                        | Factures  |
|------------------------|-----------------|---------------------|--------------------------|---------------------------|---|
| Name                   | Positioner type | Solenoid valve type | Pulse train control type | Serial communication type | Features  |
| Positioner mode        | 0               | ×                   | ×                        | (*1)                      | This is the basic operating mode, in which the user designates position numbers and inputs start signals.   |
| Teaching mode          | $\circ$         | ×                   | ×                        | (*1)                      | In this mode, the slider (rod) moves based on an external signal, and the stopped positions can be registered as position data.   |
| Solenoid valve<br>mode | 0               | 0                   | ×                        | (*1)                      | The actuator can be moved simply by ON/OFF position signals. This mode supports the same control signals you are already familiar with on solenoid valves of air cylinders. |
| Pulse train mode       | ×               | ×                   | 0                        | ×                         | In this mode, you can operate the actuator freely without inputting position data.  |
| Network compatible     | (*2)            | ×                   | ×                        | (*3)                      | The controller can be connected to a DeviceNet or CC-Link network.  |

- \*1 Operates using network communications or serial communications.
- \*2 Can make a direct connection to a field network with the network specifications.
- \*3 Can be connected to a field network using a gateway unit.

**537** ACON



PMEC / AMEC PSEP / ASEP ROBO NET PCON ACON SCON PSEL SSEL

Mini
Standard
Controllers
Integrated

Flo
Typ

Mini
Standard

Table/Arr
//FlatTyp

Mini
Standard



The table below explains the functions allocated to the controller's I/O signal.

Since the signals that can be used vary depending on the controller type and settings, check the signal table for each controller to confirm the available functions.

# ■ Signal Function Description

| Classification | Signal abbreviations | Signal                         | Function description  |  |  |
|----------------|----------------------|--------------------------------|---|--|--|
|                | CSTR                 | Start signal                   | Input this signal to cause the actuator to start moving to the position set by the command position number signal.  |  |  |
|                | PC1 to PC256         | Command position number signal | This signal is used to input a target position number (binary input).   |  |  |
|                | BKRL                 | Brake forced release signal    | This signal forcibly releases the brake.  |  |  |
|                | RMOD                 | Running mode switching signal  | This signal can switch the running mode when the MODE switch on the controller is set to AUTO. (AUTO when this signal is OFF, or MANU when the signal is ON).   |  |  |
|                | * STP                | Pause signal                   | Turning this signal OFF causes the moving actuator to decelerate to a stop. The actuator will resume the remaining movement if the signal is turned ON during the pause.  |  |  |
|                | RES                  | Reset signal                   | Turning this signal ON resets the alarms that are present. If this signal is turned ON while the actuator is paused ("STP is OFF), the remaining movement can be cancelled.   |  |  |
|                | SON                  | Servo ON signal                | The servo remains on while this signal is ON, or off while the signal is OFF.   |  |  |
|                | НОМЕ                 | Home return signal             | Turning this signal ON performs home-return operation.  |  |  |
| Input          | MODE                 | Teaching mode signal           | Turning this signal ON switches the controller to teaching mode (provided that CSTR, JOG+ and JOG- are all OFF and the actuator is not moving).   |  |  |
|                | JISL                 | JOG/INJOG switching signal     | When the main signal is off, the JOG operation will be conducted for JOG+ and JOG When the signal is on, the unit will do the inching operation for JOG+ and JOG  |  |  |
|                | JOG+, JOG-           | JOG signal                     | When the JISL signal is off and the JOG +/- signal turns on, the unit will jog in the + (positive) direction when the JOG + turns on and the - (negative) direction when the JOG - turns on. During the JOG operation, the unit slows to a stop when the JOG +/- signal turns off.                            |  |  |
|                | PWRT                 | Teaching signal                | In the teaching mode, specify a desired position number and then turn this signal ON for at least 20ms to write the current position to the specified position number.  |  |  |
|                | ST0 to ST6           | Start position command         | Turning this signal ON in the solenoid valve mode causes the actuator to move to the specified position. (Start signal is not required)   |  |  |
|                | TL                   | Torque limit selection signal  | While this signal is ON, torque is limited by the value set by a parameter. The TLR signal turns on if torque has reached the specified value. (Dedicated pulse train type)   |  |  |
|                | DCLR                 | Deviation counter clear signal | The position deviation counter is continuously cleared while this signal is ON. (Dedicated pulse train type)  |  |  |
|                | PEND/INP             | In position signal             | This signal turns ON when the actuator has entered the positioning band after movement. If the actuator has exceeded the positioning band, PEND does not turn OFF, but INP does. PEND and INP can be swapped within parameters.   |  |  |
|                | PM1 to PM256         | Position complete signal       | This signal is used to output the position number achieved at the completion of positioning (binary output)   |  |  |
|                | HEND                 | Home return completion signal  | This signal turns ON upon completion of home return.  |  |  |
|                | ZONE1                | Zone signal                    | This signal turns ON when the current actuator position has entered the range specified by the parameters.  |  |  |
|                | PZONE                | Positioning zone signal        | Turns ON when actuator moves into a position within the range of the target position data that was set. PZONE can be used together with ZONE1, but PZONE is valid only during movement to a specified position.   |  |  |
|                | RMDS                 | Running mode status signal     | This outputs the operation mode status.   |  |  |
|                | * ALM                | Controller alarm status signal | This signal remains ON while the controller is not in the alarm condition, and turns OFF when an alarm has occurred.  |  |  |
| Output         | MOVE                 | Moving signal                  | Turns ON while the actuator is moving (home return), including when there is push force.  |  |  |
|                | sv                   | Servo ON status signal         | This signal turns ON when servo is ON.  |  |  |
|                | * EMGS               | Emergency stop status signal   | This signal remains ON while the controller is not in the emergency stop mode, and turns OFF once an emergency stop has been actuated.  |  |  |
|                | MODES                | Mode status signal             | The mode signal input turns it ON when it goes into teaching mode. It turns OFF when it goes into normal mode.  |  |  |
|                | WEND                 | Writing complete signal        | This signal remains OFF after the controller has switched to the teaching mode. It turns ON upon completion of data write using the PWRT signal. If the PWRT signal is turned Off, this signal also turns OFF.  |  |  |
|                | PE0 to PE6           | Current position number signal | This signal turns ON after the controller has completed moving to the target position in the solenoid valve mode.   |  |  |
|                | TLR                  | Torque limiting signal         | This signal turns ON once the motor torque has reached the specified value in a condition where torque is being limited by the TL signal. (Dedicated pulse train type)  |  |  |
|                | LSO to LS2           | Limit switch output signal     | Each signal turns ON when the current actuator position has entered the positioning band before or after the target position. If the actuator has already completed home return, these signals are output even before a movement command is issued or while the servo is OFF. (Dedicated Solenoid Valve Mode) |  |  |

(Note) Signals with asterisks (\*) are normally ON and OFF during operation.

Slider Type

Mini

Standard

Controllers Integrated

Rod Type

Mini

Standard

Controllers Integrated

> Table/Arm /FlatType

Mini

Standard

Gripper/ Rotary Type

Type

Гуре

Splash-Proof

Controllers

/AMEC

ROBO

ERC2

PCON

ACON

SCON

POEL

ASEL

SSEL

XSEL

Pulse Moto

Servo Moto (24V)

Servo Mot

Linear Servo Moto



# I/O Signal table

# ■ Positioner type (ACON-C / CG)

|     |                |                    |                  |               | Parameters (sel | lect PIO pattern) |                       |                       |
|-----|----------------|--------------------|------------------|---------------|-----------------|-------------------|-----------------------|-----------------------|
|     | <sub>E</sub>   |                    | 0                | 1             | 2               | 3                 | 4                     | 5                     |
| Pin | gaţi           |                    | Positioning mode | Teaching mode | 256-point mode  | 512-point mode    | Solenoid Valve Mode 1 | Solenoid Valve Mode 2 |
| No. | Classification | Positioning Points | 64 points        | 64 points     | 256 points      | 512 points        | 7 points              | 3 points              |
|     | පී             | Zone signal        | 0                | ×             | ×               | ×                 | 0                     | 0                     |
|     |                | P-zone signal      | 0                | 0             | 0               | ×                 | 0                     | 0                     |
| 1A  | 24V            |                    |                  |               | P               | 24                |                       |                       |
| 2A  | 24V            |                    |                  |               | P               | 24                |                       |                       |
| 3A  | _              |                    |                  |               | N               | IC                |                       |                       |
| 4A  | -              |                    |                  |               | N               | ic                |                       |                       |
| 5A  |                | IN0                | PC1              | PC1           | PC1             | PC1               | ST0                   | ST0                   |
| 6A  |                | IN1                | PC2              | PC2           | PC2             | PC2               | ST1                   | ST1 (JOG+)            |
| 7A  |                | IN2                | PC4              | PC4           | PC4             | PC4               | ST2                   | ST2 (-)               |
| 8A  |                | IN3                | PC8              | PC8           | PC8             | PC8               | ST3                   | -                     |
| 9A  |                | IN4                | PC16             | PC16          | PC16            | PC16              | ST4                   | -                     |
| 10A |                | IN5                | PC32             | PC32          | PC32            | PC32              | ST5                   | -                     |
| 11A |                | IN6                | -                | MODE          | PC64            | PC64              | ST6                   | -                     |
| 12A | Input          | IN7                | -                | JISL          | PC128           | PC128             | -                     | -                     |
| 13A |                | IN8                | =                | JOG+          | -               | PC256             | -                     | -                     |
| 14A |                | IN9                | BKRL             | JOG-          | BKRL            | BKRL              | BKRL                  | BKRL                  |
| 15A |                | IN10               | RMOD             | RMOD          | RMOD            | RMOD              | RMOD                  | RMOD                  |
| 16A |                | IN11               | НОМЕ             | HOME          | HOME            | HOME              | HOME                  | -                     |
| 17A |                | IN12               | * STP            | * STP         | * STP           | * STP             | * STP                 | -                     |
| 18A |                | IN13               | CSTR             | CSTR/PWRT     | CSTR            | CSTR              | -                     | -                     |
| 19A |                | IN14               | RES              | RES           | RES             | RES               | RES                   | RES                   |
| 20A |                | IN15               | SON              | SON           | SON             | SON               | SON                   | SON                   |
| 1B  |                | OUT0               | PM1              | PM1           | PM1             | PM1               | PE0                   | LSO                   |
| 2B  |                | OUT1               | PM2              | PM2           | PM2             | PM2               | PE1                   | LS1                   |
| 3B  |                | OUT2               | PM4              | PM4           | PM4             | PM4               | PE2                   | LS2 (-)               |
| 4B  |                | OUT3               | PM8              | PM8           | PM8             | PM8               | PE3                   | -                     |
| 5B  | -              | OUT4               | PM16             | PM16          | PM16            | PM16              | PE4                   | -                     |
| 6B  |                | OUT5               | PM32             | PM32          | PM32            | PM32              | PE5                   | -                     |
| 7B  | -              | OUT6               | MOVE             | MOVE          | PM64            | PM64              | PE6                   | -                     |
| 8B  | Output         | OUT7               | ZONE1            | MODES         | PM128           | PM128             | ZONE1                 | ZONE1                 |
| 9B  | -              | OUT8               | PZONE            | PZONE         | PZONE           | PM256             | PZONE                 | PZONE                 |
| 10B | -              | OUT9               | RMDS             | RMDS          | RMDS            | RMDS              | RMDS                  | RMDS                  |
| 11B | -              | OUT10              | HEND             | HEND          | HEND            | HEND              | HEND                  | HEND                  |
| 12B | -              | OUT11              | PEND             | PEND/WEND     | PEND            | PEND              | PEND                  | -                     |
| 13B | -              | OUT12              | SV<br>* FMCS     | SV<br>* FMCC  | SV<br>* FMCS    | SV<br>* FMCC      | SV                    | SV                    |
| 14B | -              | OUT13              | * EMGS           | * EMGS        | * EMGS          | * EMGS            | * EMGS                | * EMGS                |
| 15B | -              | OUT14              | * ALM            | * ALM         | * ALM           | * ALM             | * ALM                 | * ALM                 |
| 16B |                | OUT15              | _                | _             |                 |                   | _                     | _                     |
| 17B | -              |                    | NC<br>NC         |               |                 |                   |                       |                       |
| 18B | -              |                    |                  |               |                 | N .               |                       |                       |
| 19B | 0V             |                    |                  |               |                 |                   |                       |                       |
| 20B | 0V             |                    |                  |               |                 | N                 |                       |                       |

(Note) The names of signals above inside () are functions before the unit returns home. (Note) Signals with asterisks (\*) are normally ON, and OFF during operation.

# ■ Solenoid valve type (ACON-CY)

|     |                |                    | Parameters (sel       | ect PIO pattern)      |
|-----|----------------|--------------------|-----------------------|-----------------------|
|     | <sub>E</sub>   |                    | 0                     | 1                     |
| Pin | Classification |                    | Solenoid valve mode 0 | Solenoid valve mode 1 |
| No. | Issif          | Positioning Points | 3 points              | 3 points              |
|     | ਲੱ             | Zone signal        | ×                     | ×                     |
|     |                | P-zone signal      | ×                     | 0                     |
| 1   | 24V            |                    |                       |                       |
| 2   | ov             |                    |                       |                       |
| 3   |                | IN0                | ST0                   | ST0                   |
| 4   |                | IN1                | ST1 (JOG+)            | ST1 (JOG+)            |
| 5   | Input          | IN2                | ST2 (RES)             | ST2 (RES)             |
| 6   |                | IN3                | SON                   | SON                   |
| 7   |                | OUT0               | LS0                   | PE0                   |
| 8   |                | OUT1               | LS1                   | PE1                   |
| 9   | Output         | OUT2               | LS2 (-)               | PE2 (-)               |
| 10  | Output         | OUT3               | sv                    | PZONE                 |
| 11  |                | OUT4               | HEND                  | HEND                  |
| 12  |                | OUT5               | * ALM                 | * ALM                 |

(Note) The names of signals above inside () are functions before the unit returns home. (Note) Signals with asterisks (\*) are normally ON, and OFF during operation.

#### ■ Pulse Train Type (ACON-PL/PO)

|     |                |                    | Parameters (sel | ect PIO pattern) |
|-----|----------------|--------------------|-----------------|------------------|
|     | 5              |                    | 0               | 1                |
| Pin | icati          |                    | Standard mode   | Push mode        |
| No. | Classification | Positioning Points | -               | -                |
|     | පී             | Zone signal        | ×               | ×                |
|     |                | P-zone signal      | ×               | ×                |
| 1   | 24V            |                    |                 |                  |
| 2   | 0V             |                    |                 |                  |
| 3   | Input          | IN0                | SON             | SON              |
| 4   |                | IN1                | TL              | TL               |
| 5   |                | IN2                | HOME            | HOME             |
| 6   |                | IN3                | RES             | RES / DCLR       |
| 7   |                | OUT0               | SV              | sv               |
| 8   | Output         | OUT1               | INP             | INP / TLR        |
| 9   | Output         | OUT2               | HEND            | HEND             |
| 10  | ]              | OUT3               | * ALM           | * ALM            |
| 11  |                |                    | * PP            | * PP             |
| 12  | Input          |                    | PP              | PP               |
| 13  |                |                    | * NP            | * NP             |
| 14  | ]              |                    | NP              | NP               |

(Note) Signals with asterisks (\*) are normally ON, and OFF during operation.

**539** ACON



Type

Mini

Standard

Controllers
Integrated

Rod
Type

Mini

Standard

Controllers
Integrated

Table/Arm
/FlatType

Mini

Standard

Gripper/
Rotary Type

Cleanroom
Type

Cleanroom
Type

Controllers

PAGE
/AMEC
PSEP
/ASEP
ROBO
NET
ERG2

PCON
ACON

SCON

PSEL


ASEL

XSEL

# Wiring Diagram for the Pulse-Train Input Type


#### ■ Differential Line Driver Method (ACON-PL)

Max. input pulse frequency : Max. 200 kpps Cable Length : Max. 10m



## ■ Open Collector Method (ACON-PO)

Max. input pulse frequency : Max. 60 kpps Cable Length : Max. 2m



Controllers Integrated

And

Standard

Controllers
Integrated

Fable/Arm
FlatType

Mini

Controllers

PMEC /AMEC

PSEP /ASEP

ROBO NET

ERC2

PCON

ACON

SCON

PSEL

ASEL



# Command Pulse Input State

|                | Command pulse train state    | Input terminal                    | During forward operation                      | During reversed operation                  |  |
|----------------|------------------------------|-----------------------------------|---|--|--|
|                | Forward pulse train          | PP•/PP                            |   |  |  |
|                | Reversed pulse train         | NP•/NP                            |   |  |  |
|                | The forward pulse            | train causes the motor to rotat   | e forward, and the reverse pulse train causes | the motor to rotate in reverse.            |  |
| logic          | Pulse train                  | PP+/PP                            |   |  |  |
| Negative logic | Symbols                      | NP•/NP                            | Low   | High                                       |  |
| S              | The command p                | ulse is used for the amount of    | motor rotation, and the command symbol is u   | sed for rotational direction.              |  |
|                | A/B phase pulse train        | PP•/PP                            |   | <b>1 1 1</b>                               |  |
|                | A/B phase pulse train        | NP•/NP                            |   |  |  |
|                | An A/B phase pulse with a 90 | o° phase difference (multiplier i | s 4) is used to generate commands for the am  | ount of rotation and rotational direction. |  |
|                | Forward pulse train          | PP•/PP                            |   |  |  |
| o              | Reversed pulse train         | NP•/NP                            |   |  |  |
| Positive logic | Pulse train                  | PP+/PP                            |   |  |  |
| Positiv        | Symbols                      | NP•/NP                            | High  | Low  |  |
|                | A/B phase pulse train        | PP+/PP                            |   |  |  |
|                | pacc pulse train             | NP·/NP                            |   |  |  |

# Table of specifications

| Item  |   |                     | Specifi                        | cations                   |                      |                           |
|---|---|---------------------|--------------------------------|---------------------------|----------------------|---------------------------|
| Controller type                             | С   | CG                  | CY                             | PL                        | PO                   | SE                        |
| Connected actuator                          |   | RCA Series Actuator |                                |                           |                      |                           |
| Number of control axes                      |   |                     | 1-6                            | ıxis                      |                      |                           |
| Operating method                            | Positio   | ner type            | Solenoid valve type            | Pulse train               | input type           | Serial communication type |
| Positioning Points                          | 512 p   | oints               | 3 points                       | _                         |                      | 64 points                 |
| Backup memory                               |   |                     | EEP                            | ROM                       |                      |                           |
| I/O connector                               | 40-pin c  | onnector            | 12-pin connector               | 14-pin co                 | onnector             | None                      |
| Number of I/O                               | 16 input points/  | 16 output points    | 4 input points / 6 output poir | nts 4 input points/       | 4 output points      | None                      |
| I/O power                                   | External supply DC24V±10%   |                     |                                | _                         |                      |                           |
| Serial Communication                        |   | RS485 1ch           |                                |                           |                      |                           |
| Peripheral device communication cable       | CB-PAC-PIO 🗆 🗆  |                     | CB-PACY-PIO                    | CB-PACPU                  | CB-PACPU-PIO □□□     |                           |
| Command pulse train input method            |   | -                   |                                | Differential line driver  | Open collector       | _                         |
| Max. input pulse frequency (Note 1)         |   | -                   |                                | Max. 200 kpps             | Max. 60 kpps         | -                         |
| Position detection method                   |   |                     | Increment                      | al encoder                |                      |                           |
| Drive-source cutoff relay at emergency stop | Integrated  |                     |                                | External                  |                      |                           |
| Forced release of electromagnetic brake     | Brake release   | switch ON/OFF       | ON/OFF to                      | erminal signal inside the | power terminal for b | orake release             |
| Input Voltage                               |   |                     | DC24V                          | ± 10%                     |                      |                           |
| Dielectric strength voltage                 |   |                     | DC500                          | <b>V</b> 1 <b>M</b> Ω     |                      |                           |
| Vibration resistance                        | XYZ directions 10 to 57Hz, One side amplitude: 0.035mm (continuous), 0.075mm (intermittent) 58 to 150 Hz 4.9 m/s² (continuous), 9.8 m/s² (intermittent) |                     |                                | ntermittent)              |                      |                           |
| Ambient operating temperature               | $0\sim40^{\circ}\mathrm{C}$   |                     |                                |                           |                      |                           |
| Ambient operating humidity                  | 10 - 95% (non-condensing)   |                     |                                |                           |                      |                           |
| Ambient operating atmosphere                | Without corrosive gases   |                     |                                |                           |                      |                           |
| Protection class                            |   |                     | IP                             | 20                        |                      |                           |
| Weight                                      | Appro   | c. 300g             |                                | Approx                    | c. 130g              |                           |

(Note 1) With the open collector specification, keep the maximum input frequency to 60 kpps or below to prevent malfunction. For applications exceeding 60kpps, use the differential line driver.


|                                | Actuator    | Motor  | Standard specifications/high acce | eleration and deceleration model | Power-saving model |          |  |
|--------------------------------|-------------|--|-----------------------------------|----------------------------------|--------------------|----------|--|
|                                | Actuator    | Motor  | Rated [A]                         | Max. [A]                         | Rated [A]          | Max. [A] |  |
|                                |             | 10W  | 1.3                               | 4.4                              | 1.3                | 2.5      |  |
| Motor                          |             | 20W [Model symbol: 20]                                     | 1.3                               | 4.4                              | 1.3                | 2.5      |  |
| Power                          | RCA         | 30W  | 1.3                               | 4.4                              | 1.3                | 2.2      |  |
| Supply<br>Capacity<br>(Note 2) | Supply RCA2 | 20W [Model symbol: 20S]<br>SA4, RA3, TA5<br>Type dedicated | 1.7                               | 5.1                              | 1.7                | 3.4      |  |
|                                |             | 2W   | 0.8                               | 4.6                              |                    |          |  |
| RCL                            |             | 5W   | 1.0                               | 6.4                              |                    |          |  |
|                                |             | 10W  | 1.3                               | 6.4                              |                    |          |  |


(Note 2) Other than motor power supply capacity, increase 0.5A as control power supply. Inrush current of approx. 5 to 12 times the rated current occurs within 1 to 2 msec from turning the power on. The inrush current changes depending on the power supply line impedance.

**541** ACON





# **External Dimensions**





#### Name of Each Part





Type

Type PIO connectors are: CY: 12 pin PL/PO: 14 pin

# 1 LED display

These LED colors indicate the condition of the controller.

Lit (green) Servo ON Lit (red) Alarm activated Unlit Servo OFF Blinking (green) Automatic servo-OFF Emergency stop

#### 2 PIO connector

Connects a cable for communicating with a PLC or other external equipment.

#### 3 Address-setting rotary switch

This switch sets the addresses for controllers used when the unit is linked with controllers.

#### 4 Mode switch

Switches between manual teaching pendant operations (MANU) and automatic operations (AUTO).

#### Operation details

| MANUAL | written from a teaching pendant or PC.  |
|--------|---|
| AUTO   | I/O commands are valid, while operations from a teaching pendant or PC are not accepted. However, monitoring is possible. |

# 5 SIO connector

Connects a teaching pendant, PC cable, controller, or gateway unit to a controller.

#### Operation details

| Pin No. | Signal | Name  | Remarks                     |
|---------|--------|---|-----------------------------|
| 1       | SGA    | Positive side, RS485<br>differential signal         |                             |
| 2       | SGB    | Negative side, RS485<br>differential signal         |                             |
| 3       | 5V     | +5V output  | For RS232/485<br>conversion |
| 4       | ENBL   | Enable signal                                       |                             |
| 5       | EMGA   | EMG line connection to<br>external equipment        |                             |
| 6       | 24V    | 24-V power for T/P                                  | For T/P                     |
| 7       | 0V     | GND   |                             |
| 8       | EMGB   | EMG line connection to<br>external equipment        |                             |
| 9       | 0V     | EMG line connection to<br>external equipment ground |                             |

# 6 Encoder brake connector

Connects the encoder/brake cable for the actuator.

## 7 Brake release switch

This switch forces the brake to release.

## 8 Motor connector

Connects the motor cable for the actuator.

#### 9 Power terminal block

Main power for controller(s), emergency stop

#### C / CG type

| Terminal number | Signal     | Name                                   |
|-----------------|------------|--|
| 7               | S1         | External drive-source cutoff for       |
| 6               | S2         | TP_EMG terminal                        |
| 5               | MPI        | Motor drive-source cutoff terminal     |
| 4               | MPO        | Motor drive-source cutoff terminal     |
| 3               | 24V        | Positive side of the 24-V power supply |
| 2               | 0 <b>V</b> | Negative side of the 24-V power supply |
| 1               | EMG        | EMG signal (application of 24 V)       |

#### CY / PL / PO / SE type

| ************************************** |     |  |  |  |
|--|-----|--|--|--|
| Terminal Signal                        |     | Name                                   |  |  |
| 6                                      | вк  | BK release                             |  |  |
| 5                                      | MPI | Motor drive-source cutoff terminal     |  |  |
| 4                                      | MPO | Motor drive-source cutoff terminal     |  |  |
| 3                                      | 24V | Positive side of the 24-V power supply |  |  |
| 2                                      | 0V  | Negative side of the 24-V power supply |  |  |
| 1                                      | EMG | EMG signal (application of 24 V)       |  |  |
|  |     |  |  |  |

Splash-Proo
Controllers
PMEC
/AMEC
PSEP
/ASEP
ROBO
NET
ERC2
PCON
ACON
SCON
PSEL

ACON 542



#### Option


# **Teaching Pendant**

Features This is a teaching device that provides information on functions such as position input, performing test runs, and monitoring.

■ Model CON-PT-M-ENG (Touch panel teaching

CON-T-ENG (Standard type)

RCM-E-ENG (Simple teaching pendant)



**■ CON-T-ENG Options** 

 Wall-mounting hook Model HK-1

 Strap Model STR-1



# 110.0 (113.5)

Specifications

| Item                                | CON-PT-M-ENG                            | CON-T-ENG                         | RCM-E-ENG                         |  |  |
|-------------------------------------|---|-----------------------------------|-----------------------------------|--|--|
| Data Input                          | 0                                       | 0                                 | 0                                 |  |  |
| Actuator motion                     | 0                                       | 0                                 | 0                                 |  |  |
| Ambient Operating<br>Temp./Humidity | Temp: 0~4                               | 0°C; Humidity: 85% RF             | l or below                        |  |  |
| Ambient Operating<br>Atmosphere     | No corrosive gases. Especially no dust. |                                   |                                   |  |  |
| Protection class                    | IP40                                    | IP54                              | _                                 |  |  |
| Weight                              | Approx. 750g                            | Approx. 400g                      | Approx. 400g                      |  |  |
| Cable Length                        |   | 5m                                |                                   |  |  |
| Display                             | 3-color LED touch panel with backlight  | 20 char. × 4 lines<br>LCD display | 16 char. × 2 lines<br>LCD display |  |  |


## PC Software (Windows Only)

Features A startup support software for inputting positions, performing test runs, and monitoring. With enhancements for adjustment functions, the startup time is shortened.

■ Model RCM-101-MW (External device communications cable + RS232 conversion unit)




■ Model RCM-101-USB (External device communications cable + USB adapter + USB cable)





# Spare parts

When you need spare parts after purchasing the product, such as when replacing a cable, refer to the list of models below.



Min. bend radius r = 50 mm or larger (when movable type is used)



ervo Moto (24V










































ACON 544



Simple absolute unit For PCON / ACON controller



#### Features

When attached to a ACON/PCON-C, -CG, -CY, or -SE (incremental) controller, the data from the encoder is retained even after the controller's main power has been turned OFF, allowing you to use it as an absolute model, which does not require homing at power-up.


\* Cannot be used for ACON/PCON-PL or PO types.


The encoder type for the actuators and controllers with a simple absolute unit is "I" (incremental) and not "A" (absolute).

Having the same size as the CY and SE compact controllers (W 34mm × H 100mm × D 75.3mm), it can be installed in a small space.

Encoder data can be retained up to 20 days.

An error will occur if the actuator's slider or rod is moved faster than the fixed speed, while the encoder data is retained. Check the specifications table on page 546 for the allowable speed (rotations).





#### Models

|       | For PCON controller | For ACON controller |  |  |
|-------|---------------------|---------------------|--|--|
| Model | PCON-ABU            | ACON-ABU            |  |  |

#### Connectable actuator

The simple absolute unit is available for the following actuators. (Models other than following models are not available.)

| Pulse Motor |  |
|-------------|--|
|             |  |

| Reference   |
|---|
| Corresponding to all models                             |
| Corresponding to all models other than HS8C/HS8R/RA10C. |
| Corresponding to all models other than HS8C.            |
| Corresponding to all models other than SA16C/RA10C.     |
| Corresponding to all models                             |
|   |

545 PCON-ABU/ACON-ABU




















# Specifications

| Item   | Details   |                  |                         |            |  |  |
|--|---|------------------|-------------------------|------------|--|--|
| Model  | ACON-ABU  |                  | PCON-ABU                |            |  |  |
|  | ACON - C /  | CG / CY / SE     | PCON - C / CG / CY / SE |            |  |  |
| Connecting controller                            | When choosing a controller to connect with the simple absolute unit, add                                |                  |                         |            |  |  |
|  | Caution:  "-ABU" to the end of the controller model designation.  Ex. ACON - C - 201 - NP - 2 - 0 - ABU |                  |                         |            |  |  |
| Connecting actuator                              | RCA2 /  | RCA series       | RCP3/RCP2 se            | ries (* 1) |  |  |
| Controller connection cable (included accessory) | Model CB - A  | C - PJ002 (0.2m) | Model CB - PC - PJ00    | 2 (0.2m)   |  |  |
| Simple absolute unit                             | Model ABU   |                  |                         |            |  |  |
| Backup battery (included accessory)              | Model AB - 7 (Ni - MH battery / Life: approx. 3 years)  |                  |                         |            |  |  |
| Power supply voltage                             | DC24V±10%   |                  |                         |            |  |  |
| Power supply current                             | Max. 300 mA   |                  |                         |            |  |  |
| Ambient operating temperature                    | 0 to 40°C (approx. 20°C is preferred)   |                  |                         |            |  |  |
| Ambient operating humidity                       | 95% RH or lower (non-condensing)  |                  |                         |            |  |  |
| Ambient operating atmosphere                     | Without corrosive gases, without dust   |                  |                         |            |  |  |
| Weight   | 330g  |                  |                         |            |  |  |
|  |   |                  |                         |            |  |  |
| Allowable encoder RPM during data retention (*2) | 800 rpm   | 400 rpm          | 200 rpm                 | 100 rpm    |  |  |
| Position data retaining time (*2)                | 120h  | 240h             | 360h                    | 480h       |  |  |

<sup>(\*1)</sup> Cannot be used with RCP2-RA10C/HS8C/HS8R/RCP2W-SA16C

(800rpm ightarrow 120h  $\diagup$  400rpm ightarrow 240h  $\diagup$  200rpm ightarrow 360h  $\diagup$  100rpm ightarrow 480h)

# **External dimensions**



ler e

Currelin

Controller

Rod Type

Mini

Standard

Controllers Integrated

> Table/Arm 'FlatTvpe

Mini

Gripper/ Rotary Type

Linear Servo Type

Cleanroom Type

Splash-Proof

Controllers

PMEC /AMEC

ROBO NET

ERC2

ACON

SCON

PSEL

SSEL

XSEL

Pulse Moto

Servo Motor (24V)

Servo Moto (200V)

Linear Servo Moto

рсон-ави/асон-ави 546

<sup>(\*2)</sup> Position data retention time changes with the allowable encoder RPMs during data retention.



#### List of models


There are 2 types of SCON controllers: standard specifications in which operation is performed via PIO or pulse train input, and network specifications for operation via connection to a field network. Incremental specifications and absolute specifications are available for both types. However, only incremental specified operations are available when operating via the pulse train input.

| Туре               |             | С                              |                  |  |          |                              |                         |                                       |          |
|--------------------|-------------|--------------------------------|------------------|--|----------|------------------------------|-------------------------|---------------------------------------|----------|
| Name               |             | Standard                       |                  |  | N        | letwork connection s         | pecifications (optional | )                                     |          |
| External View      |             |                                |                  |  |          |                              |                         |                                       |          |
| Description        |             | e, Teaching mode<br>/alve Mode | Pulse train mode | Pulse train mode DeviceNet Connection specifications |          | ns Connection specifications |                         | ProfiBus<br>Connection specifications |          |
| Position points    | Max. 51     | 2 points                       | (-)              |  |          |                              | 2 points                |                                       |          |
| I/O type symbol    |             | NP/PN                          |                  | DV   |          | C                            | С                       | P                                     | R        |
| Compatible encoder | Incremental | Absolute                       | Incremental      | Incremental  | Absolute | Incremental                  | Absolute                | Incremental                           | Absolute |

<sup>\*</sup>Always use a noise filter for power supplies. (See P548)

(Caution) Note that with the network specifications, neither control via pulse train nor PIO is available.

# Model



**547** scon



ontrollers
Integrated

Fixo
Typ

Mini

Standard

Controllers
Integrated

Table/Arr
/FlatTyp

Mini

Standard

Controllers

PMEC
/AMEC

PSEP
/ASEP

ROBO
NET

ERC2

PCON


ACON

SCON

PSEL

ASEL

XSEL



Outer diameter of finished wire 1.0 to 1.2mm

scon **548** 



Mini
Standard
Controllers
Integrated
Pro
Typ
Mini
Standard
Table/Arr
//FlatTyp
Mini
Standard

PMEC /AMEC PSEP /ASEP ROBO NET / ACON SCON PSEL ASEL

# I/O Specifications


#### ■ Input section External input specifications


| Dr                  | 0                             |
|---------------------|-------------------------------|
| Item                | Specifications                |
| Input voltage       | DC24V ±10%                    |
| Input current       | 4mA / 1 point                 |
| ON/OFF power supply | ON voltageMin DC18.0V (3.5mA) |
| ON/OFF power supply | ON voltageMax DC6.0V (1mA)    |
| Isolation method    | Photocoupler                  |


| NPN Specifications   |
|--|
| +24V  Input  S.6kΩ  Logic circuit  OV  W  N  N  N  N  N  N  N  N  N  N  N  N |

# ■ Output section External output specifications

| Item              | Specifications                   |
|-------------------|----------------------------------|
| Load Voltage      | DC24V                            |
| Max. load current | 100mA / 1 point 400mA / 8 points |
| Leak current      | Max 0.1mA / 1 point              |
| Isolation method  | Photocoupler                     |







# Explanation of I/O Signal Functions

SCON-C is compatible with all of the following control methods.

Positioning is possible with up to 512 points in positioner mode and up to 7 points in solenoid valve mode.

# ■ Control Function by Type

| Туре                | SCON-C | Features   |
|---------------------|--------|--|
| Positioner mode     |        | This is the basic operating mode, in which the user designates position numbers and inputs start signals.  |
| Teaching mode       | 0      | In this mode, it is possible to move the slide (rod) via external signal, and then register the stop position as position data.  |
| Solenoid valve mode | 0      | The actuator can be moved simply by ON/OFF of position signals. This mode supports the same control signals you are already familiar with on solenoid valves of air cylinders. |
| Pulse train mode    | 0      | In this mode, you can operate the actuator freely using pulse trains without inputting position data.  |
| Network compatible  | 0      | If the optional network specifications are selected, direct connection to a field network is possible.   |

#### CAUTION -

Note that for network compatible types, PIO and pulse train communication are not available.

**549** scon



Servo M
(2
Li
Servo M

The table below explains the functions allocated to the controller's I/O signal.

Since the signals that can be used vary depending on the controller type and settings, check the signal table for each controller to confirm the available functions.

#### ■ Signal Function Description

| Classification | Signal abbreviations | Signal                                       | Function description  |
|----------------|----------------------|--|---|
|                | CSTR                 | Start signal                                 | Input this signal to cause the actuator to start moving to the position set by the command position number signal.  |
|                | PC1 to PC256         | Command position number signal               | This signal is used to input a target position number (binary input).   |
|                | BKRL                 | Brake forced release signal                  | This signal forcibly releases the brake.  |
|                | RMOD                 | Running mode switching signal                | Operations mode can be switched when the controller's MODE switch is set to AUTO. (AUTO if this signal is OFF, MANU if the signal is ON)  |
|                | * STP                | Pause signal                                 | Turning this signal OFF causes the moving actuator to decelerate to a stop. The actuator will resume the remaining movement if the signal is turned ON during the pause.  |
|                | RES                  | Reset signal                                 | Turning this signal ON resets the alarms that are present. If this signal is turned ON while the actuator is paused ("STP is OFF), the remaining movement can be cancelled.   |
|                | SON                  | Servo ON signal                              | The servo remains on while this signal is ON, or off while the signal is OFF.   |
|                | HOME                 | Home return signal                           | Turning this signal ON preforms home-return operation.  |
| Input          | MODE                 | Teaching mode signal                         | Turning this signal ON switches the controller to the teaching mode (provided that CSTR, JOG+ and JOG- are all OFF and the actuator is not moving)  |
|                | JISL                 | JOG/INCHING switching signal                 | When the main signal is off, the JOG operation will be conducted for JOG+ and JOG When the signal is on, the unit will do the inching operation for JOG+ and JOG  |
|                | JOG+, JOG-           | JOG signal                                   | When the JISL signal is OFF and the JOG +/- signal turns ON, the unit will jog in the + (positive) direction when the JOG + turns on and the - (negative) direction when the JOG - turns on. During the JOG operation, the unit slows to a stop when the JOG +/- signal turns off.  |
|                | PWRT                 | Teaching signal                              | In the teaching mode, specify a desired position number and then turn this signal ON for at least 20ms to write the current position to the specified position number.  |
|                | ST0 to ST6           | Start position command signal                | Turning this signal ON in the solenoid valve mode causes the actuator to move to the specified position. (Start signal is not required)   |
|                | TL                   | Torque limit selection signal                | While this signal is ON, torque is limited by the value set by a parameter. The TLM signal turns on if torque has reached the specified value.  |
|                | CSTP                 | Forced Stop Signal                           | Servo OFF is performed when this signal is ON for more than 10ms.   |
|                | DCLR                 | Deviation counter clear signal               | When this signal is ON, the position deviation counter is cleared continuously.   |
|                | PEND/INP             | In position signal                           | This signal turns ON when the actuator has entered the positioning band after movement. If the actuator has exceeded the positioning band, PEND does not turn OFF, but INP does. PEND and INP can be swapped using a parameter.   |
|                | PM1 to PM256         | Positioning complete signal                  | This signal is used to output the position number achieved at completion of positioning (binary output)   |
|                | HEND                 | Home return completion signal                | This signal turns ON upon completion of home return.  |
|                | ZONE1                | Zone signal                                  | Turns ON if the actuator's current position is within the range set by the parameter.   |
|                | PZONE                | Position zone signal                         | This signal turns ON when the current actuator position has entered the range specified by position data during position movement. PZONE can be used together with ZONE1, but PZONE is valid only during movement to a specified position.  |
|                | RMDS                 | Running mode status signal                   | This outputs the operation mode status.   |
|                | * ALM                | Controller alarm status signal               | Turns ON when the controller is in normal condition, and turns OFF when an alarm occurs.  |
|                | MOVE                 | Moving signal                                | Turns ON while the actuator is moving (home return), including when there is push force.  |
|                | sv                   | Servo ON status signal                       | This signal turns ON when servo is ON.  |
| Output         | * EMGS               | Emergency stop status signal                 | This signal remains ON while the controller is not in the emergency stop mode, and turns OFF once an emergency stop has been actuated.  |
|                | * BALM               | Absolute battery voltage drop warning signal | With the absolute specifications for the controller, turns OFF when the absolute battery voltage drops.   |
|                | MODES                | Mode status signal                           | The mode signal input turns it ON when it goes into teaching mode. It turns OFF when it goes into normal mode.  |
|                | WEND                 | Writing complete signal                      | This signal remains OFF after the controller has switched to the teaching mode. It turns ON upon completion of data write using the PWRT signal. If the PWRT signal is turned Off, this signal also turns OFF.  |
|                | PE0 to PE6           | Current position number signal               | This signal turns ON after the controller has completed moving to the target position in the solenoid valve mode.   |
|                | PWR                  | System Ready Signal                          | Turns ON when it starts up normally after turning ON the controller. (Dedicated pulse train type)   |
|                | TLR                  | Torque limiting signal                       | This signal turns ON once the motor torque has reached the specified value in a condition where torque is being limited by the TL signal. (Dedicated pulse train mode)  |
|                | ALM1 to ALM8         | Alarm Code Output Signal                     | During a controller alarm, the alarm details are output in code. (Dedicated pulse train mode)   |
|                | LSO to LS2           | Limit switch output signal                   | Each signal turns ON when the current actuator position has entered the positioning band before<br>or after the target position. If the actuator has already completed home return, these signals are<br>output even before a movement command is issued or while the servo is OFF. |

(Note) Signals with asterisks (\*) are normally ON and OFF during operation.

Slider Type

Mini

Standard

Rod

Mini

Controllers

Table/Arm /FlatType

Mini

Standard

Gripper/ Rotary Type

Linear Servo

Туре

Splash-Proof

Controllers

PMEC /AMEC

ROBO

ERC2

PCON

ACON

SCON

POEL

ASEL

SSEL

XSEL

Pulse Moto

Servo Mot (24V)

Servo Motor (200V)

Linear Servo Moto

scon **550** 

# I/O wiring drawing

■ Positioning mode / teaching mode / solenoid valve mode

PIO connector (NPN)

Mini
Standard
Controllers
Integrated

Flod
Type

Mini
Standard
Controllers
Integrated

Table/Arm
//FlatType

Mini
Standard

Gripper/
Rotary Type

Cleanroom
Type

Controllers

PMEC
//MEC
PSEP
//ASED

ROBO
NET

ERC2

PCON

ACON

SCON

PSEL

ASEL

XSEL

| Din Number   Classification   Signal   24V   2   |            |                |          |   |
|--|------------|----------------|----------|---|
| 2A Power Supply 24V 3A — Not used 4A — Not used 5A   IN0 5A   IN1 IN1 IN2 IN3 IN3 IN4 IOA   IN5 IIN5 IIN6 IIN7 IIN7 IIN8 IIN8 IIN9 IIN9 IIN1 IIN1 IIN1 IIN1 IIN1 IIN1  | Pin Number | Classification | Signal   |   |
| 2A   | 1A         |                | 24V      |   |
| 4A — Not used 5A   INO 6A   INO 6A   INI 6A   INI 1N1 1N2 1N3 8A   IN3 9A   IN4 10A   IN5 11A   IN6 11A   IN6 11A   IN8 11A   IN9 11A   IN9 11A   IN1 11A    | 2A         | Power Supply   | 24V      |   |
| SA   | 3A         | _              | Not used | •                                       |
| IN1  | 4A         | _              | Not used |   |
| N2   | 5A         |                | IN0      | · • · · · · · · · · · · · · · · · · · · |
| SA   | 6A         |                | IN1      |   |
| 9A 110A 110A 111A 111A 112A 113A 113A 114A 115A 115A 115A 115A 115A 115A 115   | 7A         |                | IN2      | ·                                       |
| 10A   11A   11B   11B   11B   11B   11A   11B    | 8A         |                | IN3      | -                                       |
| 11   | 9A         |                | IN4      | ·                                       |
| 12A  | 10A        |                | IN5      |   |
| 13A INS  | 11A        |                | IN6      | · • · · · · · · · · · · · · · · · · · · |
| 13A INS  | 12A        |                | IN7      |   |
| 15A  |            | Input          |          | •                                       |
| 16A  | 14A        |                | IN9      |   |
| 17A  | 15A        |                | IN10     | •                                       |
| 18A  | 16A        |                | IN11     |   |
| 19A   IN14   IN15   IN16   IN1 | 17A        |                | IN12     | · • · · · · · · · · · · · · · · · · · · |
| 20A   INI5   OUTO   OUT | 18A        |                | IN13     |   |
| 18   | 19A        |                | IN14     | · • · · · · · · · · · · · · · · · · · · |
| 2B 3B 4B OUT2 OUT3 OUT5 FB 6B OUT5 OUT6 OUT7 OUT7 OUT7 OUT7 OUT7 OUT7 OUT7 OUT7  | 20A        |                | IN15     |   |
| 38 48 58 0UT2 0UT3 0UT3 0UT4 0UT5 7B 8B 0UT6 0UT6 0UT7 0UT8 0UT9 10B 11B 0UT10 0UT10 0UT11 13B 0UT11 0UT11 15B 0UT14 0UT15 16B 0UT14 0UT15 17B   | 1B         |                | OUT0     |   |
| 48 58 68 78 88 Output 98 10B 11B 12B 13B 13B 14B 15B 16B 0UT12 0UT13 0UT14 0UT14 0UT15 0UT10 0UT11 0UT | 2B         |                | OUT1     |   |
| 5 B 6 B 7 B OUT5 OUT6 OUT7 OUT7 OUT7 OUT7 OUT7 OUT7 OUT7 OUT7  | 3B         |                | OUT2     | - 5                                     |
| 6 B 7 B Output OUT5 OUT6 OUT7 OUT8 OUT7 OUT8 OUT9 OUT10 OUT10 OUT10 OUT11 OUT11 OUT12 OUT14 OUT14 OUT14 OUT14 OUT15 OUT1 | 4B         |                | OUT3     |   |
| 7B 8B 9B Output OUT7 OUT8 OUT9 11B 12B 13B OUT10 OUT11 OUT11 15B 16B OUT14 16B 17B Not used 18B Not used 19B Pager Supply  | 5B         | 1              | OUT4     | - 5 - <u> </u>                          |
| 8 B Output OUT7 9 B OUT9 10 OUT10 11 B OUT11 12 B OUT11 13 B OUT12 14 B OUT13 15 B OUT14 16 D OUT15 17 B Not used 18 B Not used 19 B Power Survey 19 OV  | 6B         |                | OUT5     |   |
| Section  | 7B         | 1              |          | <b>-</b> 0                              |
| 98 OUT9 10B OUT9 11B OUT10 12B OUT11 13B OUT12 14B OUT13 15B OUT14 16B OUT14 16B OUT15 17B — Not used 18B — Not used 19B Power Survey 0V   | 8B         | Output         |          |   |
| 11B OUT10 12B OUT11 13B OUT11 14B OUT12 14B OUT13 15B OUT14 16B OUT15 17B — Not used 18B — Not used 19B Power Survey 19B Powe |            | Output         | OUT8     | <b></b>                                 |
| 12B OUT11 13B OUT13 14B OUT13 15B OUT14 16B OUT15 17B — Not used 18B — Not used 19B Power Supply 0V  | 10B        |                | OUT9     | <b>~</b> ~~                             |
| 13B OUT12 OUT13 15B OUT14 OUT14 OUT15 OUT1 | 11B        | 1              | OUT10    |   |
| 14B OUT13 15B OUT14 16B OUT15 17B - Not used 18B - Not used 19B Power Supply 0V  |            |                | OUT11    | <b>-</b> _5                             |
| 15B OUT14 16B OUT15 17B — Not used 18B — Not used 19B Power Surply 0V  | 13B        | 1              | OUT12    |   |
| 16B OUT15 17B — Not used 18B — Not used 19B Power Supply OV  |            |                |          |   |
| 17B — Not used 18B — Not used 19B Power Supply OV  | 15B        | 1              | OUT14    |   |
| 17B — Not used 18B — Not used 19B Power Supply OV  | 16B        |                | OUT15    | <b></b> 5→                              |
| 19B Power Supply 0V  |            | _              |          | <u>-</u>                                |
|  | 18B        | _              |          |   |
|  |            | Dawas Com-1    |          | ·                                       |
|  |            | rower Supply   |          | -                                       |

<sup>\*</sup> Connect 24V between pins 1A and 2A, and 0V between pins 19B and 20B.

#### ■ Pulse train mode (differential output)

| Pin Number C | lassification | Signal     | Twist pair                            |
|--------------|---------------|------------|---------------------------------------|
| 1            | nassincation  | Not used   | Shield                                |
| 2            |               | Not used   |                                       |
| 3            |               | PP         |                                       |
| 4            |               | /PP        |                                       |
| 5            | Input         | NP         |                                       |
| 6            |               | /NP        |                                       |
| 7            |               | AFB        |                                       |
| 8            |               | /AFB       |                                       |
| 9            |               | BFB        |                                       |
| 10           | Output        | /BFB       |                                       |
| 11           |               | ZFB        |                                       |
| 12           |               | /ZFB       |                                       |
| 13           |               | GND        |                                       |
| 14           | Ground        | GND        | () ,                                  |
| Shell        | Shield        | Shield     |                                       |
|              |               | Officia    | . •                                   |
| PIO connecto | r (NPN)       |            |                                       |
| Pin Number C | locaification | Signal     |                                       |
| 1 /          |               | 24V        |                                       |
| ZA F         | ower Supply   | 24V<br>24V | 1                                     |
| 3A           |               | Not used   |                                       |
| 4A           |               | Not used   | :                                     |
| 5A           |               | SON        |                                       |
| 6A           | -             | RES        |                                       |
| 7A           |               | HOME       |                                       |
| 8A           |               | TL         |                                       |
| 9A           | Input         | CSTP       |                                       |
| 10A          |               | DCLR       |                                       |
| 11A          |               | BKRL       |                                       |
| 12A          |               | RMOD       |                                       |
| 13A~20A      |               | Not used   | · · · · · ·                           |
| 1B           |               | PWR        |                                       |
| 2B           |               | SV         |                                       |
| 3B           |               | INP        |                                       |
| 4B           | ŀ             | HEND       | · · · · · · · · · · · · · · · · · · · |
| 5B           | ŀ             | TLR        |                                       |
| 6B           |               | *ALM       |                                       |
| 7B           | Output        | *EMGS      |                                       |
| 8B           |               | RMDS       | · · · · · · · · · · · · · · · · · · · |
| 9B           | j             | ALM1       | <del></del>                           |
| 10B          |               | ALM2       |                                       |
| 11B          | İ             | ALM4       |                                       |
| 12B          | l             | ALM8       |                                       |
| 13B          | l             |            | -                                     |
| 14B          | ļ             | _          | ·                                     |
| 15B          |               | ZONE1      | <del></del>                           |
| 16B          | İ             | ZONE2      |                                       |
| 17B~18B      | _             | Not used   | · · · · · · · · · · · · · · · · · · · |
| 19B -        | ower Supply   | OV         | DC24V±                                |
|              |               |            |                                       |

<sup>\*</sup>The shield on the twisted pair cable connected to the pulse connector must be connected to the shell.
Also, the cable length must not be longer than 10m.
\*Connect 24V between pins 1A and 2A, and 0V between pins 19B and 20B.

# I/O Signal Table \*Choose from 7 types of signal allocation

|          |                |                     | Parameter Selections (PIO Patterns) Pulse |               |                |                | Pulse Train Mode      |                       |                 |
|----------|----------------|---------------------|---|---------------|----------------|----------------|-----------------------|-----------------------|-----------------|
|          |                |                     | 0   | 1             | 2              | 3              | 4                     | 5                     | 0               |
| Pin      |                |                     | Positioning Mode                          | Teaching Mode | 256-point Mode | 512-point Mode | Solenoid Valve Mode 1 | Solenoid Valve Mode 2 |                 |
| Number   | Classification | Number of Positions | 64 points                                 | 64 points     | 256 points     | 512 points     | 7 points              | 3 points              | -               |
| Humber   |                | Zone Signal         | 0   | ×             | ×              | ×              | 0                     | 0                     | ×               |
|          |                | P-zone Signal       | 0   | 0             | 0              | ×              | 0                     | 0                     | ×               |
| 1A       | 24V            |                     |   |               | P2             | 24             |                       |                       | P24             |
| 2A       | 24V            |                     |   |               | P2             | 24             |                       |                       | P24             |
| 3A       | -              |                     |   |               | N              | С              |                       |                       | NC              |
| 4A       | -              |                     |   |               | N              | С              |                       |                       | NC              |
| 5A       |                | IN0                 | PC1                                       | PC1           | PC1            | PC1            | ST0                   | ST0                   | SON             |
| 6A       |                | IN1                 | PC2                                       | PC2           | PC2            | PC2            | ST1                   | ST1 (JOG+)            | RES             |
| 7A       |                | IN2                 | PC4                                       | PC4           | PC4            | PC4            | ST2                   | ST2 (-)               | HOME            |
| 8A       |                | IN3                 | PC8                                       | PC8           | PC8            | PC8            | ST3                   | -                     | TL              |
| 9A       |                | IN4                 | PC16                                      | PC16          | PC16           | PC16           | ST4                   | -                     | CSTP            |
| 10A      |                | IN5                 | PC32                                      | PC32          | PC32           | PC32           | ST5                   | -                     | DCLR            |
| 11A      |                | IN6                 | -   | MODE          | PC64           | PC64           | ST6                   | -                     | BKRL            |
| 12A      | Input          | IN7                 | -   | JISL          | PC128          | PC128          | -                     | -                     | RMOD            |
| 13A      | put            | IN8                 | -   | JOG+          | -              | PC256          | -                     | -                     | -               |
| 14A      |                | IN9                 | BKRL                                      | JOG-          | BKRL           | BKRL           | BKRL                  | BKRL                  | -               |
| 15A      |                | IN10                | RMOD                                      | RMOD          | RMOD           | RMOD           | RMOD                  | RMOD                  | -               |
| 16A      |                | IN11                | HOME                                      | HOME          | HOME           | HOME           | HOME                  | -                     | -               |
| 17A      |                | IN12                | * STP                                     | * STP         | * STP          | * STP          | * STP                 | -                     | -               |
| 18A      | 1              | IN13                | CSTR                                      | CSTR/PWRT     | CSTR           | CSTR           | -                     | -                     | -               |
| 19A      |                | IN14                | RES                                       | RES           | RES            | RES            | RES                   | RES                   | -               |
| 20A      |                | IN15                | SON                                       | SON           | SON            | SON            | SON                   | SON                   | -               |
| 1B       | -              | OUT0                | PM1                                       | PM1           | PM1            | PM1            | PE0                   | LSO                   | PWR             |
| 2B       | -              | OUT1                | PM2                                       | PM2           | PM2            | PM2            | PE1                   | LS1 (TRQS)            | SV              |
| 3B       | -              | OUT2                | PM4                                       | PM4           | PM4            | PM4            | PE2                   | LS2                   | INP             |
| 4B       |                | OUT3<br>OUT4        | PM8                                       | PM8           | PM8            | PM8            | PE3                   | =                     | HEND            |
| 5B<br>6B | -              | OUT5                | PM16                                      | PM16          | PM16           | PM16           | PE4                   |                       | TLR<br>* ALM    |
| 6B<br>7B | -              | OUT6                | PM32<br>MOVE                              | PM32<br>MOVE  | PM32<br>PM64   | PM32           | PE5<br>PE6            | <del>-</del>          | * ALM<br>* EMGS |
| 7B<br>8B | -              | OUT7                | ZONE1                                     | MOVE          | PM64<br>PM128  | PM64<br>PM128  | ZONE1                 | ZONE1                 | RMDS            |
| 9B       | Output         | OUT8                | PZONE                                     | PZONE         | PZONE          | PM128<br>PM256 | PZONE                 | PZONE                 | ALM1            |
| 10B      | -              | OUT9                | RMDS                                      | RMDS          | RMDS           | RMDS           | RMDS                  | RMDS                  | ALM1            |
| 11B      |                | OUT10               | HEND                                      | HEND          | HEND           | HEND           | HEND                  | HEND                  | ALM4            |
| 12B      | -              | OUT11               | PEND                                      | PEND/WEND     | PEND           | PEND           | PEND                  | HEND -                | ALM8            |
| 13B      | 1              | OUT12               | SV  | SV SV         | SV             | SV             | SV                    | SV                    | ALIVIO          |
| 14B      | 1              | OUT12               | * EMGS                                    | * EMGS        | * EMGS         | * EMGS         | * EMGS                | * EMGS                | _               |
| 15B      | -              | OUT14               | * ALM                                     | * ALM         | * ALM          | * ALM          | * ALM                 | * ALM                 | ZONE1           |
| 16B      | 7              | OUT15               | * BALM                                    | * BALM        | * BALM         | * BALM         | * BALM                | * BALM                | ZONE2           |
| 17B      | -              | 00113               | DALIVI                                    | DALIVI        | DALIVI         |                | I DALIN               | DALIN                 | ZONEZ           |
| 18B      | _              |                     |   |               | _              |                |                       |                       | _               |
| 19B      | OV             |                     |   |               | N              |                |                       |                       | N               |
| 20B      | OV             |                     |   |               | N              |                |                       |                       | N               |

<sup>\*</sup> The names of signals above, the values enclosed in () are functions before homing is performed.
\* The signals with an asterisk are normally ON, and OFF during operation.

551




# Pulse Train Type I/O Specifications (differential line driver specifications)

#### ■ Input Section

Max. No. of : Line-driver interface: 500kpps


Input Pulses Open collector interface: 200kpps (AK-04 required)

Isolation method : Photocoupler




#### Output Section

Output method: Line-driver output Isolation : Not isolated



# Pulse Train Ttype I/O Specifications (open collector specifications)



- \* Use the DC24V power supply connected to AK-04 to also supply power to the PIO interface.
- \* Make sure the cable between the pulse output unit (PLC) and AK-04 is as short as possible. Also, the cable between AK-04 and the pulse connector should be 2m or shorter.

# **Command Pulse Input State**

| Co         | mmand Pulse Train Shapes | Input terminals                 | Forward  | Reverse                            |
|------------|--------------------------|---------------------------------|--|------------------------------------|
|            | Forward pulse train      | PP, /PP                         |  |                                    |
|            | Reverse pulse train      | NP, /NP                         |  |                                    |
| <u>د</u> . | The forward pulse train  | controls the amount of forward  | motor rotation; the reverse pulse train contro | ols the same in reverse direction. |
| Logic      | Pulse train              | PP, /PP                         |  |                                    |
| Negative   | Sign                     | NP, /NP                         | Low  | High                               |
| ega        | The command p            | oulse controls the amount of mo | tor rotation, and the command sign controls    | the direction of rotation.         |
| Ž          | A/R phase pulse train    | PP, /PP                         |  |                                    |
|            | A/B phase pulse train    | NP, /NP                         |  |                                    |
|            | A (frequency-quadru      | pled) A/B phase pulse with a 90 | ° phase difference is used to control the amo  | ount and direction of rotation.    |
|            | Forward pulse train      | PP, /PP                         |  |                                    |
| ogic       | Reverse pulse train      | NP, /NP                         |  |                                    |
| _          | Pulse train              | PP, /PP                         |  |                                    |
| ositive    | Sign                     | NP, /NP                         | High   | Low                                |
| Po         | A/D whose mules twein    | PP, /PP                         |  |                                    |
|            | A/B phase pulse train    | NP, /NP                         |  |                                    |

**552** 



Integrated

Rod

Fype

Mini

Standard

Controllers
Integrated

PMEC /AMEC PSEP /ASEP ROBO NET PCON ACON SCON PSEL

| Controller Controller                 |   |  |  |  |  |
|---------------------------------------|---|--|--|--|--|
| Table of specifications               | 5   |  |  |  |  |
| Item                                  | Consider  |  |  |  |  |
|                                       | Specific  | 400W or more   |  |  |  |
| Motor Capacity                        | Less than 400W  | 10011 01 111010  |  |  |  |
| Connected actuator                    | RCS2 series actuator / single a   |  |  |  |  |
| Number of control axes                | 1-a   |  |  |  |  |
| Operating method                      | Positioner type /   |  |  |  |  |
| Positioning Points                    | 512 p   |  |  |  |  |
| Backup memory                         | EEPI  |  |  |  |  |
| I/O connector                         | 40 pin co   |  |  |  |  |
| Number of I/O                         | 16 input points /   | • •  |  |  |  |
| I/O power                             | External suppl  | ,  |  |  |  |
| Serial Communication                  | RS485   |  |  |  |  |
| Field Network                         | Device Net, CC  | ,  |  |  |  |
| Peripheral device communication cable | CB-PAC-F  |  |  |  |  |
| Command pulse train input method      | Differential line driver method / open collector method   | I (converted to differential with the pulse converter *1)  |  |  |  |
| Max. input pulse frequency            | Differential line driver method: up to 500 kpps / open c  | Differential line driver method: up to 500 kpps / open collector method (using pulse converter): up to 200kpps |  |  |  |
| Position detection method             | Incremental encoder   | r / Absolute encoder   |  |  |  |
| Emergency stop function               | Y (integra  | ted relay)   |  |  |  |
| Electromagnetic brake forced release  | Brake release s   | switch ON/OFF  |  |  |  |
| Input Voltage                         | Single-phase AC90V to AC126.5V<br>Single-phase AC180V to AC253V   | Single-phase AC180V to AC253V  |  |  |  |
| Power Supply Capacity                 | 20W / 74VA 30W / 94VA<br>60W / 186VA 100W / 282VA<br>150W / 376VA 200W / 469VA  | 400W ∕ 844VA<br>600W ∕ 1212VA<br>750W ∕ 1569VA   |  |  |  |
| Dielectric strength voltage           | DC500V 10   | DMΩ or more  |  |  |  |
| Vibration resistance                  | XYZ directions 10 to 57Hz, One side amplitude: 0.035mm (continuous), 0.075mm (intermittent) 58 to 150 Hz 4.9 m/s² (continuous), 9.8 m/s² (intermittent) |  |  |  |  |
| Ambient operating temperature         | 0~4   | 0°C  |  |  |  |
| Ambient operating humidity            | 10 - 95% (non-condensing)   |  |  |  |  |
| Ambient operating atmosphere          | Without corrosive gases   |  |  |  |  |
| Protection class                      | IP20  |  |  |  |  |
| Weight                                | Approximately 800g (plus 25g for the absolute specifications)   | Approximately 1.1kg (plus 25g for absolute specifications  |  |  |  |
| External dimension                    | 58mm(W)×194mm(H)×121mm(D)   | 72mm(W)×194mm(H)×121mm(D)  |  |  |  |

(Note 1) For the command-pulse input method, use the differential line driver method offering higher noise resistance.


If the open collector method must be used, convert the pulse to differential using the optional pulse converter (AK-04).


**553** scon




Mini
Standard
Controllers
Integrated
Floor
Mini
Standard
Controllers
Integrated
Type
Mini
Standard
Controllers
Integrated
Table/Arm
/FlatType
Linear Servo
Type
Cleanroom
Type
Controllers
PMEC
/AMEC
PSEP
/ASEP
ROBO
NET
ERC2
PCON
ACON
SCON
PSEL
ASEL
XSEL


# External dimensions






# Name of Each Part







# 1 LED display

These LED colors indicate the condition of the controller.

| Name | Color  | Explanation  |  |
|------|--------|--|--|
| PWR  | Green  | Lit when the system is ready (after power is ON, CPU normal functions) |  |
| SV   | Green  | Lit when servo is ON   |  |
| ALM  | Orange | Lit during an alarm  |  |
| EMG  | Red    | Lit during an emergency stop   |  |

#### 2 Rotary switch

This is the address setting switch for identifying each controller when they are linked.

# 3 Piano switch

Controller system switch.

| Name | Explanation   |  |  |  |  |
|------|---|--|--|--|--|
| 1    | Operating mode switch OFF: positioner mode ON: pulse train control mode *Enabled at power ON.   |  |  |  |  |
| 2    | Remote update switch (normally set to OFF) OFF: normal operating mode ON: update mode *Enabled when power is ON or during soft reset. |  |  |  |  |

# 4 System I/O connector

Connector for the emergency stop switch etc.

#### 5 Regeneration unit connector

Connector for resistance unit that absorbs regeneration current produced when the actuator decelerates to a stop.

#### 6 Motor connector (X-SEL, ECON, RCS compatible)

Actuator motor cable connector.

#### 7 Power supply connector

AC power connector. Divided into the control power input and motor power input.

#### 8 Grounding screw

Protective grounding screw. Always ground this screw.

#### 9 Pulse train control connector

This connector is used during pulse train control mode operations. It is disconnected during operations in positioner mode.

#### 10 PIO connector

Connector for the cable for parallel communications with the PLC and other peripheral devices.

# 11 Operating mode switch

| Name | Explanation                 |  |
|------|-----------------------------|--|
| MANU | Do not receive PIO commands |  |
| AUTO | Accept PIO commands         |  |

\*The emergency stop switch on the teaching pendant becomes effective when the line is connected, regardless of whether this switch is set to AUTO or MANU. Take note that an emergency stop will be actuated momentarily when the teaching-pendant or SIO communication cable is disconnected. This is a normal phenomenon and does not indicate an error.

#### 12 SIO connector

Connector for the teaching pendant or PC communications

#### 13 Brake release switch

This is the electromagnetic brake forced release switch, integrated with the actuator.

\*It is necessary to connect the DC 24V power for the brake

#### 14 Brake power connector

Brake power DC 24V supply connector (only required when the brake equipped actuator is connected)

#### 15 Encoder sensor connector (X-SEL-P/Q compatible)

Encoder sensor cable connector

#### 16 Absolute battery connector

Connector for the absolute data backup battery. (Required only for absolute encoder specifications)

## 17 Absolute battery holder

Battery holder for installing the absolute data backup

Controllers

PMEC
/AMEC
PSEP
/ASEP
ROBO
NET
ERC2

PCON
ACON
SCON
PSEL
ASEL

(200V)

**554** 

#### Option

Model HK-1

ontrollers
integrated

Flod
Type

Mini

Standard

Controllers
Integrated

Table/Ac
/FlatTy

Min

PMEC /AMEC PSEP /ASEP ROBO NET ERC2 PCON ACON SCON ASEL

# **Teaching Pendant**


This is a teaching device that provides Features information on functions such as position input, test runs, and monitoring

CON-PT-M-ENG (Touch panel teaching pendant) Model

CON-T-ENG (Standard type)

Model STR-1

RCM-E-ENG (Simple teaching pendant)



CON-PT-M-ENG


| ■ Specifications                |   |                                   |                                   |  |  |
|---------------------------------|---|-----------------------------------|-----------------------------------|--|--|
| Item                            | CON-PT-M-ENG                            | CON-T-ENG                         | RCM-E-ENG                         |  |  |
| Data input                      | 0                                       | 0                                 | 0                                 |  |  |
| Actuator motion                 | 0                                       | 0                                 | 0                                 |  |  |
| Ambient operating temp/humidity | Temp: 0~40°C; Humidity: 85% RH or below |                                   |                                   |  |  |
| Ambient operating atmosphere    | No corrosive gases. Especially no dust. |                                   |                                   |  |  |
| Protection class                | IP40                                    | IP54                              | _                                 |  |  |
| Weight                          | Approx. 750g                            | Approx. 400g                      | Approx. 400g                      |  |  |
| Cable length                    | 5m                                      |                                   |                                   |  |  |
| Display                         | 3-color LED touch panel with backlight  | 20 char × 4 lines<br>LCD .display | 16 char. × 2 lines<br>LCD display |  |  |

CON-T-ENG


# PC Software (Windows Only)

Features A startup support software for inputting positions, performing test runs, and monitoring. With enhancements for adjustment functions, the startup time is shortened.

■ Model RCM-101-MW (External device communications cable + RS232 conversion unit)



■ Model RCM-101-USB (External device communications cable + USB adapter + USB cable)



RCM-E-ENG

#### ■ Regenerative Resistance Unit

A unit that returns the regenerative current, generated during the acceleration/deceleration of the motor, into heat. In the tables below, check the total power output of the actuator to see if a regenerative resistor is needed. Features

REU-2 (for SCON/SSEL) Model

# ■ Specifications


Actuator weight 0.9kg Internal regenerative resistance 220Ω 80W Actuator-Controller CB-SC-REU010 (for SSEL) Connection Cable (included)


| Requi   | red Number o | of Units |   | Required   | d Number of Un | its (RCS2-RA1 | 3R only) |
|---------|--------------|----------|---|------------|----------------|---------------|----------|
|         | Horizontal   | Vertical |   |            | 2.5 lead       | 1.25 lead     |          |
| 0 units | ~100W        | ~100W    |   | Horizontal | 1 unit         | 0 units       |          |
| 1 unit  | 400W         | 400W     | 1 | Vertical   | 4              | 4             |          |

2 units ~750W \* Depending on the operating conditions, more regenerative resistor may be needed. ~750W Depending on the operating conditions,
more regenerative resistor may be needed.

If two regenerative units are needed, acquire one REU-2 and one REU-1

(See P596).






data, when operating an actuator with an absolute encoder.

AB-5 Model



**555** scon



~ ⊙

ন ⊙

Plug: 10114-3000PE (Sumitomo 3M) Shell: 10314-52F0-008 (Sumitomo 3M

scon **556** 

0

0

Shield

(200V)






#### List of models

Program controller for operating RCP3 / RCP2 Series actuators. Various control functions are combined into a single unit.


| Туре                           | C   |  |
|--------------------------------|---|--|
| Name                           | Program mode  | Positioner Mode  |
| External View                  |   |  |
| Description                    | Both the actuator operation and communication with external equipment can be handled by a single controller. When two axes are connected, arc interpolation, path operations, and synchronization can be performed. | Up to 1500 positioning points are supported. Push-motion operation and teaching operation are also possible. |
| Position points                | 1500  | points   |
| Maximum number of control axes |   | 2  |

#### Model









Slider

Mini

Standard

Integrate

Mini

Standard

Integrated

Table/Arm /Flat Type

Mini

Standard

Rotary Type

Cleanroom

Splash-Proof

Controllers

PMEC /AMEC

ROBO NET

PCON

ACON

SCON

ASEL

SSEL

XSEL

Pulse Moto

Servo Moto (24V)

> Servo Motor 200V)

Linear Servo Moto

# I/O Specifications


#### ■ Input section External input specifications


| •                |                    |                        |
|------------------|--------------------|------------------------|
| Item             | Specifications     |                        |
| Input voltage    | DC24V ±10%         |                        |
| Input current    | 7mA / circuit      |                        |
| ON/OFF voltage   | ON voltage (min.)  | NPN: DC16V / PNP: DC8V |
| ON/OFF Vollage   | OFF voltage (max.) | NPN: DC5V / PNP: DC19V |
| Isolation method | Photocoupler       |                        |


| NPN Specifications                                 |
|--|
| External power supply +24V Input terminals R=3.3kΩ |

# ■ Output section External output specifications

| Item                    | Specifications                            |
|-------------------------|---|
| Load Voltage            | DC24V                                     |
| Max. load current       | 100mA / 1 point 400mA / 8 points in total |
| Residual voltage (Max.) | Max 0.1mA / 1 point                       |
| Isolation method        | Photocoupler                              |







# **Explanation of I/O Signal Functions**

Two modes can be selected for the SSEL controller: "Program Mode," in which the actuator is operated by entering a program, and "Positioner Mode," in which PLC signals are received and the actuator is moved to designated positions.

The Positioner Mode has the five input patterns listed below to enable various applications.

# ■ Control Function by Type

| Operation       | on mode                    | Features   |
|-----------------|----------------------------|--|
| Prograi         | n mode                     | Various operations including linear/arc interpolation operation, path operation ideal for coating processes, etc., archmotion operation and palletizing operation can be performed using the Super SEL language that lets you program complex control actions using simple commands. |
|                 | Standard mode              | This is the basic mode from which operations can be conducted by designating position numbers and inputting the start signal.  Push-motion operation and teaching operation are also possible.   |
|                 | Product Change<br>mode     | Multiple work parts of the same shape with slightly different hole positions can be handled using movement commands to the same position numbers by simply changing the product type number.   |
| Positioner mode | 2-axis independent mode    | With a 2-axis controller, each axis can be commanded and operated separately.  |
|                 | Teaching mode              | In this mode, the slider (rod) moves based on an external signal, when the actuator is stopped, the current location can be registered as position data.   |
|                 | DS-S-C1<br>Compatible mode | If you were using a DS-S-C1 controller, you can replace it with a PSEL controller without having to change the host programs. *This mode does not ensure actuator compatibility.   |





# Program mode

| Pin Number | Classification | Port No.   | Program Mode           | Functions  | Wiring Diagram  |
|------------|----------------|------------|------------------------|--|-----------------|
| 1A         | P24            |            | 24V input              | Connect 24V.   |                 |
| 1B         |                | 016        | Select Program No. 1   |  | •••             |
| 2A         | ] [            | 017        | Select Program No. 2   |  |                 |
| 2B         | ] [            | 018        | Select Program No. 4   | Selects the program number to start.   | •••             |
| 3A         | ] [            | 019        | Select Program No. 8   | (Input as BCD values to ports 016 to 022)                                    | •••             |
| 3B         |                | 020        | Select Program No. 10  | (input as BCD values to ports 016 to 022)                                    | •••             |
| 4A         |                | 021        | Select Program No. 20  |  | •••             |
| 4B         |                | 022        | Select Program No. 40  |  | •••             |
| 5A         |                | 023        | CPU reset              | Resets the system to the same state as when the power is turned on.          | •••             |
| 5B         |                | 000        | Start                  | Starts the program selected by ports 016 to 022.                             | •••             |
| 6A         |                | 001<br>002 | General-purpose input  |  | •               |
| 6B         |                |            | General-purpose input  |  | •••             |
| 7A         | Input          | 003        | General-purpose input  |  | •••             |
| 7B         | ] Input        | 004        | General-purpose input  |  | •••             |
| 8A         |                | 005        | General-purpose input  |  | •••             |
| 8B         |                | 006        | General-purpose input  |  | •••             |
| 9A         |                | 007        | General-purpose input  |  | •••             |
| 9B         |                | 800        | General-purpose input  | Waits for external input via program instructions.                           | •••             |
| 10A        |                | 009        | General-purpose input  |  | •               |
| 10B        |                | 010        | General-purpose input  |  | •••             |
| 11A        |                | 011        | General-purpose input  |  | •••             |
| 11B        |                | 012        | General-purpose input  |  | •••             |
| 12A        |                | 013        | General-purpose input  |  | •••             |
| 12B        |                | 014        | General-purpose input  |  | •••             |
| 13A        |                | 015        | General-purpose input  |  |                 |
| 13B        |                | 300        | Alarm                  | Turns off when an alarm occurs. (Contact B)                                  | -5 <del>-</del> |
| 14A        | ] [            | 301        | Ready                  | Turns on when the controller starts up normally and is in an operable state. |                 |
| 14B        | ] [            | 302        | General-purpose output |  |                 |
| 15A        | Output         | 303        | General-purpose output |  |                 |
| 15B        | Output         | 304        | General-purpose output | These outputs can be turned ON/OFF as desired via program instructions.      |                 |
| 16A        |                | 305        | General-purpose output | mese outputs can be turned ON/OFF as desired via program instructions.       |                 |
| 16B        | ] [            | 306        | General-purpose output |  |                 |
| 17A        |                | 307        | General-purpose output |  |                 |
| 17B        | N              | /          | 0V input               | Connect 0V.  |                 |

# Positioner mode

| n Number C | Classification | Port No. | Positioner<br>Standard Mode | Functions   | Wiring Diagram              |
|------------|----------------|----------|-----------------------------|---|-----------------------------|
| 1A         | P24            |          | 24V input                   | Connect 24V.  |                             |
| 1B         |                | 016      | Position input 10           |   | <b></b>                     |
| 2A         |                | 017      | Position input 11           | Specifies the position numbers to move to, using port number 007 to 019.                      |                             |
| 2B         |                | 018      | Position input 12           | The number can be specified either as BCD or binary.  | <b></b>                     |
| 3A         |                | 019      | Position input 13           |   |                             |
| 3B         |                | 020      |                             | -   | <b></b>                     |
| 4A         |                | 021      | -                           | -   |                             |
| 4B         |                | 022      | -                           | -   |                             |
| 5A         | 0:<br>0:       | 023      | Error reset                 | Resets minor errors. (Severe errors require a restart.)                                       | <b></b>                     |
| 5B         |                | 000      | Start                       | Starts moving to selected position.   | <b></b>                     |
| 6A         |                | 001      | Home return                 | Performs home return.   | <b></b>                     |
| 6B         |                | 002      | Servo ON                    | Switches between Servo ON and OFF.  | <b></b>                     |
| 7A         |                | 003      | Push                        | Performs a push motion.   |                             |
| 7B         | Input          | 004      | Pause                       | Pauses the motion when turned OFF, and resumes when turned ON.                                | <b></b>                     |
| 8A         |                | 005      | Cancel                      | Stops the motion when turned OFF. The remaining motion is canceled.                           |                             |
| 8B         |                | 006      | Interpolation settings      | When this signal is turned ON for a 2-axis model, the actuator moves by linear interpolation. | <b></b>                     |
| 9A         |                | 007      | Position input 1            |   | <b></b>                     |
| 9B         |                | 800      | Position input 2            |   | <b></b>                     |
| 10A        |                | 009      | Position input 3            | Specifies the position numbers to move to, using ports 007 to 019.                            |                             |
| 10B        |                | 010      | Position input 4            | The number can be specified either as BCD or binary.  | <b></b>                     |
| 11A        |                | 011      | Position input 5            | The number can be specified either as BOD or billary.   |                             |
| 11B        |                | 012      | Position input 6            |   | <b></b>                     |
| 12A        |                | 013      | Position input 7            |   |                             |
| 12B        |                | 014      | Position input 8            |   | -                           |
| 13A        |                | 015      | Position input 9            |   |                             |
| 13B        |                | 300      | Alarm                       | Turns off when an alarm occurs. (Contact B)   | <b>-</b> ₹₹                 |
| 14A        | L              | 301      | Ready                       | Turns on when the controller starts up normally and is in an operable state.                  |                             |
| 14B        |                | 302      | Positioning complete        | Turns on when the movement to the destination is complete.                                    |                             |
| 15A        | Output         | 303      | Home return complete        | Turns on when the home return operation is complete.  |                             |
| 15B        | Juipui         | 304      | Servo ON output             | Turns on when servo is ON.  | <b>-</b> ₹\$ <del>-</del> - |
| 16A        |                | 305      | Pushing complete            | Turns on when a push motion is complete.  | <b></b>                     |
| 16B        |                | 306      | System battery error        | Turns on when the system battery runs low (warning level).                                    | -FO+                        |
| 17A        |                | 307      | -                           | -   | <b></b>                     |
| 17B        | N              |          | 0V input                    | Connect 0V.   |                             |

PSEL **560** 



Stider
Type

Mini
Standard
Controllers
Integrated

Rod
Type

Mini
Standard
Controllers
Integrated

Mini
Standard
Controllers
Integrated

Table/Arm
/Flat Type

Mini
Standard
Gripper/
Rotary Type

# Positioner, Product-Type Change Mode

| Pin Number | Classification | Port No. | Positioner Product<br>Type Change Mode | Functions   | Wiring Diagram       |  |
|------------|----------------|----------|--|---|----------------------|--|
| 1A         | P24            |          | 24V input                              | Connect 24V.  |                      |  |
| 1B         |                | 016      | Position/Product Type Input 10         |   |                      |  |
| 2A         |                | Γ        | 017 Position/Product Type Input        | Position/Product Type Input 11  | 0                    |  |
| 2B         | 1 [            | 018      | Position/Product Type Input 12         | Specifies the position numbers to move to, and the product type numbers,  | <b>—•</b>            |  |
| 3A         | 1 [            | 019      | Position/Product Type Input 13         | using ports 007 to 022.   |                      |  |
| 3B         |                | 020      | Position/Product Type Input 14         | The position and product type numbers are assigned by parameter settings.   | <b>—•</b>            |  |
| 4A         |                | 021      | Position/Product Type Input 15         | The number can be specified either as BCD or binary.  |                      |  |
| 4B         | 1 1            | 022      | Position/Product Type Input 16         |   |                      |  |
| 5A         | 1 [            | 023      | Error reset                            | Resets minor errors. (Severe errors require a restart.)   |                      |  |
| 5B         | ]              | 000      | Start                                  | Starts moving to selected position.   |                      |  |
| 6A         |                | 001      | Home return                            | Performs home return.   |                      |  |
| 6B         | ] [            | 002      | Servo ON                               | Switches between Servo ON and OFF.  |                      |  |
| 7A         | Input 003 004  | 003      | Push                                   | Performs a push motion.   |                      |  |
| 7B         |                | 004      | Pause                                  | Pauses the motion when turned OFF, and resumes when turned ON.  | <b>—•</b>            |  |
| 8A         | ] [            | 005      | Cancel                                 | Stops the motion when turned OFF. The remaining motion is canceled.   |                      |  |
| 8B         | ] [            | 006      | Interpolation settings                 | When this signal is turned ON for a 2-axis model, the actuator moves by linear interpolation.   | <b></b>              |  |
| 9A         | ] [            | 007      | Position/Product Type Input 1          |   |                      |  |
| 9B         |                | 800      | Position/Product Type Input 2          | •   | <b></b>              |  |
| 10A        | ] [            | 009      | Position/Product Type Input 3          | Specifica the position numbers to make to and the product time numbers  |                      |  |
| 10B        | ] [            | 010      | Position/Product Type Input 4          | Specifies the position numbers to move to, and the product type numbers, using ports 007 to 022.  The position and product type numbers are assigned by parameter settings. |                      |  |
| 11A        | ] [            | 011      | Position/Product Type Input 5          |   |                      |  |
| 11B        |                | 012      | Position/Product Type Input 6          |   |                      |  |
| 12A        | ] [            | 013      | Position/Product Type Input 7          | The number can be specified either as BCD or binary.  |                      |  |
| 12B        |                | 014      | Position/Product Type Input 8          |   |                      |  |
| 13A        |                | 015      | Position/Product Type Input 9          |   |                      |  |
| 13B        | ]              | 300      | Alarm                                  | Turns off when an alarm occurs. (Contact B)   | <b>→</b> ♥♥ <b>→</b> |  |
| 14A        | ] [            | 301      | Ready                                  | Turns on when the controller starts up normally and is in an operable state.  |                      |  |
| 14B        | ] [            | 302      | Positioning complete                   | Turns on when the movement to the destination is complete.  | <b>→</b> ♥♥          |  |
| 15A        | Output         | 303      | Home return complete                   | Turns on when the home return operation is complete.  | <b>-</b> _           |  |
| 15B        |                | 304      | Servo ON output                        | Turns on when servo is ON.  |                      |  |
| 16A        |                | 305      | Pushing complete                       | Turns on when a push motion is complete.  | <b>-</b> 5           |  |
| 16B        |                | 306      | System battery error                   | Turns on when the system battery runs low (warning level).  | <b>→</b> 55 <b>→</b> |  |
| 17A        |                | 307      | -                                      | =   | <b></b>              |  |
| 17B        | N              |          | 0V input                               | Connect 0V.   |                      |  |

# Positioner, 2-axis Independent Mode

| n Number | Classification | Port No. | Positioner 2-axis<br>Independent Mode | Functions   | Wiring Diagram |
|----------|----------------|----------|---------------------------------------|---|----------------|
| 1A       | P24            |          | 24V input                             | Connect 24V.  |                |
| 1B       |                | 016      | Position input 7                      |   | <b></b>        |
| 2A       |                | 017      | Position input 8                      | Specifies the position numbers to move to, using ports 010 to 022.                |                |
| 2B       |                | 018      | Position input 9                      | The position numbers on the 1st and 2nd axes are assigned by                      | <b></b>        |
| ЗА       |                | 019      | Position input 10                     | parameter settings.   |                |
| 3B       |                | 020      | Position input 11                     | The number can be specified either as BCD or binary.                              | <b></b>        |
| 4A       |                | 021      | Position input 12                     |   |                |
| 4B       |                | 022      | Position input 13                     |   | <b></b>        |
| 5A       |                | 023      | Error reset                           | Resets minor errors. (Severe errors require a restart.)                           |                |
| 5B       |                | 000      | Start 1                               | Starts the movement to the selected position number on the 1st axis.              |                |
| 6A       |                | 001      | Home return 1                         | Performs home return on the 1st axis.   |                |
| 6B       |                | 002      | Servo ON 1                            | Switches between servo ON and OFF for the 1st axis.                               | <b>—•</b>      |
| 7A       | Input          | 003      | Pause 1                               | Pauses the motion on 1st axis when turned OFF, and resumes when turned ON.        |                |
| 7B       | Input          | 004      | Cancel 1                              | Cancels the movement on the 1st axis.   | <b></b>        |
| 8A       |                | 005      | Start 2                               | Starts the movement to the selected position number on the 2nd axis.              | <b></b>        |
| 8B       |                | 006      | Home return 2                         | Performs home return on the 2nd axis.   |                |
| 9A       |                | 007      | Servo ON 2                            | Switches between servo ON and OFF for the 2nd axis.                               | <b></b>        |
| 9B       |                | 800      | Pause 2                               | Pauses the motion on 2nd axis when turned OFF, and resumes when turned ON.        | <b></b>        |
| 10A      |                | 009      | Cancel 2                              | Cancels the movement on the 2nd axis.   |                |
| 10B      |                | 010      | Position input 1                      | Specifies the position numbers to move to, using ports 010 to 022.                | <b>—•</b>      |
| 11A      |                | 011      | Position input 2                      | The position numbers on the 1st and 2nd axes are assigned by                      |                |
| 11B      |                | 012      | Position input 3                      | parameter settings.   | <b></b>        |
| 12A      | [              | 013      | Position input 4                      | The number can be specified either as BCD or binary.                              | •••            |
| 12B      | [              | 014      | Position input 5                      | The number can be specified either as bob of billary.                             | •••            |
| 13A      |                | 015      | Position input 6                      |   |                |
| 13B      |                | 300      | Alarm                                 | Turns off when an alarm occurs. (Contact B)                                       |                |
| 14A      |                | 301      | Ready                                 | Turns on when the controller starts up normally and is in an operable state.      |                |
| 14B      |                | 302      | Positioning complete 1                | Turns on when the movement to the specified position on the 1st axis is complete. |                |
| 15A      | Output         | 303      | Home return complete 1                | Turns on when home return on the 1st axis is complete.                            |                |
| 15B      | Output         | 304      | Servo ON output 1                     | Turns on when the 1st axis is in a servo ON state.                                |                |
| 16A      |                | 305      | Positioning complete 2                | Turns on when the movement to the specified position on the 2nd axis is complete  |                |
| 16B      |                | 306      | Home return complete 2                | Turns on when home return on the 2nd axis is complete.                            | <b>-</b> ₽₽    |
| 17A      |                | 307      | Servo ON output 2                     | Turns on when the 2nd axis is in a servo ON state.                                | <b></b>        |
| 17B      | N              |          | 0V input                              | Connect 0V.   |                |

**561** PSEL



Silder Type

Mini
Standard

Controllers Integrated

Rod Type

Mini
Standard

Controllers Integrated

Table/Arm //Flat Type

Mini
Standard

Cripper/
Mini
Standard

Cripper/
Mini
Standard

Cripper/
Flat Type

Cleanroom Type

Controllers

PMEC //AMEG
PSEP //ASEP
ROBO NET

ERC2

PCON

ACON

SCON

PSEL

ASEL

SSEL

XSEL

# Positioner, Teaching Mode

| in Number | Classification | Port No. | Positioner<br>Teaching Mode | Functions   | Wiring Diagram       |
|-----------|----------------|----------|-----------------------------|---|----------------------|
| 1A        | P24            |          | 24V input                   | Connect 24V.  |                      |
| 1B        |                | 016      | JOG- on 1st axis            | While the signal is on, the 1st axis is moved in the - (negative) direction.  |                      |
| 2A        |                | 017      | JOG+ on 2nd axis            | While the signal is on, the 2nd axis is moved in the + (positive) direction.  |                      |
| 2B        |                | 018      | JOG- on 2nd axis            | While the signal is on, the 2nd axis is moved in the - (negative) direction.  | <b>—</b> •           |
| 3A        |                | 019      | Specify inching (0.01mm)    |   |                      |
| 3B        |                | 020      | Specify inching (0.1mm)     | Specifies how much to move during inching.  | <b></b>              |
| 4A        |                | 021      | Specify inching (0.5mm)     | (Total of the values specified for ports 019 to 022)  |                      |
| 4B        |                | 022      | Specify inching (1mm)       |   | <b></b>              |
| 5A        |                | 023      | Error reset                 | Resets minor errors. (Severe errors require a restart.)   |                      |
| 5B        |                | 000      | Start                       | Starts moving to selected position.   |                      |
| 6A        | ] [            | 001      | Servo ON                    | Switches between Servo ON and OFF.  |                      |
| 6B        |                | 002      | Pause                       | Pauses the motion when turned OFF, and resumes when turned ON.  | -                    |
| 7A        | Input          | 003      | Position input 1            |   |                      |
| 7B        |                | 004      | Position input 2            | -   |                      |
| 8A        |                | 005      | Position input 3            |   |                      |
| 8B        |                | 006      | Position input 4            | Parts 003 to 013 are used to enecify the nacition number to make and  | <b></b>              |
| 9A        |                | 007      | Position input 5            | Ports 003 to 013 are used to specify the position number to move, and   |                      |
| 9B        |                | 800      | Position input 6            | the position number for inputting the current position.  - When the teaching mode setting on port 014 is in the ON state, the | <b></b>              |
| 10A       |                | 009      | Position input 7            | current value is written to the specified position number.  |                      |
| 10B       |                | 010      | Position input 8            | current value is written to the specified position number.  | <b></b>              |
| 11A       |                | 011      | Position input 9            |   |                      |
| 11B       |                | 012      | Position input 10           | -   |                      |
| 12A       |                | 013      | Position input 11           |   | <b></b>              |
| 12B       |                | 014      | Teaching mode setting       |   | <b></b>              |
| 13A       |                | 015      | JOG+ on 1st axis            | While the signal is on, the 1st axis is moved in the + (positive) direction.  | ~                    |
| 13B       |                | 300      | Alarm                       | Turns off when an alarm occurs. (Contact B)   | <b>─•</b> ○ <b>•</b> |
| 14A       | ]              | 301      | Ready                       | Turns on when the controller starts up normally and is in an operable state.  |                      |
| 14B       | ] [            | 302      | Positioning complete        | Turns on when the movement to the destination is complete.  | <b>→</b> 55 <b>→</b> |
| 15A       | Output         | 303      | Home return complete        | Turns on when the home return operation is complete.  |                      |
| 15B       | Output         | 304      | Servo ON output             | Turns on when servo is ON.  |                      |
| 16A       | ] [            | 305      | -                           | _   |                      |
| 16B       |                | 306      | System battery error        | Turns on when the system battery runs low (warning level).  | <b>→</b> ₹₹          |
| 17A       |                | 307      | -                           | _   | <b></b>              |
| 17B       | N              |          | 0V input                    | Connect 0V.   |                      |

# Positioner, DS-S-C1 Compatible Mode

| Pin Number | Classification | Port No.      | Positioner<br>DS-S-C1<br>Compatible Mode | Functions   | Wiring Diagram |
|------------|----------------|---------------|--|---|----------------|
| 1A         | P24            | $\overline{}$ | 24V input                                | Connect 24V.  |                |
| 1B         |                | 016           | Position No. 1000                        | (Same as ports 004 through 015)   |                |
| 2A         |                | 017           | -  |   |                |
| 2B         |                | 018           | -  | =   |                |
| 3A         |                | 019           | -  | -   |                |
| 3B         |                | 020           | -  | -   | •••            |
| 4A         |                | 021           | -  | -   | <b>-</b> _     |
| 4B         |                | 022           | -  | -   |                |
| 5A         |                | 023           | CPU reset                                | Resets the system to the same state as when the power is turned on.                           | <b></b>        |
| 5B         |                | 000           | Start                                    | Starts moving to selected position.   |                |
| 6A         |                | 001           | Hold (Pause)                             | Pauses the motion when turned ON, and resumes when turned OFF.                                |                |
| 6B         | Input 00       | 002           | Cancel                                   | Stops the motion when turned ON. The remaining motion is canceled.                            |                |
| 7A         |                | 003           | Interpolation settings                   | When this signal is turned ON for a 2-axis model, the actuator moves by linear interpolation. |                |
| 7B         |                | 004           | Position No. 1                           |   |                |
| 8A         |                | 005           | Position No. 2                           |   |                |
| 8B         |                | 006           | Position No. 4                           |   | <b></b>        |
| 9A         |                | 007           | Position No. 8                           |   |                |
| 9B         |                | 800           | Position No. 10                          | Ports 004 through 016 are used to specify the position number to move.                        |                |
| 10A        |                | 009           | Position No. 20                          | The numbers are specified as BCD.   |                |
| 10B        |                | 010           | Position No. 40                          | The numbers are specified as BCD.   |                |
| 11A        |                | 011           | Position No. 80                          |   |                |
| 11B        |                | 012           | Position No. 100                         |   | •••            |
| 12A        |                | 013           | Position No. 200                         |   |                |
| 12B        |                | 014           | Position No. 400                         |   | •              |
| 13A        |                | 015           | Position No. 800                         |   |                |
| 13B        |                | 300           | Alarm                                    | Turns off when an alarm occurs. (Contact A)   | - <del></del>  |
| 14A        |                | 301           | Ready                                    | Turns on when the controller starts up normally and is in an operable state.                  |                |
| 14B        |                | 302           | Positioning complete                     | Turns on when the movement to the destination is complete.                                    | <del>_</del>   |
| 15A        | Output         | 303           | -  | -   |                |
| 15B        | Output         | 304           | =  | -   |                |
| 16A        |                | 305           | -  | -   | <b>───────</b> |
| 16B        |                | 306           | System battery error                     | Turns on when the system battery runs low (warning level).                                    | -FO-           |
| 17A        |                | 307           | -  | =   | <b></b>        |
| 17B        | N              |               | 0V input                                 | Connect 0V.   |                |

PSEL **562** 



PMEC /AMEC PSEP /ASEP ROBO NET PCON ACON PSEL ASEL SSEL































# Table of specifications

|                           | Item   | Specifications  |  |  |
|---------------------------|--|---|--|--|
| ations                    | Connected actuator   | RCP2 series actuator (Note 1)   |  |  |
|                           | Input voltage  | DC24V ±10%  |  |  |
|                           | Power Supply Capacity  | Control power (Max. 1.2A) + Motor power (See the table below)   |  |  |
| e<br>E                    | Dielectric strength voltage  | DC500V 10MΩ or higher   |  |  |
| Basic Specifications      | Withstand voltage  | AC500V 1 min.   |  |  |
|                           | Rush current   | Max. 30A  |  |  |
|                           | Vibration resistance   | XYZ directions 10 to 57Hz, One side amplitude: 0.035mm (continuous), 0.075mm (intermittent) 58 to 150 Hz 4.9 m/s² (continuous), 9.8 m/s² (intermittent) |  |  |
| _                         | Maximum total output of connected axis   | -   |  |  |
| o sti                     | Position detection method  | Incremental encoder   |  |  |
| Control                   | Speed setting  | From 1mm/s. The maximum limit varies depending on the actuator.   |  |  |
| Control<br>specification  | Acceleration setting   | From 0.01G. The maximum limit varies depending on the actuator.   |  |  |
|                           | Operating method   | Program operation / Positioner operation (switchable)   |  |  |
|                           | Programming language   | Super SEL language  |  |  |
|                           | Number of programs   | 64 programs   |  |  |
| Ē                         | Number of program steps  | 2000 steps  |  |  |
| Program                   | Number of multi-tasking programs   | 8 programs  |  |  |
| Pro                       | Positioning Points   | 1500 points   |  |  |
|                           | Data memory device   | FLASHROM (A system-memory backup battery can be added as an option)   |  |  |
|                           | Data input method  | Teaching pendant or PC software   |  |  |
|                           | Number of I/O  | 24 input points / 8 output points (NPN or PNP selectable)   |  |  |
| 6                         | I/O power  | Externally supplied 24VDC ± 10%   |  |  |
| Sati                      | PIO cable  | CB-DS-PIO □□□ (supplied with the controller)  |  |  |
| Communication             | Serial communications function   | RS232C (Half-pitch connector) / USB connector   |  |  |
| Ē                         | Field Network  | DeviceNet, CC-Link, ProfiBus  |  |  |
| Ö                         | Motor Cable  | CB-RCP2-MA □ □ □ (Max. 20m)   |  |  |
|                           | Encoder cable  | CB-RCP2-PA 🗆 (Max. 20m)   |  |  |
| General<br>specifications | Protection function  | Motor driver temperature check, Encoder open-circuit check Soft limit over, system error, battery error, etc.   |  |  |
|                           | Ambient operating humidity and temperature   | 0 to 40°C 10 to 95% (non-condensing)  |  |  |
|                           | Ambient atmosphere   | Free from corrosive gases. In particular, there shall be no significant powder dust.  |  |  |
|                           | Protection class   | IP20  |  |  |
| ŝ                         | Weight   | Approx. 450g  |  |  |
|                           | External dimension   | 43 mm (W) x 159 mm (H) x 110 mm (D)   |  |  |
| A1 . 4                    | ) Company or surface High Throught was (MATON) High Consult was (HORO/HORD) are Without was (MORO/HORD). |   |  |  |

(Note 1) Cannot operate High-Thrust type (RA10C), High-Speed type (HS8C/HS8R), or Waterproof type (RCP2W-SA16).


|                    |                      | 1-Axis specifications |              | 2-Axis specifications |              |
|--------------------|----------------------|-----------------------|--------------|-----------------------|--------------|
| Motorpower         | Motor type           | Rated                 | Max.(Note 3) | Rated                 | Max.(Note 3) |
| supply<br>Capacity | 20P, 28P, 28SP motor | 0.4A                  | 2.0A         | 0.8A                  | 4.0A         |
| (Note2)            | 35P, 42P, 56SP motor | 1.2A                  |              | 2.4A                  | 4.04         |


(Note 2) For both 1-axis and 2-axis specifications, approx. 30A inrush current flows for 5 ms when the control power supply is turned on.

(Note 3) After Servo ON, excitation detection is performed. In that case, the current is maximized. (Approx. 100 msec)

However, if motor drive power supply is turned on after a shut-down, approx. 6.0A and approx. 12.0A current flows to axis-1 and axis-2 respectively. (Approx. 1 to 2 msec)


# Exterior dimensions








#### Name of Each Part





#### 1 Motor connector for axis 1

Connects the motor cable of the axis 1 actuator.

#### 2 Motor connector for axis 2

Connects the motor cable of the axis 2 actuator.

#### 3 Brake switch for axis 1

This switch is used to release the axis brake. Setting it to the left position (RLS side) forcibly releases the brake, while setting it to the right position (NOM side) causes the controller to automatically control the brake.

#### 4 Encoder connector for axis 1

Connect the encoder cable of the axis 1 actuator.

#### 5 Brake switch for axis 2

This switch is used to release the axis brake. Setting it to the left position (RLS side) forcibly releases the brake. while setting it to the right position (NOM side) causes the controller to automatically control the brake.

#### 6 Encoder connector for axis 2

Connect the encoder cable of the axis 2 actuator.

#### 7 Status indicator LEDs

These LEDs are used to indicate the operating condition of the controller.

The LED status indicators are as follows:

Power is input to controller.

RDY The controller is ready to perform program

operation.

SV1

The controller is abnormal. **EMG** 

An emergency stop is actuated and the drive source is cut off.

: The axis 1 actuator servo is on.

SV2 : The axis 2 actuator servo is on.

#### 8 Panel unit connector

A connector for the panel unit (optional) that displays the controller status and error codes.

#### 9 I/O Connector

A connector for interface I/Os.

34-pin flat cable connector for DIO (24IN/8OUT) interface.

I/O power is also supplied to the controller via this connector (Pin No. 1 and No. 34).

#### 10 Mode switch

This switch is used to specify the running mode of the controller. The left position indicates the MANU (manual operation) mode, while the right position indicates the AUTO (automatic operation) mode. Teaching can only be performed in manual operation, and automatic operation using external I/Os is not possible in the MANU mode.

#### 11 USB connector

A connector for PC connection via USB. If the USB connector is connected, the TP connector is disabled and all communication inputs to the TP connector are cut off.

#### 12 Teaching pendant connector

A half-pitch I/O 26-pin connector that connects a teaching pendant when the running mode is MANU. A special conversion cable is needed to connect a conventional D-sub, 25-pin connector.

#### 13 System-memory backup battery connector

If you wish to retain the various data recorded in the SRAM of the controller even after the power is cut off, connect the necessary battery to this connector. This battery is installed externally to the unit. The controller does not come standard with the battery (Option).

#### 14 Motor power input connector

This connector is used to input the motor power. It consists of a 2-pin, 2-piece connector by Phoenix Contact.

#### 15 Control power/System input connector

This connector is used to connect the control power input, emergency stop switch, and enable switch. It consists of a Phoenix Contact 6-pin 2-piece connector.

Mini
Standard
Controllers
integrated
Rod
Type
Mini
Standard
Controllers
integrated
Table/Arm
Flat Type
Mini

Splash-Proof

Controllers

PMEC /AMEC

PSEP /ASEP

ROBO NET

ERC2

PCON

ACON

SCON

PSEL

ASEL



#### Option

# ■Teaching Pendant


Features This is a teaching device that provides information on functions such as position input, test runs, and monitoring.

Model

Mini
Standard
Controllers
Integrated
Rocc
Type
Mini
Standard
Controllers
Integrated
Table/Arm
/Flat Type
Mini
Standard

| Model    | Description                                      |
|----------|--|
| SEL-T-J  | Standard type with adapter cable                 |
| SEL-TD-J | Equipped with a deadman switch and adapter cable |

Configuration




■ SEL-T option

• Wall-mounting hook • Strap

Model HK-1 Model STR-1





Specifications


| Item                                | SEL-T-J                           | SEL-TD-J  |  |
|-------------------------------------|-----------------------------------|-----------|--|
| 3-position Enable Switch            | No                                | Yes       |  |
| ANSI/UL standards                   | Non-compliant                     | Compliant |  |
| CE mark                             | Compliant                         |           |  |
| Display                             | 20 char. × 4 lines                |           |  |
| Ambient Operating<br>Temp./Humidity | 0~40°C 10~90% RH (non-condensing) |           |  |
| Protective structure                | IP54                              |           |  |
| Weight                              | Approx. 0.4kg (not incl. cable)   |           |  |

#### **■PC Software (Windows Only)**

Features A startup support software for inputting programs/positions, performing test runs, and monitoring. More functions have been added for debugging, and improvements have been made to shorten the start-up time.


■ Model IA-101-X-MW-J (with RS232C cable + adapter cable)

■ Configuration





■ Model IA-101-X-USB (with USB cable)



# Pulse Motor

PMEC
/AMEC
PSEP
/ASEP
ROBO
NET
ERC2
PCON


Servo Motor

Linea Servo Moto

# Panel Unit

■ Features Display device that shows the error code from the controller or the currently running program number.

■ Model PU-1 (Cable length: 3m)



# System Memory Backup Battery

■ Features This battery is required when you are using global flags in the program and you want to retain your data even after the power has been turned OFF.

■ Model AB-5-CS (with case)
AB-5 (stand-alone battery)



#### **Dummy Plug**

■ Features

When connecting the PSEL controller to a computer with a USB cable, this plug is inserted in the teaching port to shut off the enable circuit.

(Supplied with the PC software IA-101-X-USB)

■ Model DP-3



#### Option

#### **USB** Cable

■ Features

A cable for connecting the controller to the USB port to a computer. A controller with no USB port (e.g. XSEL) can be connected to the USB port of a computer by connecting an R5232C cable to the USB cable via a USB adapter. ee PC software IA-101-X-USBMW)

■ Model CB-SEL-USB030 (Cable length: 3m)



#### Adapter Cable

■ Features


An adapter cable to connect the D-sub 25-pin connector from the teaching pendant or a PC to the teaching connector (half-pitch) of the PSEL controller.


■ Model CB-SEL-SJ002 (Cable length: 0.2m)




#### **Spare Parts**

When you need spare parts after purchasing the product, such as when replacing a cable, refer to the list of models below.









# I/O Flat Cable

CB-DS-PIO Model

> No connector Flat cable AWG28 (34-core)

\* Enter the cable length (L) into \( \subseteq \subseteq \). Compatible to a maximum of 10 meters. Ex.: 080 = 8 m

Gray 2

PSEL **566** 



Controllers

PMEC
/AMEC
/AMEC
PSEP
/ASEP
/ASEP
ROBO
NET
ERC2
PCON
ACON
SCON
PSEL
ASEL






# List of models

Program controller for operating RCA2/RCA Series actuators. One unit can handle various controls.

| Туре                   | С  |  |  |
|------------------------|--|--|--|
| Name                   | Program mode   | Positioner Mode  |  |
| External view          |  |  |  |
| Description            | Both the actuator operation and communication with external equipment can be handled by a single controller.  When two axes are connected, arc interpolation, path operations, and synchronization can be performed. | Up to 1500 positioning points are supported. Push-motion operation and teaching operation are also possible. |  |
| Position points        | 1500 points  |  |  |
| Number of control axes | Up to 2 axes   |  |  |

# Model



**567** ASEL





Controllers

PMEC /AMEC

PSEP /ASEP

ROBO NET |

ERC2

PCON

ACON |


SCON

PSEL

XSEL

XSEL

# System configuration



Controllers

PMEC
/AMEC
PSEP
/ASEP

ROBO
NET

ERC2

PCON

ACON

SCON

ASEL **568** 



#### I/O Specifications


#### ■ Input section External input specifications


| Item             | Specifications                            |
|------------------|---|
| Input voltage    | DC24V ±10%                                |
| Input current    | 7mA / circuit                             |
| ON/OFF voltage   | ON voltage (min.) NPN: DC16V / PNP: DC8V  |
| ON/OFF voilage   | OFF voltage (max.) NPN: DC5V / PNP: DC19V |
| Isolation method | Photocoupler                              |


| NPN Specifications                                       |
|--|
| External power supply +24V Input terminal Inputs R=3.3kΩ |

#### ■ Output section External output specifications

| Item                    | Specifications                            |
|-------------------------|---|
| Load Voltage            | DC24V                                     |
| Max. load current       | 100mA / 1 point 400mA / 8 points in total |
| Residual voltage (Max.) | Max 0.1mA / 1 point                       |
| Isolation method        | Photocoupler                              |







#### Explanation of I/O Signal Functions

Two modes can be selected for the ASEL controller: "Program Mode," in which the actuator is operated by entering a program, and "Positioner Mode," in which PLC signals are received and the actuator is moved to designated positions. The Positioner Mode has the five input patterns listed below to enable various applications.

#### ■ Control Function by Type

| Operation       | on mode                    | Features   |
|-----------------|----------------------------|--|
| Progra          | m mode                     | Various operations including linear/arc interpolation operation, path operation ideal for coating processes, etc., archmotion operation and palletizing operation can be performed using the Super SEL language that lets you program complex control actions using simple commands. |
|                 | Standard mode              | This is the basic mode from which operations can be conducted by designating position numbers and inputting the start signal.  Push-motion operation and teaching operation are also possible.   |
|                 | Product Change<br>mode     | Multiple parts of the same shape with slightly different hole positions can be handled using movement commands to the same position numbers by simply changing the product type number.  |
| Positioner mode | 2-axis independent mode    | With a 2-axis controller, each axis can be commanded and operated separately.  |
|                 | Teaching mode              | In this mode, the slider (rod) moves based on an external signal, when the actuator is stopped, the current location can be registered as position data.   |
|                 | DS-S-C1<br>Compatible mode | If you were using a DS-S-C1 controller, you can replace it with a ASEL controller without having to change the host programs. *This mode does not ensure actuator compatibility.   |

**569** ASEL



PMEC JAMEC
PSEP JASEP
ROBO NET JERC2
PCON ACON
SCON
PSEL
ASEL
XSEL

Mini
Standard
Controllers
Integrated
Mini
Standard
Controllers
Integrated
Table/Arm
/Flat Type
Mini
Standard



#### Program mode

| Pin Number | Category | Port No. | Program Mode           | Functions   | Wiring Diagram |
|------------|----------|----------|------------------------|---|----------------|
| 1A         | P24      |          | 24V input              | Connect 24V.  |                |
| 1B         |          | 016      | Select Program No. 1   |   | •              |
| 2A         | 1 1      | 017      | Select Program No. 2   |   | -              |
| 2B         | 1 1      | 018      | Select Program No. 4   |   | •              |
| 3A         | i i      | 019      | Select Program No. 8   | Selects the program number to start.  | •              |
| 3B         | 1 1      | 020      | Select Program No. 10  | (Input as BCD values to ports 016 to 022)                                   | •••            |
| 4A         | 1 1      | 021      | Select Program No. 20  |   | •••            |
| 4B         | 1 1      | 022      | Select Program No. 40  |   | •••            |
| 5A         | 1 [      | 023      | CPU reset              | Resets the system to the same state as when the power is turned on.         | • •            |
| 5B         | 1 1      | 000      | Start                  | Starts the program selected by ports 016 to 022.                            | •••            |
| 6A         | 1 [      | 001      | General-purpose input  |   | •••            |
| 6B         | 1 [      | 002      | General-purpose input  |   | •••            |
| 7A         | l [      | 003      | General-purpose input  |   | •••            |
| 7B         | Input    | 004      | General-purpose input  |   | •              |
| 8A         |          | 005      | General-purpose input  |   | •••            |
| 8B         |          | 006      | General-purpose input  | Waits for external input via program instructions.                          | •••            |
| 9A         |          | 007      | General-purpose input  |   | •••            |
| 9B         | ] [      | 800      | General-purpose input  |   | •••            |
| 10A        | ] [      | 009      | General-purpose input  |   | •••            |
| 10B        | ] [      | 010      | General-purpose input  |   | •••            |
| 11A        | ] [      | 011      | General-purpose input  |   | •••            |
| 11B        | ] [      | 012      | General-purpose input  |   | •••            |
| 12A        | ] [      | 013      | General-purpose input  |   | •••            |
| 12B        | 1 [      | 014      | General-purpose input  |   | •              |
| 13A        |          | 015      | General-purpose input  |   | ~              |
| 13B        |          | 300      | Alarm                  | Turns off when an alarm occurs. (Contact B)                                 | - F            |
| 14A        | ] [      | 301      | Ready                  | Turns on when the controller starts up normally and is in an operable state |                |
| 14B        | ] [      | 302      | General-purpose output |   |                |
| 15A        | Output   | 303      | General-purpose output |   |                |
| 15B        | Juiput   | 304      | General-purpose output | These outputs can be turned ON/OFF as desired via program instructions.     |                |
| 16A        | ] [      | 305      | General-purpose output | These outputs can be turned on/or as desired via program instructions.      | • • •          |
| 16B        | ] [      | 306      | General-purpose output |   |                |
| 17A        |          | 307      | General-purpose output |   |                |
| 17B        | N        |          | 0V input               | Connect 0V.   | <b>•</b>       |

#### Positioner mode

| Number | Category      | Port No. | Positioner<br>Standard Mode   | Functions  | Wiring Diagram       |
|--------|---------------|----------|---|--|----------------------|
| 1A     | P24           |          | 24V input   | Connect 24V.   |                      |
| 1B     |               | 016      | Position input 10   |  | <b></b>              |
| 2A     | [             | 017      | Position input 11   | Specifies the position numbers to move to, using port number 007 to 019  |                      |
| 2B     | Ī             | 018      | Position input 12   | The number can be specified either as BCD or binary.   | <b></b>              |
| 3A     | [             | 019      | Position input 13   |  |                      |
| 3B     | [             | 020      | -   | -  | <b></b>              |
| 4A     | [             | 021      | -   | -  | <b></b>              |
| 4B     | ſ             | 022      | -   | -  | <b></b>              |
| 5A     |               | 023      | Error reset   | Resets minor errors. (Severe errors require a restart.)  |                      |
| 5B     | [             | 000      | Start   | Starts moving to the selected position.  | <b></b>              |
| 6A     | [             | 001      | Home Return   | Performs Home Return.  |                      |
| 6B     | [             | 002      | Servo ON  | Switches between Servo ON and OFF.   | <b></b>              |
| 7A     | Input 003 004 | Push     | Performs a push motion.   |  |                      |
| 7B     |               | Pause    | Pauses the motion when turned OFF, and resumes motion when turned ON. | <b></b>  |                      |
| 8A     | [             | 005      | Cancel  | Stops the motion when turned OFF. The remaining motion is canceled.  | <b></b>              |
| 8B     | [             | 006      | Interpolation settings  | When this signal turned ON for a 2-axis model, the actuator moves by linear interpolation.                               | •••                  |
| 9A     |               | 007      | Position input 1  |  |                      |
| 9B     | [             | 800      | Position input 2  |  | <b>—</b>             |
| 10A    | [             | 009      | Position input 3  | 0  | <b></b>              |
| 10B    | [             | 010      | Position input 4  | Specifies the position numbers to move to, using ports 007 to 019.  The number can be specified either as BCD or binary. | <b></b>              |
| 11A    |               | 011      | Position input 5  | The number can be specified either as BOD or billary.  |                      |
| 11B    | [             | 012      | Position input 6  |  | <b></b>              |
| 12A    |               | 013      | Position input 7  |  | <b></b>              |
| 12B    |               | 014      | Position input 8  |  | <b>—</b>             |
| 13A    |               | 015      | Position input 9  |  |                      |
| 13B    |               | 300      | Alarm   | Turns off when an alarm occurs. (Contact B)  | •O•                  |
| 14A    | Į             | 301      | Ready   | Turns on when the controller starts up normally and is in an operable state.   |                      |
| 14B    |               | 302      | Positioning complete  | Turns on when the movement to the destination is complete.   | <b>→</b> ○ <b>→</b>  |
| 15A    | Output        | 303      | Home Return complete  | Turns on when the home return operation is complete.   |                      |
| 15B    | Output        | 304      | Servo ON output   | Turns on when servo is ON.   | -65 <del>-</del>     |
| 16A    |               | 305      | Pushing complete  | Turns on when a push motion is complete.   |                      |
| 16B    | ļ             | 306      | System battery error  | Turns on when the system battery runs low (warning level).   | <b>→</b> 55 <b>→</b> |
| 17A    |               | 307      | Absolute encoder battery error  | Turns on when the battery for the absolute encoder runs low (warning level).   |                      |
| 17B    | N             |          | 0V input  | Connect 0V.  |                      |

ASEL **570** 



Controllers

PMEC
/AMEC

PSEP
/ASEP

ROBO
NET

ERC2

PCON

ACON

SCON

PSEL

ASEL

# ASEL Controller

Slider Type

Mini
Standard

Controllers Integrated

Rod Type

Mini
Standard

Controllers Integrated

Table/Arm //Flat Type

Mini
Standard

Gripper/
Rotary Type

PMEC JAMEC
PSEP JASEP
ROBO NET
ERG2
PCON
ACON
SCON
PSEL
ASEL
XSEL

#### Explanation of I/O Signal Functions

#### Positioner, Product-Type Change Mode

| Pin Number | Category | Port No. | Positioner<br>Product Type Change Mode | Functions   | Wiring Diagram |
|------------|----------|----------|--|---|----------------|
| 1A         | P24      |          | 24V input                              | Connect 24V.  |                |
| 1B         |          | 016      | Position/Product Type Input 10         |   | <b>—</b>       |
| 2A         | 1        | 017      | Position/Product Type Input 11         | 0 7 11 17 17 17 17 17 17 17 17 17 17 17 1   | •••            |
| 2B         |          | 018      | Position/Product Type Input 12         | Specifies the position numbers to move to, and the product type numbers,  | •••            |
| 3A         | 1        | 019      | Position/Product Type Input 13         | using ports 007 to 022.   | •••            |
| 3B         | 1        | 020      | Position/Product Type Input 14         | The position and product type numbers are assigned by parameter settings.   | •••            |
| 4A         |          | 021      | Position/Product Type Input 15         | The number can be specified either as BCD or binary.  | •••            |
| 4B         | ]        | 022      | Position/Product Type Input 16         |   | <b>—</b>       |
| 5A         |          | 023      | Error reset                            | Resets minor errors. (Severe errors require a restart.)   | <b>—</b>       |
| 5B         |          | 000      | Start                                  | Starts moving to the selected position.   | • •            |
| 6A         | ]        | 001      | Home Return                            | Performs Home Return.   | <b>—</b>       |
| 6B         |          | 002      | Servo ON                               | Switches between Servo ON and OFF.  | • • •          |
| 7A         |          | 003      | Push                                   | Performs a push motion.   | •••            |
| 7B         | Input    | 004      | Pause                                  | Pauses the motion when turned OFF, and resumes motion when turned ON.   | <b>—</b> •••   |
| 8A         |          | 005      | Cancel                                 | Stops the motion when turned OFF. The remaining motion is canceled.   | <b></b>        |
| 8B         |          | 006      | Interpolation settings                 | When this signal is turned ON for a 2-axis model, the actuator moves by linear interpolation.                                   | <b>—</b>       |
| 9A         |          | 007      | Position/Product Type Input 1          |   | <b></b>        |
| 9B         |          | 008      | Position/Product Type Input 2          | Specifies the position numbers to move to, and the product type numbers,  | <b>—</b>       |
| 10A        |          | 009      | Position/Product Type Input 3          |   | •••            |
| 10B        |          | 010      | Position/Product Type Input 4          |   | <b>—</b>       |
| 11A        |          | 011      | Position/Product Type Input 5          | using ports 007 to 022.   | •••            |
| 11B        |          | 012      | Position/Product Type Input 6          | The position and product type numbers are assigned by parameter settings.  The number can be specified either as BCD or binary. | <b>—</b>       |
| 12A        |          | 013      | Position/Product Type Input 7          |   | •••            |
| 12B        | ]        | 014      | Position/Product Type Input 8          |   | •••            |
| 13A        |          | 015      | Position/Product Type Input 9          |   |                |
| 13B        |          | 300      | Alarm                                  | Turns off when an alarm occurs (Contact B)  | F0-            |
| 14A        |          | 301      | Ready                                  | Turns on when the controller starts up normally and is in an operable state.  | F0-            |
| 14B        |          | 302      | Positioning complete                   | Turns on when the movement to the destination is complete.  |                |
| 15A        |          | 303      | Home Return complete                   | Turns on when the home return operation is complete.  | F 5 + 5 + 1    |
| 15B        | Output   | 304      | Servo ON output                        | Turns on when servo is ON.  |                |
| 16A        |          | 305      | Pushing complete                       | Turns on when a push motion is complete.  | F              |
| 16B        |          | 306      | System battery error                   | Turns on when the system battery runs low (warning level).  | <b>-</b>       |
| 17A        |          | 307      | Absolute encoder battery error         | Turns on when the battery for the absolute encoder runs low (warning level).  | <b>──</b>      |
| 17B        | N        | /        | 0V input                               | Connect OV.   | <b>—</b>       |

#### Positioner, 2-axis Independent Mode

| Pin Number | Category                 | Port No.   | Positioner 2-axis<br>Independent Mode   | Functions   | Wiring Diagram                            |
|------------|--------------------------|------------|---|---|---|
| 1A         | P24                      |            | 24V input   | Connect 24V.  |   |
| 1B         |                          | 016        | Position input 7  |   | •••                                       |
| 2A         |                          | 017        | Position input 8  | Specifies the position numbers to move to, using ports 010 to 022.                |   |
| 2B         |                          | 018        | Position input 9  | The position numbers on the 1st and 2nd axes are assigned by                      | <b></b>                                   |
| 3A         |                          | 019        | Position input 10   | parameter settings.   | <b>-</b> _                                |
| 3B         |                          | 020        | Position input 11   | The number can be specified either as BCD or binary.                              | <b></b>                                   |
| 4A         |                          | 021        | Position input 12   |   | <b></b>                                   |
| 4B         |                          | 022        | Position input 13   |   | <b></b>                                   |
| 5A         |                          | 023        | Error reset   | Resets minor errors. (Severe errors require a restart.)                           | <b></b>                                   |
| 5B         | 1                        | 000        | Start 1   | Starts movement to the selected position number on the 1st axis.                  | •••                                       |
| 6A         | 1                        | 001        | Home Return 1   | Performs home return on the 1st axis.   | •••                                       |
| 6B         | 001<br>002<br>003<br>004 | Servo ON 1 | Switches between servo ON and OFF for the 1st axis.                               | •••   |   |
| 7A         |                          | Pause 1    | Pauses the motion on 1st axis when turned OFF, and resumes motion when turned ON. | •••   |   |
| 7B         | Input                    | Input      | Cancel 1  | Cancels the movement on the 1st axis.   | <b></b>                                   |
| 8A         |                          | Start 2    | Starts the movement to the selected position number on the 2nd axis.              | $\longrightarrow \bullet \longrightarrow$   |   |
| 8B         |                          | 006        | Home Return 2   | Performs home return on the 2nd axis.   | <b></b>                                   |
| 9A         |                          | 007        | Servo ON 2  | Switches between servo ON and OFF for the 2nd axis.                               | $\longrightarrow \bullet \longrightarrow$ |
| 9B         |                          | 008        | Pause 2   | Pauses the motion on 2nd axis when turned OFF, and resumes when turned ON.        | $- \bullet$                               |
| 10A        |                          | 009        | Cancel 2  | Cancels the movement on the 2nd axis.   | •••                                       |
| 10B        |                          | 010        | Position input 1  | 0   | $- \bullet +$                             |
| 11A        |                          | 011        | Position input 2  | Specifies the position numbers to move to, using ports 010 to 022.                | •••                                       |
| 11B        |                          | 012        | Position input 3  | The position numbers on the 1st and 2nd axes are assigned by                      | $\longrightarrow \longleftarrow$          |
| 12A        |                          | 013        | Position input 4  | parameter settings.  The number can be specified either as BCD or binary.         | <b></b>                                   |
| 12B        |                          | 014        | Position input 5  | The number can be specified either as BOD or binary.                              | <b></b>                                   |
| 13A        |                          | 015        | Position input 6  |   |   |
| 13B        |                          | 300        | Alarm   | Turns off when an alarm occurs (Contact B)  | - <del>•</del> ••                         |
| 14A        |                          | 301        | Ready   | Turns on when the controller starts up normally and is in an operable state.      |   |
| 14B        |                          | 302        | Positioning complete 1  | Turns on when the movement to the specified position on the 1st axis is complete. |   |
| 15A        | Output 303<br>304        |            | Home Return complete 1  | Turns on when home return on the 1st axis is complete.                            | <del>-</del> 55•                          |
| 15B        |                          |            | Servo ON output 1   | Turns on when the 1st axis is in a servo ON state.                                |   |
| 16A        |                          | 305        | Positioning complete 2  | Turns on when the movement to the specified position on the 2nd axis is complete. |   |
| 16B        |                          | 306        | Home Return complete 2  | Turns on when home return on the 2nd axis is complete.                            |   |
| 17A        |                          | 307        | Servo ON output 2   | Turns on when the 2nd axis is in a servo ON state.                                |   |
| 17B        | N                        |            | 0V input  | Connect 0V.   |   |

**571** ASEL



#### Positioner, Teaching Mode

| n Number | Category | Port No. | Positioner<br>Teaching Mode    | Functions   | Wiring Diagram        |
|----------|----------|----------|--------------------------------|---|-----------------------|
| 1A       | P24      |          | 24V input                      | Connect 24V.  |                       |
| 1B       |          | 016      | JOG- on 1st axis               | While the signal is on, the 1st axis is moved in the - (negative) direction.    | •                     |
| 2A       |          | 017      | JOG+ on 2nd axis               | While the signal is on, the 2nd axis is moved in the + (positive) direction.    | <b>———</b>            |
| 2B       |          | 018      | JOG- on 2nd axis               | While the signal is on, the 2nd axis is moved in the - (negative) direction.    | <b>—</b>              |
| 3A       |          | 019      | Specify inching (0.01mm)       |   | •••                   |
| 3B       |          | 020      | Specify inching (0.1mm)        | Specifies how much to move during inching.                                      |                       |
| 4A       |          | 021      | Specify inching (0.5mm)        | (Total of the values specified for ports 019 to 022)                            |                       |
| 4B       |          | 022      | Specify inching (1mm)          |   | •••                   |
| 5A       |          | 023      | Error reset                    | Resets minor errors. (Severe errors require a restart.)                         | •••                   |
| 5B       |          | 000      | Start                          | Starts moving to selected position.   | •                     |
| 6A       |          | 001      | Servo ON                       | Switches between Servo ON and OFF.  | •                     |
| 6B       |          | 002      | Pause                          | Pauses the motion when turned OFF, and resumes motion when turned ON.           | •                     |
| 7A       | Innut    | 003      | Position input 1               |   | •••                   |
| 7B       | Input    | 004      | Position input 2               |   | •                     |
| 8A       |          | 005      | Position input 3               |   | •••                   |
| 8B       |          | 006      | Position input 4               | Ports 003 to 013 are used to specify the position number to move, and the       | •                     |
| 9A       |          | 007      | Position input 5               | position number for inputting the current position.                             | •••                   |
| 9B       |          | 008      | Position input 6               | position number for inputting the current position.                             | •••                   |
| 10A      |          | 009      | Position input 7               | When the teaching mode setting on port 014 is in the ON state, the current      | •                     |
| 10B      |          | 010      | Position input 8               |   | •                     |
| 11A      |          | 011      | Position input 9               | value is written to the specified position number.                              | •                     |
| 11B      |          | 012      | Position input 10              |   |                       |
| 12A      |          | 013      | Position input 11              |   |                       |
| 12B      |          | 014      | Teaching mode setting          |   | •••                   |
| 13A      |          | 015      | JOG+ on 1st axis               | While the signal is input, the 1st axis is moved in the + (positive) direction. | ~                     |
| 13B      |          | 300      | Alarm                          | Turns off when an alarm occurs. (Contact B)                                     |                       |
| 14A      |          | 301      | Ready                          | Turns on when the controller starts up normally and is in an operable state.    | <del>-</del> 55•      |
| 14B      |          | 302      | Positioning complete           | Turns on when the movement to the destination is complete.                      |                       |
| 15A      | Output   | 303      | Home return complete           | Turns on when the home return operation is complete.                            | <b>-55-</b>           |
| 15B      | Output   | 304      | Servo ON output                | Turns on when servo is ON.  |                       |
| 16A      | 305      |          | -                              |   |                       |
| 16B      |          | 306      | System battery error           | Turns on when the system battery runs low (warning level).                      | <del>-</del> 5        |
| 17A      |          | 307      | Absolute encoder battery error | Turns on when the battery for the absolute encoder runs low (warning level).    | <b></b> -₹ <b>5</b> + |
| 17B      | N        |          | 0V input                       | Connect 0V.   |                       |

#### Positioner, DS-S-C1 Compatible Mode

| Number | Category | Port No. | Positioner DS-S-C1<br>Compatible Mode | Functions   | Wiring Diagram  |
|--------|----------|----------|---------------------------------------|---|-----------------|
| 1A     | P24      |          | 24V input                             | Connect 24V.  |                 |
| 1B     |          | 016      | Position No. 1000                     | (Same as ports 004 through 015)   | ••              |
| 2A     |          | 017      | -                                     | -   | •••             |
| 2B     |          | 018      | -                                     | -   | •••             |
| 3A     |          | 019      | -                                     | -   | •••             |
| 3B     |          | 020      | -                                     | -   | •••             |
| 4A     |          | 021      | -                                     | -   | •••             |
| 4B     |          | 022      | -                                     | =   | •••             |
| 5A     | [        | 023      | CPU reset                             | Resets the system to the same state as when the power is turned on.                           | •••             |
| 5B     |          | 000      | Start                                 | Starts moving to selected position.   | •••             |
| 6A     | [        | 001      | Hold (Pause)                          | Pauses the motion when turned ON, and resumes when turned OFF.                                | • •             |
| 6B     |          | 002      | Cancel                                | Stops the motion when turned ON. The remaining motion is canceled.                            | •••             |
| 7A     | Input    | 003      | Interpolation settings                | When this signal is turned ON for a 2-axis model, the actuator moves by linear interpolation. | •••             |
| 7B     | input    | 004      | Position No. 1                        |   | •••             |
| 8A     |          | 005      | Position No. 2                        |   | •••             |
| 8B     |          | 006      | Position No. 4                        | Ports 004 through 016 are used to specify the position number to move.                        | •••             |
| 9A     |          | 007      | Position No. 8                        |   | •••             |
| 9B     |          | 800      | Position No. 10                       |   | •••             |
| 10A    |          | 009      | Position No. 20                       | The numbers are specified as BCD.   | •••             |
| 10B    |          | 010      | Position No. 40                       | The numbers are specified as BOD.   | •••             |
| 11A    |          | 011      | Position No. 80                       |   | •••             |
| 11B    |          | 012      | Position No. 100                      |   | •••             |
| 12A    | [        | 013      | Position No. 200                      |   |                 |
| 12B    | [        | 014      | Position No. 400                      |   | • •             |
| 13A    |          | 015      | Position No. 800                      |   |                 |
| 13B    |          | 300      | Alarm                                 | Turns off when an alarm occurs. (Contact A)   | ◆ O ◆           |
| 14A    |          | 301      | Ready                                 | Turns on when the controller starts up normally and is in an operable state.                  |                 |
| 14B    |          | 302      | Positioning complete                  | Turns on when the movement to the destination is complete.                                    | -5 <sup>+</sup> |
| 15A    | Output   | 303      | -                                     | =   | - FOT-          |
| 15B    | Jaspat   | 304      | -                                     | -   | -5 <sup>+</sup> |
| 16A    |          | 305      | -                                     | -   | - F             |
| 16B    |          | 306      | System battery error                  | Turns on when the system battery runs low (warning level).                                    | -50             |
| 17A    |          | 307      | Absolute encoder battery error        | Turns on when the battery for the absolute encoder runs low (warning level).                  |                 |
| 17B    | N        |          | 0V input                              | Connect 0V.   | •               |

ASEL **572** 



# ASEL Controller

#### Table of specifications

|                           | Item                                       | Specifications   |  |  |  |  |  |
|---------------------------|--|--|--|--|--|--|--|
|                           | Connected actuator                         | RCA/RCA2 Series Actuator   |  |  |  |  |  |
| LIS I                     |  | DC24V ±10%   |  |  |  |  |  |
| Basic Specifications      | Input Voltage                              | Control power supply (Max. 1.2A) + motor power supply (See the table below)  |  |  |  |  |  |
| <u>2</u>                  | Power Supply Capacity                      |  |  |  |  |  |  |
| eC.                       | Dielectric strength voltage                | DC500V 10MΩ or higher  |  |  |  |  |  |
| Š                         | Withstand voltage                          | AC500V 1 min.  |  |  |  |  |  |
| . <u>c</u>                | Rush current                               | Max. 30A   |  |  |  |  |  |
| Bas                       | Vibration resistance                       | XYZ directions 10 to 57Hz, One side amplitude: 0.035mm (continuous), 0.075mm (intermittent) 58 to 150 Hz 4.9 m/s² (continuous), 9.8 m/s²(intermittent) |  |  |  |  |  |
|                           | Number of control axes                     | 1 axis / 2 axis  |  |  |  |  |  |
| Control<br>specification  | Maximum total output of connected axis     | 60W (30W + 30W)  |  |  |  |  |  |
|                           | Position detection method                  | Incremental encoder / Absolute encoder   |  |  |  |  |  |
| Ę i                       | Speed setting                              | 1mm/sec and up, the maximum depends on actuator specifications   |  |  |  |  |  |
| Col                       | Acceleration setting                       | 0.01G and up, the maximum depends on the actuator  |  |  |  |  |  |
| <del>is</del>             | Operating method                           | Program operation / Positioner operation (switchable)  |  |  |  |  |  |
| m                         | Programming language                       | Super SEL language   |  |  |  |  |  |
|                           | Number of programs                         | 64 programs  |  |  |  |  |  |
|                           | Number of program steps                    | 2000 steps   |  |  |  |  |  |
| Program                   | Number of multi-tasking programs           | 8 points   |  |  |  |  |  |
| ٩                         | Positioning Points                         | 1500 points  |  |  |  |  |  |
|                           | Data memory device                         | FLASHROM (A system-memory backup battery can be added as an option)  |  |  |  |  |  |
|                           | Data input method                          | Teaching pendant or PC software  |  |  |  |  |  |
|                           | Number of I/O                              | 24 input points / 8 output points (NPN or PNP selectable)  |  |  |  |  |  |
| o                         | I/O power                                  | Externally supplied 24VDC ± 10%  |  |  |  |  |  |
| cati                      | PIO cable                                  | CB-DS-PIO □□□ (supplied with the controller)   |  |  |  |  |  |
| Ē                         | Serial communications function             | RS232C (D-Sub Half-pitch connector) / USB connector  |  |  |  |  |  |
| Communication             | Field Network                              | DeviceNet, CC-Link, ProfiBus   |  |  |  |  |  |
| ĕ                         | Motor Cable                                | CB-ACS-MA □ □ □ (Max. 20m)   |  |  |  |  |  |
|                           | Encoder cable                              | CB-ACS-PA □□□ (Max. 20m)   |  |  |  |  |  |
| Su                        | Protection function                        | Motor overcurrent, Motor driver temperature check, Overload check, Encoder open-circuit check<br>Soft limit over, system error, battery error, etc.    |  |  |  |  |  |
| اغ ہے                     | Ambient operating humidity and temperature | 0 to 40°C 10 to 95% (non-condensing)   |  |  |  |  |  |
| ine<br>Fica               | Ambient atmosphere                         | Free from corrosive gases. In particular, there shall be no significant dust.  |  |  |  |  |  |
| General<br>specifications | Protection class                           | IP20   |  |  |  |  |  |
| Spe                       | Weight                                     | Approx. 450g   |  |  |  |  |  |
|                           | External dimensions                        | 43 mm (W) x 159 mm (H) x 110 mm (D)  |  |  |  |  |  |


|                 |             |  | 1-Axis specification  |              |              |              | 2-Axis specification  |              |              |              |
|-----------------|-------------|--|---|--------------|--------------|--------------|---|--------------|--------------|--------------|
|                 | Actuat      | or type  | Standard specifications/high<br>acceleration and deceleration model |              | Power-saving |              | Standard specifications/high<br>acceleration and deceleration model |              | Power-saving |              |
|                 |             |  | Rated   | Max. (Note2) | Rated        | Max. (Note3) | Rated   | Max. (Note2) | Rated        | Max. (Note3) |
|                 | RCA<br>RCA2 | 10W, 20W [Model symbol: 20]                          | 1.3A  | 4.4A         | 1.3A         | 2.5A         | 2.6A  | 8.8A         | 2.6A         | 5.0A         |
| Motor           |             | 30W  | 1.3A  | 4.4A         | 1.3A         | 2.2A         | 2.6A  | 8.8A         | 2.6A         | 4.4A         |
| power<br>supply |             | 20W [Model symbol: 20S] SA4, RA3, TA5 type dedicated | 1.7A  | 5.1A         | 1.7A         | 3.4A         | 3.4A  | 10.2A        | 3.4A         | 6.8A         |
| capacity        |             | 2W   | 0.8A  | 4.6A         | -            | -            | 1.6A  | 9.2A         | -            | -            |
| (Note1)         | RCL         | 5W   | 1.0A  | 6.4A         | ı            | -            | 2.0A  | 12.8A        | -            | -            |
|                 |             | 10W  | 1.3A  | 6.4A         | ı            | -            | 2.6A  | 12.8A        | -            | -            |


(Note 1) For both 1-axis and 2-axis specifications, approx. 30.0A inrush current flows for 5 ms when the control power supply is turned on.

(Note 2) Max. current at accelerating/decelerating

(Note 3) Current reaches the maximum when detecting the servo motor excitation phase at the first servo on after the power is on. (Normal: Approx. 1 to 2 sec., Max.: 10 sec) (Note 4) Other than motor power supply capacity, it increases 0.5A for control power.

#### **External Dimensions**





**573** ASEL




PMEC /AMEC


PSEP /ASEP
/ASEP
ROBO NET
ERG2

PCON
ACON
SCON
PSEL
ASEL

#### Name of Each Part



# 13



#### 1 Motor connector for axis 1

Connect the motor cable of the axis 1 actuator.

#### 2 Motor connector for axis 2

Connect the motor cable of the axis 2 actuator.

#### 3 Brake switch for axis 1

This switch is used to release the axis brake. Setting it to the left position (RLS side) forcibly releases the brake, while setting it to the right position (NOM side) causes the controller to automatically control the brake.

#### 4 Encoder connector for axis 1

Connect the encoder cable of the axis 1 actuator.

#### 5 Brake switch for axis 2

This switch is used to release the axis brake.

Setting it to the left position (RLS side) forcibly releases the brake, while setting it to the right position (NOM side) causes the controller to automatically control the brake.

#### 6 Encoder connector for axis 2

Connect the encoder cable of the axis 2 actuator.

#### 7 Status indicator LEDs

These LEDs are used to indicate the operating condition of the controller.

The LED status indicators are as follows:

PWR : Power is input to controller.

RDY : The controller is ready to perform program

operation.

The controller is abnormal.

EMG An emergency stop is actuated and the drive

source is cut off. The axis 1 actuator servo is on.

SV2 : The axis 2 actuator servo is on.

#### 8 Panel unit connector

A connector for the panel unit (optional) that displays the controller status and error codes.

#### 9 I/O Connector

A connector for interface I/Os.

34-pin flat cable connector for DIO (24IN/8OUT) interface

I/O power is also supplied to the controller via this connector (Pin No. 1 and No. 34).

This switch is used to specify the running mode of the controller. The left position indicates the MANU (manual operation) mode, while the right position indicates the AUTO (automatic operation) mode. Teaching can only be performed in manual operation, and automatic operation using external I/Os is not possible in the MANU mode.

#### 11 USB connector

A connector for PC connection via USB. If the USB connector is connected, the TP connector is disabled and all communication inputs to the TP connector are cut off.

#### 12 Teaching pendant connector

A half-pitch I/O 26-pin connector that connects a teaching pendant when the running mode is MANU. A special conversion cable is needed to connect a conventional Dsub, 25-pin connector.

#### 13 System-memory backup battery connector

If you wish to retain the various data recorded in the SRAM of the controller even after the power is cut off, connect the necessary battery to this connector. This battery is installed externally to the unit. The controller does not come standard with the battery (Option).

#### 14 Motor power input connector

This connector is used to input the motor power. It consists of a 2-pin, 2-piece connector by Phoenix Contact.

#### 15 External regenerative resistor connector

A connector for the regenerative resistor that must be connected when the built-in regenerative resistor alone does not offer sufficient capacity in high-acceleration/ high-load operation, etc.

Whether or not an external regenerative resistor is necessary depends on the conditions of your specific application such as the axis configuration.

#### 16 Control power/System input connector

This connector is used to connect the control power input, emergency stop switch, and enable switch. It consists of a Phoenix Contact 6-pin 2-piece connector.

#### 17 Absolute-data backup battery connector for axis 1

A connector for the battery that backs up absolute data when the actuator uses an absolute encoder. Secure installation of the battery is the customer's responsibility.

#### 18 Absolute-data backup battery connector for axis 2

A connector for the battery that backs up absolute data when the actuator uses an absolute encoder. Secure installation of the battery is the customer's responsibility.

10 Mode switch







































**574** 

# ASEL Controller

#### Option

#### ■ Teaching Pendant


Features This is a teaching device that provides information on functions such as position input, test runs, and monitoring.

Model

| Model    | Description   |
|----------|---|
| SEL-T-J  | Standard type with adapter cable                    |
| SEL-TD-J | Equipped with a deadman<br>switch and adapter cable |

Configuration


Mini
Standard
Controllers
Integrated
Rod
Type
Mini
Standard
Controllers
Integrated
Table/Arm
//Flat Type
Mini
Standard
Gripper
Rodary Typ



SEL-T dedicated options

Model HK-1 Model STR-1





#### Specifications

| Item                                | SEL-T-J                           | SEL-TD-J  |  |  |  |  |
|-------------------------------------|-----------------------------------|-----------|--|--|--|--|
| 3-position Enable Switch            | No                                | Yes       |  |  |  |  |
| ANSI/UL standards                   | Non-compliant                     | Compliant |  |  |  |  |
| CE mark                             | Compliant                         |           |  |  |  |  |
| Display                             | 20 char. × 4 lines                |           |  |  |  |  |
| Ambient Operating<br>Temp./Humidity | 0~40°C 10~90% RH (non-condensing) |           |  |  |  |  |
| Protective structure                | IP54                              |           |  |  |  |  |
| Weight                              | Approx. 0.4kg (not incl. cable)   |           |  |  |  |  |


#### ■PC Software (Windows Only)


Features A startup support software for entering programs/positions, performing test runs, and monitoring. More functions have been added for debugging, and improvements have been made to shorten the start-up time.

IA-101-X-MW-J (with RS232C cable + adapter cable) Model


Configuration

Model





IA-101-X-USB (with USB cable)



Note: Only versions 7.0.0.0 and later can be used with the PSEL controller.


PMEC /AMEC PSEP /ASEP ROBO NET ERC2 PCON ACON SCON PSEL SSEL

#### **Panel Unit**

Model

Display device that shows the error code from the controller or the Features currently running program number.

PU-1 (Cable length: 3m)



#### **Absolute Data Backup Battery**

Battery for saving absolute data, when operating an actuator with an absolute encoder.

Same as the battery used for system ■ Features

memory backup.

AB-5 Model



#### **System Memory Backup Battery**

This battery is required when you are using global flags in the program and you want to retain your data even after the power has been turned OFF. ■ Features

AB-5-CS (with case) Model AB-5 (Standalone battery)



**575** ASEL

#### Option

#### **Dummy Plug**

■ Features

When connecting the ASEL controller to a computer with a USB cable, this plug is inserted in the teaching port to shut off the enable circuit.

(Supplied with the PC software IA-101-X-USB)

DP-3 Model

Model CB-ACS-PA



#### **USB Cable**

Features A cable for connecting the controller to the USB port to a computer.
A controller with no USB port (e.g. XSEL) can be connected to the USB

RS232C cabbe to the USB cable via a USB adapter. (See PC software IA-101-X-USBMW)

CB-SEL-USB030 (Cable length: 3m) Model



#### **Adapter Cable**

Features An adapter cable to connect the D-sub 25-pin connector from the teaching pendant or a PC to the teaching connector (half-pitch) of the ASEL controller.

CB-SEL-SJ002 (Cable length: 0.2m) Model





PSEP /ASEP ROBO NET ERC2
PCON ACON SCON PSEL ASEL


ASEL **576** 




When you need spare parts after purchasing the product, such as when replacing a cable, refer to the list of models below.









sales@electromate.com






#### List of models

Program controller for operating RCS2 Series actuators. One unit can handle various controls.

| Туре                    | С  |   |  |  |  |  |  |
|-------------------------|--|---|--|--|--|--|--|
| Name                    | Program mode Positioner Mode   |   |  |  |  |  |  |
| External View           |  |   |  |  |  |  |  |
| Description             | Both the actuator operation and communication with<br>external equipment can be handled by a single controller.<br>When two axes are connected, arc interpolation, path<br>operations, and synchronization can be performed. | Up to 20000 positioning points are supported. Push-motion operation and teaching operation are also possible. |  |  |  |  |  |
| Position points         | 20000  | points  |  |  |  |  |  |
| Number of control axes: | 2 axes   | s max.  |  |  |  |  |  |

#### Model



**577** SSEL



Type

Mini

Standard

Rod Type

Mini

Controllers Integrated

/Flat Type

Standard

Linear Servo

Cleanroom Type

spiasii-Prooi

Controllers

PSEP /ASEP

NET ERC2

ACON

SCON

ASEL


SSEL

Servo Motor (24V)

Servo Motor (200V)

Linear Servo Motor

#### System configuration



**578** 

PMEC /AMEC PSEP /ASEP ROBO NET ERC2



#### I/O Specifications


#### ■ Input section External input specifications


| Item             | Specifications     |                        |
|------------------|--------------------|------------------------|
| Input voltage    | DC24V ±10%         |                        |
| Input current    | 7mA / circuit      |                        |
| ON/OFF voltage   | ON voltage (min.)  | NPN: DC16V / PNP: DC8V |
|                  | OFF voltage (max.) | NPN: DC5V / PNP: DC19V |
| Isolation method | Photocoupler       |                        |


| NPN Specifications                                       |
|--|
| External power supply +24V Input terminal Inputs R=3.3kΩ |

#### ■ Output section External output specifications

| Item                    | Specifications                            |
|-------------------------|---|
| Load Voltage            | DC24V                                     |
| Max. load current       | 100m A / 1point 400mA / 8 points in total |
| Residual voltage (Max.) | Max 0.1mA / 1 point                       |
| Isolation method        | Photocoupler                              |







#### Explanation of I/O Signal Functions

Two modes can be selected for the SSEL controller: "Program Mode," in which the actuator is operated by entering a program, and "Positioner Mode," in which PLC signals are received and the actuator is moved to designated positions.

The Positioner Mode has the five input patterns listed below to enable various applications.

#### ■ Control Function by Type

| Operation       | on mode                    | Features   |
|-----------------|----------------------------|--|
| Program mode    |                            | Various operations including linear/arc interpolation operation, path operation ideal for coating processes, etc., archmotion operation and palletizing operation can be performed using the Super SEL language that lets you program complex control actions using simple commands. |
|                 | Standard mode              | This is the basic mode from which operations can be conducted by designating position numbers and inputting the start signal.  Push-motion operation and teaching operation are also possible.   |
|                 | Product change mode        | Multiple parts of the same shape with slightly different hole positions can be handled using movement commands to the same position numbers by simply changing the product type number.  |
| Positioner mode | 2-axis independent mode    | With a 2-axis controller, each axis can be commanded and operated separately.  |
|                 | Teaching mode              | In this mode, the slider (rod) moves based on an external signal, when the actuator is stopped, the current position can be registered as position data.   |
|                 | DS-S-C1<br>Compatible mode | If you were using a DS-S-C1 controller, you can replace it with a SSEL controller without having to change the host programs. *This mode does not ensure actuator compatibility.   |

**579** SSEL





Mini
Standard
Controllers
Integrated
Roor
Type
Mini
Standard
Controllers
Integrated
Table/Arm
//Flat Type
Mini
Standard

#### Program mode

| Pin Number | Category | Port No. | Program Mode           | Functions  | Wiring Diagram |
|------------|----------|----------|------------------------|--|----------------|
| 1A         | P24      |          | 24V input              | Connect 24V.   |                |
| 1B         |          | 016      | Select Program No. 1   |  | •              |
| 2A         | 1 1      | 017      | Select Program No. 2   |  | • •            |
| 2B         | 1 1      | 018      | Select Program No. 4   |  | •              |
| 3A         | 1 1      | 019      | Select Program No. 8   | Selects the program number to start.   | • •            |
| 3B         | 1 1      | 020      | Select Program No. 10  | (Input as BCD values to ports 016 to 022)  | •••            |
| 4A         | 1 1      | 021      | Select Program No. 20  |  | • •            |
| 4B         | 1 1      | 022      | Select Program No. 40  |  | •••            |
| 5A         | 1 1      | 023      | CPU reset              | Resets the system to the same state as when the power is turned on.  | • •            |
| 5B         | 1        | 000      | Start                  | Starts the programs selected by ports 016 to 022.  | •              |
| 6A         | 1 1      | 001      | General-purpose input  |  | • •            |
| 6B         | 1        | 002      | General-purpose input  |  | •              |
| 7A         | l [      | 003      | General-purpose input  |  | • •            |
| 7B         | Input    | 004      | General-purpose input  |  | •••            |
| 8A         |          | 005      | General-purpose input  |  | •••            |
| 8B         | 1        | 006      | General-purpose input  |  | •••            |
| 9A         | 1 1      | 007      | General-purpose input  |  | • •            |
| 9B         | 1 1      | 800      | General-purpose input  | Waits for external input via program instructions.   | •••            |
| 10A        | 1 1      | 009      | General-purpose input  |  | • •            |
| 10B        | 1        | 010      | General-purpose input  |  | •              |
| 11A        | ] [      | 011      | General-purpose input  |  | • •            |
| 11B        | 1        | 012      | General-purpose input  |  | •              |
| 12A        | 1 1      | 013      | General-purpose input  |  | • •            |
| 12B        | 1        | 014      | General-purpose input  |  | •••            |
| 13A        | 1 1      | 015      | General-purpose input  |  | • •            |
| 13B        |          | 300      | Alarm                  | Turns off when an alarm occurs. (Contact B)  | •50•           |
| 14A        | ] [      | 301      | Ready                  | Turns on when the controller starts up normally and is in an operable state.   |                |
| 14B        | ]        | 302      | General-purpose output |  | •0•            |
| 15A        |          | 303      | General-purpose output |  |                |
| 15B        | Output   | 304      | General-purpose output | There are the transport ON/OFF are desired the area to be a size of the size o | - D            |
| 16A        | ]        | 305      | General-purpose output | These outputs can be turned ON/OFF as desired via program instructions.  | •0•            |
| 16B        | ]        | 306      | General-purpose output |  |                |
| 17A        |          | 307      | General-purpose output |  | •••            |
| 17B        | N        |          | 0V input               | Connect 0V.  | •              |

#### Positioner mode

| n Number | Category | Port No. | Positioner<br>Standard Mode    | Functions   | Wiring Diagram                                   |
|----------|----------|----------|--------------------------------|---|--|
| 1A       | P24      |          | 24V input                      | Connect 24V.  |  |
| 1B       |          | 016      | Position input 10              |   | <b></b>  |
| 2A       |          | 017      | Position input 11              | Specifies the position numbers to move to, using port number 007 to 019                       |  |
| 2B       |          | 018      | Position input 12              | The number can be specified either as BCD or binary.  | <b></b>  |
| 3A       |          | 019      | Position input 13              |   | <b></b>  |
| 3B       |          | 020      | Position input 14              | -   | <b></b>  |
| 4A       |          | 021      | Position input 15              | -   | <b></b>  |
| 4B       |          | 022      | Position input 16              | -   | •••  |
| 5A       |          | 023      | Error reset                    | Resets minor errors. (Severe errors require a restart.)                                       | <b></b>  |
| 5B       |          | 000      | Start                          | Starts moving to selected position.   | <b></b>  |
| 6A       | Input    | 001      | Home Return                    | Performs home return.   | <b></b>  |
| 6B       |          | 002      | Servo ON                       | Switches between Servo ON and OFF.  | •••  |
| 7A       |          | 003      | Push                           | Performs a push motion.   |  |
| 7B       |          | 004      | Pause                          | Pauses the motion when turned OFF, and resumes motion when turned ON.                         | •••  |
| 8A       |          | 005      | Cancel                         | Stops the motion when turned OFF. The remaining motion is canceled.                           |  |
| 8B       |          | 006      | Interpolation setting          | When this signal is turned ON for a 2-axis model, the actuator moves by linear interpolation. | •••  |
| 9A       |          | 007      | Position input 1               |   |  |
| 9B       |          | 800      | Position input 2               |   | •••  |
| 10A      |          | 009      | Position input 3               | Specifies the position numbers to move to, using ports 007 to 019.                            |  |
| 10B      |          | 010      | Position input 4               | The number can be specified either as BCD or binary.  | <b></b>  |
| 11A      |          | 011      | Position input 5               | The number can be specified either as BOD or binary.  |  |
| 11B      |          | 012      | Position input 6               |   | <b>—</b>   |
| 12A      |          | 013      | Position input 7               |   |  |
| 12B      |          | 014      | Position input 8               |   | •••  |
| 13A      |          | 015      | Position input 9               |   | -D+  |
| 13B      |          | 300      | Alarm                          | Turns off when an alarm occurs. (Contact B)   | <b>→</b> ♥                                       |
| 14A      |          | 301      | Ready                          | Turns on when the controller starts up normally and is in an operable state.                  |  |
| 14B      |          | 302      | Positioning complete           | Turns on when the movement to the destination is complete.                                    | <b>→</b> ♥                                       |
| 15A      | Output   | 303      | Home Return complete           | Turns on when the home return operation is complete.  |  |
| 15B      | Juipui   | 304      | Servo ON output                | Turns on when servo is ON.  | <b>→</b> 55 <b>→</b>                             |
| 16A      |          | 305      | Pushing complete               | Turns on when a push motion is complete.  |  |
| 16B      |          | 306      | System battery error           | Turns on when the system battery runs low (warning level).                                    | <b>→</b> 5 → F → F → F → F → F → F → F → F → F → |
| 17A      |          | 307      | Absolute encoder battery error | Turns on when the battery for the absolute encoder runs low (warning level).                  | <b></b>  |
| 17B      | N        |          | 0V input                       | Connect 0V.   |  |

**580** 



Slider Type

Mini

Standar

Controllers Integrated

Rod Type

Mini

Standard

Controllers Integrated

/Flat Type

Standard

Standard
Gripper/

Linear Servo

Cleanroom Type

Splash-Proof

Controllers

PMEC /AMEC

ROBO NET

ERG2

ACON

PSEL

ASEL

XSEL

Pulse Motor

Servo Motor (24V)

> Servo Motor (200V)

Linear Servo Mot

#### Positioner, Product-Type Change Mode

| Pin Number | Category | Port No.                          | Positioner Product<br>Type Change Mode                                    | Functions  | Wiring Diagram |
|------------|----------|-----------------------------------|---|--|----------------|
| 1A         | P24      |                                   | 24V input   | Connect 24V.   |                |
| 1B         |          | 016                               | Position/Product Type Input 10  |  | •••            |
| 2A         | 1        | 017                               | Position/Product Type Input 11  | Consider the position of the p | •••            |
| 2B         |          | 018                               | Position/Product Type Input 12  | Specifies the position numbers to move to, and the product type numbers, using ports 007 to 022.   | •••            |
| 3A         | ]        | 019                               | Position/Product Type Input 13  |  | 1311           |
| 3B         |          | 020                               | Position/Product Type Input 14  | The position and product type numbers are assigned by parameter  | <b></b>        |
| 4A         |          | 021                               | Position/Product Type Input 15  | settings. The number can be specified either as BCD or binary.   | •••            |
| 4B         |          | 022                               | Position/Product Type Input 16  |  | <b></b>        |
| 5A         |          | 023                               | Error reset   | Resets minor errors. (Severe errors require a restart.)  | •••            |
| 5B         |          | 000                               | Start   | Starts moving to selected position.  | •              |
| 6A         |          | 001                               | Home Return   | Performs home return.  | •••            |
| 6B         |          | 002                               | Servo ON  | Switches between Servo ON and OFF.   | •••            |
| 7A         | Input    | 003                               | Push  | Performs a push motion.  | <b></b>        |
| 7B         | liiput   | 004<br>005<br>006                 | Pause   | Pauses the motion when turned OFF, and resumes motion when turned ON.  | •••            |
| 8A         |          |                                   | Cancel  | Stops the motion when turned OFF. The remaining motion is canceled.  | •••            |
| 8B         |          |                                   | Interpolation setting   | When this signal is turned ON for a 2-axis model, the actuator moves by linear interpolation.  | •••            |
| 9A         |          | 007                               | Position/Product Type Input 1   |  | •••            |
| 9B         |          | 800                               | Position/Product Type Input 2   |  | •••            |
| 10A        |          | 009                               | Position/Product Type Input 3   | Specifies the position numbers to move to, and the product type numbers,   | •••            |
| 10B        |          | 010                               | Position/Product Type Input 4   |  | <b></b>        |
| 11A        |          | 011 Position/Product Type Input 5 | The position and product type numbers are assigned by parameter settings. | •••  |                |
| 11B        |          | 012                               | Position/Product Type Input 6   | The number can be specified either as BCD or binary.   | •••            |
| 12A        |          | 013                               | Position/Product Type Input 7   | The number can be specified either as BOD or binary.   | •••            |
| 12B        |          | 014                               | Position/Product Type Input 8   |  | <b>-</b>       |
| 13A        |          | 015                               | Position/Product Type Input 9   |  |                |
| 13B        |          | 300                               | Alarm   | Turns off when an alarm occurs. (Contact B)  | •0•            |
| 14A        |          | 301                               | Ready   | Turns on when the controller starts up normally and is in an operable state.   |                |
| 14B        |          | 302                               | Positioning complete  | Turns on when the movement to the destination is complete.   | •0•            |
| 15A        | Output   | 303                               | Home Return complete  | Turns on when the home return operation is complete.   | - T            |
| 15B        | Juput    | 304                               | Servo ON output   | Turns on when servo is ON.   | - 6 T          |
| 16A        |          | 305                               | Pushing complete  | Turns on when a push motion is complete.   |                |
| 16B        |          | 306                               | System battery error  | Turns on when the system battery runs low (warning level).   | - T            |
| 17A        |          | 307                               | Absolute encoder battery error  | Turns on when the battery for the absolute encoder runs low (warning level).   | <b></b>        |
| 17B        | N        |                                   | 0V input  | Connect 0V.  Note: This is for NPN, PNP will be different.   | •              |

#### Positioner, 2-axis Independent Mode

| in Number | Category | Port No. | Positioner<br>Independent Mode | Functions   | Wiring Diagram |
|-----------|----------|----------|--------------------------------|---|----------------|
| 1A        | P24      |          | 24V input                      | Connect 24V.  |                |
| 1B        |          | 016      | Position input 7               |   | <b></b>        |
| 2A        | ] [      | 017      | Position input 8               | Specifies the position numbers to move to, using ports 010 to 022.                | •••            |
| 2B        | 1        | 018      | Position input 9               | The position numbers on the 1st and 2nd axes are assigned by                      | •••            |
| 3A        | 1 [      | 019      | Position input 10              | parameter settings.   | •••            |
| 3B        | 1 [      | 020      | Position input 11              | The number can be specified either as BCD or binary.                              | <b></b>        |
| 4A        | ] [      | 021      | Position input 12              |   | •••            |
| 4B        | 1 [      | 022      | Position input 13              |   | <b></b>        |
| 5A        | 1 [      | 023      | Error reset                    | Resets minor errors. (Severe errors require a restart.)                           | •••            |
| 5B        | ] [      | 000      | Start 1                        | Starts the movement to the selected position number on the 1st axis.              | •••            |
| 6A        | ] [      | 001      | Home Return 1                  | Performs Home Return on the 1st axis.   | •••            |
| 6B        | 1        | 002      | Servo ON 1                     | Switches between servo ON and OFF for the 1st axis.                               | •••            |
| 7A        | l        | 003      | Pause 1                        | Pauses the motion on 1st axis when turned OFF, and resumes when turned ON.        | •••            |
| 7B        | Input    | 004      | Cancel 1                       | Cancels the movement on the 1st axis.   | <b></b>        |
| 8A        | ] [      | 005      | Start 2                        | Starts the movement to the selected position number on the 2nd axis.              |                |
| 8B        | 1 [      | 006      | Home Return 2                  | Performs Home Return on the 2nd axis.   | <b></b>        |
| 9A        | 1 [      | 007      | Servo ON 2                     | Switches between servo ON and OFF for the 2nd axis.                               | •••            |
| 9B        | 1 [      | 800      | Pause 2                        | Pauses the motion on 2nd axis when turned OFF, and resumes when turned ON.        | <b></b>        |
| 10A       | 1 [      | 009      | Cancel 2                       | Cancels the movement on the 2nd axis.   | •••            |
| 10B       | 1        | 010      | Position input 1               | 0   | <b></b>        |
| 11A       | 1 [      | 011      | Position input 2               | Specifies the position numbers to move to, using ports 010 to 022.                | •••            |
| 11B       | 1 [      | 012      | Position input 3               | The position numbers on the 1st and 2nd axes are assigned by                      | <b></b>        |
| 12A       | ] [      | 013      | Position input 4               | parameter settings.   |                |
| 12B       | 1 [      | 014      | Position input 5               | The number can be specified either as BCD or binary.                              | <b></b>        |
| 13A       |          | 015      | Position input 6               |   | •              |
| 13B       |          | 300      | Alarm                          | Turns off when an alarm occurs. (Contact B)                                       | <b>→5</b> →    |
| 14A       | ] [      | 301      | Ready                          | Turns on when the controller starts up normally and is in an operable state.      |                |
| 14B       | ] [      | 302      | Positioning complete 1         | Turns on when the movement to the specified position on the 1st axis is complete. |                |
| 15A       | [        | 303      | Home Return complete 1         | Turns on when home return on the 1st axis is complete.                            |                |
| 15B       | Output   | 304      | Servo ON output 1              | Turns on when the 1st axis is in a servo ON state.                                | -FÖT           |
| 16A       |          | 305      | Positioning complete 2         | Turns on when the movement to the specified position on the 2nd axis is complete. |                |
| 16B       | 1        | 306      | Home Return complete 2         | Turns on when home return on the 2nd axis is complete.                            | <b>-</b> ₽₽    |
| 17A       | 1        | 307      | Servo ON output 2              | Turns on when the 2nd axis is in a servo ON state.                                | <b></b>        |
| 17B       | N        |          | 0V input                       | Connect 0V.   |                |

581



Slider Type

Mini
Standard

Controllers Integrated

Rod Type

Mini
Standard

Controllers Integrated

Table/Arm //Flat Type

Mini
Standard

Gripper/
Rotary Type















#### Positioner, Teaching Mode

| in Number | Category | Port No. | Positioner<br>Teaching Mode    | Functions   | Wiring Diagram |
|-----------|----------|----------|--------------------------------|---|----------------|
| 1A        | P24      |          | 24V input                      | Connect 24V.  |                |
| 1B        |          | 016      | JOG- on 1st axis               | While the signal is input, the 1st axis is moved in the - (negative) direction. | •              |
| 2A        |          | 017      | JOG+ on 2nd axis               | While the signal is input, the 2nd axis is moved in the + (positive) direction. | •••            |
| 2B        |          | 018      | JOG- on 2nd axis               | While the signal is input, the 2nd axis is moved in the - (negative) direction. | •••            |
| 3A        |          | 019      | Specify inching (0.01mm)       |   | •••            |
| 3B        |          | 020      | Specify inching (0.1mm)        | Specifies how much to move during inching.                                      | •••            |
| 4A        |          | 021      | Specify inching (0.5mm)        | (Total of the values specified for ports 019 to 022)                            | •••            |
| 4B        |          | 022      | Specify inching (1mm)          |   | •••            |
| 5A        |          | 023      | Error reset                    | Resets minor errors. (Severe errors require a restart.)                         | •••            |
| 5B        |          | 000      | Start                          | Starts moving to selected position.   | •••            |
| 6A        |          | 001      | Servo ON                       | Switches between Servo ON and OFF.  | • •            |
| 6B        |          | 002      | Pause                          | Pauses the motion when turned OFF, and resumes motion when turned ON.           | • •            |
| 7A        | Innut    | 003      | Position input 1               |   | •••            |
| 7B        | Input    | 004      | Position input 2               |   | •••            |
| 8A        |          | 005      | Position input 3               |   | •••            |
| 8B        |          | 006      | Position input 4               |   | •••            |
| 9A        |          | 007      | Position input 5               | Ports 003 to 013 are used to specify the position number to move, and           | •••            |
| 9B        |          | 800      | Position input 6               | the position number for inputting the current position.                         | •••            |
| 10A       |          | 009      | Position input 7               | When the teaching mode setting on port 014 is in the ON state, the              | •••            |
| 10B       |          | 010      | Position input 8               | current value is written to the specified position number.                      | •••            |
| 11A       |          | 011      | Position input 9               |   | •••            |
| 11B       |          | 012      | Position input 10              |   | •••            |
| 12A       |          | 013      | Position input 11              |   | •••            |
| 12B       |          | 014      | Teaching mode setting          |   | •••            |
| 13A       |          | 015      | JOG+ on 1st axis               | While the signal is input, the 1st axis is moved in the plus direction.         |                |
| 13B       |          | 300      | Alarm                          | Turns off when an alarm occurs. (Contact B)                                     |                |
| 14A       | [        | 301      | Ready                          | Turns on when the controller starts up normally and is in an operable state.    |                |
| 14B       |          | 302      | Positioning complete           | Turns on when the movement to the destination is complete.                      | <b>→</b> ○     |
| 15A       | Output   | 303      | Home Return complete           | Turns on when the home return operation is complete.                            |                |
| 15B       | Output   | 304      | Servo ON output                | Turns on when servo is ON.  |                |
| 16A       | [        | 305      | _                              | -   |                |
| 16B       |          | 306      | System battery error           | Turns on when the system battery runs low (warning level).                      |                |
| 17A       |          | 307      | Absolute encoder battery error | Turns on when the battery for the absolute encoder runs low (warning level).    | •5•            |
| 17B       | N        |          | 0V input                       | Connect 0V.   | •              |

#### Positioner, DS-S-C1 Compatible Mode

| Number | Category | Port No. | Positioner DS-S-C1<br>Compatible Mode | Functions   | Wiring Diagram |
|--------|----------|----------|---------------------------------------|---|----------------|
| 1A     | P24      |          | 24V input                             | Connect 24V.  |                |
| 1B     |          | 016      | Position No. 1000                     | (Same as ports 004 through 015)   | •••            |
| 2A     | Ī        | 017      | Position No. 2000                     | -   | •••            |
| 2B     | Ī        | 018      | Position No. 4000                     | =   | •••            |
| 3A     | Ī        | 019      | Position No. 8000                     | =   | •••            |
| 3B     | Ī        | 020      | Position No. 10000                    | -   | <b></b>        |
| 4A     |          | 021      | Position No. 20000                    | -   | •••            |
| 4B     | ſ        | 022      | NC (*1)                               | =   |                |
| 5A     |          | 023      | CPU reset                             | Resets the system to the same state as when the power is turned on.                           | •••            |
| 5B     |          | 000      | Start                                 | Starts moving to selected position.   | •••            |
| 6A     | [        | 001      | Hold (Pause)                          | Pauses the motion when turned ON, and resumes motion when turned OFF.                         | • • •          |
| 6B     | [        | 002      | Cancel                                | Stops the motion when turned ON. The remaining motion is canceled.                            | <b></b>        |
| 7A     | Input    | 003      | Interpolation setting                 | When this signal is turned ON for a 2-axis model, the actuator moves by linear interpolation. | •••            |
| 7B     | IIIput   | 004      | Position No. 1                        |   | <b></b>        |
| 8A     |          | 005      | Position No. 2                        |   | •••            |
| 8B     |          | 006      | Position No. 4                        |   | <b>-</b>       |
| 9A     |          | 007      | Position No. 8                        |   | •••            |
| 9B     |          | 008      | Position No. 10                       | Ports 004 through 016 are used to specify the position number to move.                        | •••            |
| 10A    |          | 009      | Position No. 20                       | The numbers are specified as BCD.   | • • •          |
| 10B    |          | 010      | Position No. 40                       | The humbers are specified as BOD.   | •••            |
| 11A    |          | 011      | Position No. 80                       |   | •••            |
| 11B    |          | 012      | Position No. 100                      |   | • • •          |
| 12A    |          | 013      | Position No. 200                      |   |                |
| 12B    |          | 014      | Position No. 400                      |   | • •            |
| 13A    |          | 015      | Position No. 800                      |   |                |
| 13B    |          | 300      | Alarm                                 | Turns off when an alarm occurs. (Contact A)   | • O •          |
| 14A    |          | 301      | Ready                                 | Turns on when the controller starts up normally and is in an operable state.                  | <u> </u>       |
| 14B    |          | 302      | Positioning complete                  | Turns on when the movement to the destination is complete.                                    | •0•            |
| 15A    | Output   | 303      | -                                     | -   |                |
| 15B    | - Lapar  | 304      | -                                     | -   | •              |
| 16A    |          | 305      | _                                     | -   | •0•            |
| 16B    |          | 306      | System battery error                  | Turns on when the system battery runs low (warning level).                                    |                |
| 17A    |          | 307      | Absolute encoder battery error        | Turns on when the battery for the absolute encoder runs low (warning level).                  |                |
| 17B    | N        |          | 0V input                              | Connect 0V.  Note: This is for NPN. PNP will be different.                                    | •              |

SSEL **582** 





# SSEL Controller

#### Table of specifications

|                           | Item Specifications                        |   |  |  |  |  |
|---------------------------|--|---|--|--|--|--|
|                           | Connected actuator                         | RCS2 series actuator / single a   | xis robot / linear servo actuator  |  |  |  |
| Si l                      | Input Voltage                              | Single-phase AC90V to AC126.5V  | Single-phase AC180V to AC253V  |  |  |  |
| ä                         | Power Supply Capacity                      | Max. 1660VA (for 400W, 2-axis operation)                                      |  |  |  |  |
|                           | Dielectric strength voltage                | DC500V 10   | MΩ or higher   |  |  |  |
| bed                       | Withstand voltage                          | AC500V 1 min.   |  |  |  |  |
| ွ                         | Rush current                               | Control Power 15A / Motor Power 37.5A   | Control Power 30A / Motor Power 75A  |  |  |  |
| Basic Specifications      | Vibration resistance                       | XYZ directions 10 to 57Hz, One side amplitude 58 to 150 Hz 4.9 m/s² (continuo |  |  |  |  |
|                           | Number of control axes                     | 1 axis  | / 2 axis   |  |  |  |
| o u                       | Maximum total output of connected axis     | 400W  | 800W   |  |  |  |
| Control<br>specification  | Position detection method                  | Incremental encode  | r / Absolute encoder   |  |  |  |
| 듯흥                        | Speed setting                              | 1mm/sec and up, the maximum de  | epends on actuator specifications  |  |  |  |
| o g                       | Acceleration setting                       | 0.01G and up, the maximum   | m depends on the actuator  |  |  |  |
|                           | Operating method                           | Program operation / Position  | oner operation (switchable)  |  |  |  |
|                           | Programming language                       | Super SEL language  |  |  |  |  |
|                           | Number of programs                         | 128 programs  |  |  |  |  |
| 듩                         | Number of program steps                    | 9999 steps  |  |  |  |  |
| Program                   | Number of multi-tasking programs           | 8 programs  |  |  |  |  |
| 집                         | Positioning Points                         | 20000 points  |  |  |  |  |
|                           | Data memory device                         |   | up battery can be added as an option)  |  |  |  |
|                           | Data input method                          | Teaching pendant or PC software   |  |  |  |  |
| _                         | Number of I/O                              | 24 input points / 8 output po   | ints (NPN or PNP selectable)   |  |  |  |
| . <u>i</u>                | I/O power                                  | Externally supplied   |  |  |  |  |
| cat                       | PIO cable                                  | CB-DS-PIO □□□ (sup  | plied with the controller)   |  |  |  |
| Ē                         | Serial communications function             | RS232C (D-Sub Half-pitch o  | connector) / USB connector   |  |  |  |
| Communication             | Field Network                              | DeviceNet, CC   | -Link, ProfiBus  |  |  |  |
| Š                         | Motor Cable                                |   | □  |  |  |  |
|                           | Encoder cable                              | CB-RCP2-PA □  | □□ (Max. 20m)  |  |  |  |
| SL                        | Protection function                        | Motor overcurrent, Motor driver temperature che<br>Soft limit over, system    | ck, Overload check, Encoder open-circuit check<br>error, battery error, etc. |  |  |  |
| 텵σ                        | Ambient operating humidity and temperature | 0 to 40°C 10 to 95  | % (non-condensing)   |  |  |  |
| General<br>specifications | Ambient atmosphere                         | Free from corrosive gases. In particu   | lar, there shall be no significant dust.                                     |  |  |  |
| Se Se                     | Protection class                           | IP.   | 20   |  |  |  |
| g                         | Weight                                     | 1.4   | kg   |  |  |  |
|                           | External dimensions                        | 100mm (W) x 202.6mm (H) x 126mm (D)   |  |  |  |  |

#### **External Dimensions**





**583** SSEL



SCON

PSEL

ASEL

SSEL


XSEL

Pulse Motor

Servo Motor
(24V)

Servo Motor
(200V)

# 19 20 8



#### 1 Status indicator LEDs

These LEDs are used to indicate the operating condition of

The LED status indicators are as follows:

**PWR** Power is input to controller.

The controller is ready to perform program

operation.

The controller is abnormal. ALM EMG

An emergency stop is actuated and the drive

source is cut off.

SV1 The axis 1 actuator servo is on. SV2 : The axis 2 actuator servo is on.

2 System I/O connector

Connector for emergency stop / enable input / brake power

3 Teaching pendant connector

A half-pitch I/O 26-pin connector that connects a teaching pendant when the running mode is MANU. A special conversion cable is needed to connect a conventional Dsub. 25-pin connector.

4 Mode switch

This switch is used to specify the running mode of the controller. The left position indicates the MANU (manual operation) mode, while the right position indicates the AUTO (automatic operation) mode. Teaching can only be performed as manual operation, and automatic operation using external I/Os is not possible in the MANU mode.

5 USB connector

A connector for PC connection via USB. If the USB connector is connected, the TP connector is disabled and all communication inputs to the TP connector are cut off.

6 I/O Connector

A connector for interface I/Os.

34-pin flat cable connector for DIO (24IN/8OUT) interface.

I/O power is also supplied to the controller via this connector (Pin No. 1 and No. 34).

7 Panel unit connector

A connector for the panel unit (optional) that displays the controller status and error numbers.

8 Absolute data backup battery

When an absolute-type axis is operated, this battery retains position data even after the power is cut off.

9 System memory backup battery (Option)

This battery is needed if you wish to retain various data recorded in the SRAM of the controller even after the

power is cut off.
This battery is optional. Specify it if necessary.

10 Power supply connector

AC power connector. Divided into the control power input and motor power input.

11 Grounding screw

Protective grounding screw. Always ground this screw.

12 External regenerative resistor connector

A connector for the regenerative resistor that must be connected when the built-in regenerative resistor alone does not offer sufficient capacity in high-acceleration/ high-load operation, etc.

Whether or not an external regenerative resistor is necessary depends on the conditions of your specific application such as the axis configuration.

13 Motor connector for axis 1

Connects the motor cable of the axis 1 actuator.

14 Motor connector for axis 2

Connects the motor cable of the axis 2 actuator.

15 Brake switch for axis 1

This switch is used to release the axis brake. Setting it to the left position (RLS side) forcibly releases the brake, while setting it to the right position (NOM side) causes the controller to automatically control the brake.

16 Brake switch for axis 2

This switch is used to release the axis brake. Setting it to the left position (RLS side) forcibly releases the brake, while setting it to the right position (NOM side) causes the controller to automatically control the brake.

17 Encoder connector for axis 1

Connect the encoder cable of the axis 1 actuator.

18 Encoder connector for axis 2 Connect the encoder cable of the axis 2 actuator.

19 Absolute-data backup battery connector for axis 1 A connector for the battery that backs up absolute data for

axis 1 when the actuator uses an absolute encoder.

20 Absolute-data backup battery connector for axis 2

A connector for the battery that backs up absolute data for axis 2 when the actuator uses an absolute encoder.

21 System-memory backup battery connector A connector for the system-memory backup battery.

Standard
Controllers
Integrated
Rod
Type
Mini
Standard
Controllers
Integrated
Table/Arm
(Flat Type
Mini

Controllers

PMEC
/AMEC

PSEP
/ASEP

ROBO
NET

ERC2

PCON

ACON

SCON

PSEL

ASEL

XSEL

Sold & Serviced By: **S** ELECTROMATE Toll Free Phone (877) SERV098 Toll Free Fax (877) SERV099 www.electromate.com

sales@electromate.com

#### Option

## Teaching Pendant

A teaching device for entering programs and positions, test runs, and monitoring. Features

■ Model/Price

| Model    | Description                             |
|----------|---|
| SEL-T-J  | Standard type with adapter cable        |
| SEL-TD-J | Deadman's switch type and adapter cable |






**■** SEL-T option Wall-mounting

hook Model HK-1





Specifications

| Item                                | SEL-T-J   | SEL-TD-J          |  |  |
|-------------------------------------|---|-------------------|--|--|
| 3-position Enable Switch            | No  | Yes               |  |  |
| ANSI/UL standards                   | Non-compliant   | Compliant         |  |  |
| CE mark                             | Compliant   |                   |  |  |
| Display                             | 20 char. × 4 lines                                      |                   |  |  |
| Ambient Operating<br>Temp./Humidity | mbient Operating<br>emp./Humidity 0~40°C 10~90% RH (nor |                   |  |  |
| Protective structure                | e structure IP54  |                   |  |  |
| Weight                              | Approx. 0.4kg   | (not incl. cable) |  |  |

## PC Software (Windows Only)

A startup support software for entering programs/positions, performing test runs, and monitoring. More functions have been added for Features

debugging, and improvements have been made to shorten the start-up time.

IA-101-X-MW-J (with RS232C cable + adapter cable) Model

> IA-101-X-MW (with RS232C cable)

Mini
Standard
Controllers
Integrated
Roc
Type
Mini
Standard









BS232C Cable Adapter cable CB-ST-E1MW050-EB (with USB cable)









Only versions 6.0.0.0 and later can be used with the SSEL controller.

## Regenerative Resistor Unit

■ Features


A unit that converts the regenerative current, generated during the acceleration/deceleration of the of the motor, into heat. In the table on the right, check the total power output of the actuator to see if a regenerative resistor is needed.

REU-2 (for SCON/SSEL) ■ Model

Standard Price

|         | Horizontal | Vertical |
|---------|------------|----------|
| 0 units | ~200W      | ~200W    |
| 1 unit  | ~800W      | ~600W    |
| 2 units |            | 800W     |

\* Depending on the operating conditions, more regenerative resistors may be need




#### ■ Specifications

| Weight of main unit              | 0.9kg                   |
|----------------------------------|-------------------------|
| Internal regenerative resistance | 220Ω 80W                |
| Main unit-Controller             | CB-SC-REU010 (for SSEL) |

#### **Panel Unit**

■ Features Display device that shows the error code from ניסיים uevice that shows the error code from the controller or the currently running program number.

■ Model PU-1 (Cable length: 3m)



# acquire one REU-2 and one REU-1 (See P596). Absolute Data Backup Battery

If 2 regenerative units are needed.

■ Features Battery for saving absolute data, when operating an actuator with an absolute encoder. Same as the battery used for system memory

■ Model AB-5



## System Memory Backup Battery

■ Features This battery is required, for example, when you are using global flags in the program and you want to retain your data even after the power has been turned OFF.

■ Model AB-5-CS (with case) AB-5 (Standalone battery)



585 SSFI



#### **Dummy Plug**

When connecting the SSEL controller to a computer with a USB cable, this plug is inserted in the teaching port to shut off the ■ Features

Motor cable/Motor robot cable

(Supplied with the PC software IA-101-X-USB)

■ Model DP-3

#### **USB** Cable

■ Features A cable for connecting the controller to the

USB port to a computer.
A controller with no USB port (e.g. XSEL) can be connected to the USB port of a computer by connecting an RS232C cable to the USB cable via a USB adapter.
(See PC software IA-101-X-USBMW)

■ Model CB-SEL-USB030 (Cable length: 3m)



#### Adapter Cable

■ Features

An adapter cable to connect the D-sub 25-pin connector from the teaching pendant or a PC to the teaching connector (half-pitch) of the SSEL controller.

CB-SEL-SJ002 (Cable length: 0.2m) **■ Model** 

\* Enter the cable length (L) into  $\Box\Box\Box$  . Compatible to a maximum of 30 meters. Ex.: 080 = 8 m

\* Enter the cable length (L) into . Compatible to a maximum of 30 meters.

 $^{\star}$  Enter the cable length (L) into  $\Box\Box\Box$  . Compatible to a maximum of 30 meters.

\* Enter the cable length (L) into  $\square$  . Compatible to a maximum of 10 meters. Ex.: 080 = 8 m



**SSEL 586** 





#### Spare parts

When you need spare parts after purchasing the product, such as when replacing a cable, refer to the list of models below.

Model CB-RCC-MA 

| 2                                     |                 |              | Wire   | Color | Signal |   |               |   | Signal | Color | Wire      |  |
|---------------------------------------|-----------------|--------------|--------|-------|--------|---|---------------|---|--------|-------|-----------|--|
|                                       | 1               | <u> </u>     |        | Green | PE     | 1 | $\vdash$      | 1 | U      | Red   |           |  |
| :                                     |                 |              | 0.75sq | Red   | U      | 2 | $\vdash$      | 2 | ٧      | White | 0.75sq    |  |
|                                       |                 | (8)          |        | White | ٧      | 3 | $\overline{}$ | 3 | W      | Black | (crimped) |  |
| 1                                     | Mechanical side | (Front view) |        | Black | w      | 4 |               | 4 | PE     | Green |           |  |
| or larger (when movable type is used) |                 |              |        |       |        |   |               |   |        |       |           |  |


Ex.: 080 = 8 m


Min. bend radius r = 50 mm or \* Only the robot cable is to be used in a cable track.

#### Encoder cable/Encoder robot cable

CB-RCS2-PA / CB-X3-PA

Min. bend radius r = 50 mm or larger (when movable type is used) \* Only the robot cable is to be used in a cable track.







#### Encoder cable/Encoder robot cable for RCS2-RT6/RT6R/RT7R/RA13R

□ / CB-X2-PLA [ CB-RCS2-PLA Min. bend radius r = 50 mm or larger (when movable type is used)

\* Only the robot cable is to be used in a cable track.





**CB-DS-PIO** Model

1B

|                          | Pin No.           | Color    | Wire    | Pin No. | Color    | Wire    |
|--------------------------|-------------------|----------|---------|---------|----------|---------|
| <u>∠</u> 2m              | 1A                | Brown 1  |         | 9B      | Gray 2   |         |
| i i                      | 1B                | Red 1    |         | 10A     | White 2  |         |
|                          | 2A                | Orange 1 |         | 10B     | Black 2  |         |
| 20 4 4                   | 2B                | Yellow 1 |         | 11A     | Brown-3  |         |
| No c                     | 3A                | Green 1  |         | 11B     | Red 3    |         |
|                          | 3B                | Blue1    |         | 12A     | Orange 3 |         |
| No c                     | connector 4A      | Purple 1 |         | 12B     | Yellow 3 |         |
|                          | 4B                | Gray 1   | Flat    | 13A     | Green 3  | Flat    |
|                          | 5A                | White 1  | cable   | 13B     | Blue 3   | cable   |
| ■ 17A ■ 17A              | 5B                | Black 1  | crimped | 14A     | Purple 3 | crimped |
|                          | 6A                | Brown-2  |         | 14B     | Gray 3   |         |
| Flat cable AWG28 (34-cor | re) <sub>6B</sub> | Red 2    |         | 15A     | White 3  |         |
|                          | 7A                | Orange 2 |         | 15B     | Black 3  |         |
|                          | 7B                | Yellow 2 |         | 16A     | Brown-4  |         |
|                          | 8A                | Green 2  |         | 16B     | Red 4    |         |
|                          | 8B                | Blue 2   |         |         | Orange 4 |         |
|                          | 9A                | Purple 2 |         | 17B     | Yellow 4 |         |



Mini
Standard
Controllers
Integrated
Rod
Type
Mini
Standard

























Program controller For RCS2 series



## List of models

Multiaxial program controller for operating RCS2 Series actuators. Up to 6 axes can be simultaneously controlled.

| Туре                           | J  | к                    | Р   | Q   |  |
|--------------------------------|--|----------------------|---|---|--|
| Name                           | Compact Type   | General Purpose Type | Large-Capacity Type   | Large-Capacity Type<br>(Safety Category<br>Compliant)     |  |
| External View                  | Compact, low-cost type ideal for operating low-capable of corporation id |                      |   |   |  |
| Description                    |  |                      | Large-capacity type<br>capable of controlling up<br>to six axes or 2,400W | Large-capacity type<br>conforming to safety<br>category 4 |  |
| Maximum number of control axes | 4-2  | axis                 | 6-axis  |   |  |
| Number of positions            | 3,000 р  | ositions             | 20,000 positions  |   |  |
| Total Number of Connectable W  | 800W 1600W   |                      | 2400W   |   |  |
| Power Supply                   | Single-phase AC100V  | /Single-phase AC200V | Single-phase AC20   | 0V/3-phase AC200V   |  |
| Safety Category                | · ·  | 3                    | В   | Category 4 compatible                                     |  |
| Safety Rating                  | -  | -                    | CE  | CE, ANSI  |  |

- (\*1) The maximum output for 1 shaft during vertical operation is limited to 600W.
- (\*2) Axis 5 and axis 6 cannot control the RCS2-RA7/SRA7 series.

Pulse Motor

Servo Motor
(24V)

Servo Motor
(200V)


Linear
Servo Motor

Linear Servo
Type
Cleanroom
Type
Splash-Proof
Controllers
PMEC
/MMEC
/MMEC
PSEP
/ASEP
ROBO
NET
ERC2
PCON
ACON
PSEL
ASEL


**587** XSEL








\*To specify multiple options, enter them in alphabetical order, (Example: Brake + Home sensor -> BL)



#### [XSEL-P/Q type]



#### Note:

For axis 5 and 6 of XSEL-P/Q type, LSA series, and the RCS2-RA7 / SRA7 series actuators are unavailable.



Controllers Integrated

Food

Standard

Controllers Integrated


Controllers Integrated

Fable/Arm

FlatType

Mini

(200V)



ZCAT3035-1330 for control power (Manufacturer: TDK) RFC-H13 for motor power (Manufacturer: Kitagawa Kogyo Co., Ltd.) 3-phase R/AV-781BXZ-4 Single-phase R/AV-781BWZ-2A (Manufacturer: Okaya Electric Industries)

(Supplied by user)

Required only for type Q (not required for type P)

Clamp Filter

Surge Protector Recommended Models

Recommended Models

589 xsel


For the required number of regenerative units, see P596.



#### I/O wiring drawing


#### ■ Input section External input specification (NPN specification)

| Item                 | Specifications  |  |  |  |
|----------------------|---|--|--|--|
| Input voltage        | DC24V ±10%  |  |  |  |
| Input current        | 7mA / circuit   |  |  |  |
| ON/OFF voltage       | ON Voltage Min DC16.0V / OFF Voltage Max DC5.0V         |  |  |  |
| Isolation method     | Photocoupler  |  |  |  |
| Externally Connected | (1) Non-Voltage Contact (Minimum load around DC5V, 1mA) |  |  |  |
| Equipment            | (2) Photoelectric Proximity Sensor (NPN Type)           |  |  |  |
|                      | (3) PLC Transistor Output (Open Collector Type)         |  |  |  |
|                      | (4) PLC Contact Output (Minimum Load approx.            |  |  |  |
|                      | DC5V, 1mA)  |  |  |  |




#### ■ Input section External input specification (PNP specification)

| Item                           | Specifications  |
|--------------------------------|---|
| Input voltage                  | DC24V ±10%  |
| Input current                  | 7mA / circuit   |
| ON/OFF voltage                 | ON Voltage Min DC8V / OFF Voltage Max DC19V             |
| Isolation method               | Photocoupler  |
| Externally Connected Equipment | (1) Non-Voltage Contact (Minimum load around DC5V, 1mA) |
|                                | (2) Photoelectric Proximity Sensor (PNP Type)           |
|                                | (3) PLC Transistor Output (Open Collector Type)         |
|                                | (4) PLC Contact Output (Minimum Load approx. DC5V, 1mA) |



#### ■ Output section External input specification (NPN specification)


| Item                 | Specifications             |                           |  |  |  |  |
|----------------------|----------------------------|---------------------------|--|--|--|--|
| Load Voltage         | DC24V                      |                           |  |  |  |  |
| Max. load current    | 100mA / point 400 mA       | TDC0004 (as a suited and) |  |  |  |  |
| Leak current         | Peak (Total Current)       | TD62084 (or equivalent)   |  |  |  |  |
| Isolation method     | Max 0.1mA / point          |                           |  |  |  |  |
| Externally Connected | Photocoupler               |                           |  |  |  |  |
| Equipment            | (1) Miniature Relay, (2) P | LC Input Unit             |  |  |  |  |
|                      |                            |                           |  |  |  |  |



#### ■ Output section External input specification (PNP specification)

| Specifications                          |   |  |  |  |
|---|---|--|--|--|
| DC24V                                   | TDC0704 (or a revised and)  |  |  |  |
| 100mA /1 point                          |   |  |  |  |
| 400mA / 8 port (Note)                   | TD62784 (or equivalent)   |  |  |  |
| Max 0.1mA / point                       |   |  |  |  |
| Photocoupler                            |   |  |  |  |
| (1) Miniature Relay, (2) PLC Input Unit |   |  |  |  |
|   | DC24V<br>100mA /1 point<br>400mA / 8 port (Note)<br>Max 0.1mA / point<br>Photocoupler |  |  |  |

(Note) 400mA is the maximum total load current for each set of the eight ports from output port No. 300. (The maximum total current output for output port No. 300+n to No. 300+n+7 must be 400mA, where n = 0 or a multiple of eight.)



#### I/O Signal table

| Pin No. | Classification | Port No. | Standard Settings                         |
|---------|----------------|----------|---|
| 1       |                | _        | (J/P/Q type: 24V connection / K type: NC) |
| 2       | 1              | 000      | Program start                             |
| 3       | 1              | 001      | General Purpose Input                     |
| 4       | 1              | 002      | General Purpose Input                     |
| 5       |                | 003      | General Purpose Input                     |
| 6       | 1              | 004      | General Purpose Input                     |
| 7       | i I            | 005      | General Purpose Input                     |
| 8       | 1              | 006      | General Purpose Input                     |

Standard I/O Signal Table (when N1 or P1 is selected)

| 2  |        | 000 | Program start                          |
|----|--------|-----|--|
| 3  |        | 001 | General Purpose Input                  |
| 4  |        | 002 | General Purpose Input                  |
| 5  |        | 003 | General Purpose Input                  |
| 6  |        | 004 | General Purpose Input                  |
| 7  | 1      | 005 | General Purpose Input                  |
| 8  |        | 006 | General Purpose Input                  |
| 9  | 1      | 007 | Program Specification (PRG No. 1)      |
| 10 | 1      | 800 | Program Specification (PRG No. 2)      |
| 11 | 1      | 009 | Program Specification (PRG No. 4)      |
| 12 | 1      | 010 | Program Specification (PRG No. 8)      |
| 13 | 1      | 011 | Program Specification (PRG No. 10)     |
| 14 | 1      | 012 | Program Specification (PRG No. 20)     |
| 15 | 1      | 013 | Program Specification (PRG No. 40)     |
| 16 | i      | 014 | General Purpose Input                  |
| 17 | Input  | 015 | General Purpose Input                  |
| 18 |        | 016 | General Purpose Input                  |
| 19 | 1      | 017 | General Purpose Input                  |
| 20 | 1      | 018 | General Purpose Input                  |
| 21 | 1      | 019 | General Purpose Input                  |
| 22 | i      | 020 | General Purpose Input                  |
| 23 | İ      | 021 | General Purpose Input                  |
| 24 | i      | 022 | General Purpose Input                  |
| 25 | i      | 023 | General Purpose Input                  |
| 26 | 1      | 024 | General Purpose Input                  |
| 27 | i      | 025 | General Purpose Input                  |
| 28 | i      | 026 | General Purpose Input                  |
| 29 | i      | 027 | General Purpose Input                  |
| 30 |        | 028 | General Purpose Input                  |
| 31 | i      | 029 | General Purpose Input                  |
| 32 | İ      | 030 | General Purpose Input                  |
| 33 | i      | 031 | General Purpose Input                  |
| 34 |        | 300 | Alarm Output                           |
| 35 | 1      | 301 | Ready Output                           |
| 36 | 1      | 302 | Emergency Stop Output                  |
| 37 | 1      | 303 | General Purpose Output                 |
| 38 | 1      | 304 | General Purpose Output                 |
| 39 | 1      | 305 | General Purpose Output                 |
| 40 | 1      | 306 | General Purpose Output                 |
| 41 | 1      | 307 | General Purpose Output                 |
| 42 | Output | 308 | General Purpose Output                 |
| 43 |        | 309 | General Purpose Output                 |
| 44 | 1      | 310 | General Purpose Output                 |
| 45 | 1      | 311 | General Purpose Output                 |
| 46 | 1      | 312 | General Purpose Output                 |
| 47 | 1      | 313 | General Purpose Output                 |
| 48 | 1      | 314 | General Purpose Output                 |
| 49 | 1      | 315 | General Purpose Output                 |
| 50 | İ      | _   | (J/P/Q type: 0V connection/K type: NC) |
|    |        |     | (3 2)p                                 |

| Pin No.   Classification   Standard Settings   1   1   1   1   1   1   1   1   1  |
|---|
| 1 UPPO type 2NV connection / K type NO) 2 General Purpose Input 4 General Purpose Input 5 General Purpose Input 6 General Purpose Input 6 General Purpose Input 7 General Purpose Input 8 General Purpose Input 9 General Purpose Input 10 General Purpose Input 11 General Purpose Input 12 General Purpose Input 13 General Purpose Input 14 General Purpose Input 15 General Purpose Input 16 General Purpose Input 17 General Purpose Input 18 General Purpose Input 19 General Purpose Input 19 General Purpose Input 19 General Purpose Input 19 General Purpose Input 19 General Purpose Input 20 General Purpose Input 21 General Purpose Input 22 General Purpose Input 23 General Purpose Input 24 General Purpose Input 25 General Purpose Input 26 General Purpose Input 27 General Purpose Input 28 General Purpose Input 29 General Purpose Input 29 General Purpose Input 29 General Purpose Input 29 General Purpose Input 29 General Purpose Input 29 General Purpose Input 29 General Purpose Input 29 General Purpose Input 30 General Purpose Input 31 General Purpose Input 32 General Purpose Input 33 General Purpose Input 34 General Purpose Input 35 General Purpose Input 36 General Purpose Input 37 General Purpose Input 38 General Purpose Input 39 General Purpose Input 40 General Purpose Input 40 General Purpose Input 41 General Purpose Input 42 General Purpose Input 43 General Purpose Input |
| General Purpose Input   |
| General Purpose Input   |
| General Purpose Input   |
| General Purpose Input   |
| General Purpose Input   |
| Second Purpose Input  |
| 9 General Purpose Input 10 General Purpose Input 11 General Purpose Input 12 General Purpose Input 13 General Purpose Input 14 General Purpose Input 15 General Purpose Input 16 General Purpose Input 17 Input 18 General Purpose Input 19 General Purpose Input 20 General Purpose Input 21 General Purpose Input 22 General Purpose Input 23 General Purpose Input 24 General Purpose Input 25 General Purpose Input 26 General Purpose Input 27 General Purpose Input 28 General Purpose Input 29 General Purpose Input 29 General Purpose Input 29 General Purpose Input 29 General Purpose Input 29 General Purpose Input 29 General Purpose Input 29 General Purpose Input 29 General Purpose Input 30 General Purpose Input 31 General Purpose Input 32 General Purpose Input 33 General Purpose Input 34 General Purpose Input 35 General Purpose Input 36 General Purpose Input 37 General Purpose Input 38 General Purpose Input 39 General Purpose Input 39 General Purpose Input 39 General Purpose Input 39 General Purpose Input 39 General Purpose Output 39 General Purpose Output 39 General Purpose Output 39 General Purpose Output   |
| 10  |
| 11  |
| 12  |
| 13  |
| 14   General Purpose Input  |
| 15  |
| 16  |
| 17  |
| 18  |
| 19  |
| 20  |
| 21   General Purpose Input  |
| 22   General Purpose Input  |
| 23  |
| 24         General Purpose Input           25         General Purpose Input           26         General Purpose Input           27         General Purpose Input           28         General Purpose Input           29         General Purpose Input           30         General Purpose Input           31         General Purpose Input           32         General Purpose Input           33         General Purpose Input           34         General Purpose Output           35         General Purpose Output           36         General Purpose Output   |
| 25 General Purpose Input 26 General Purpose Input 27 General Purpose Input 28 General Purpose Input 29 General Purpose Input 30 General Purpose Input 31 General Purpose Input 32 General Purpose Input 32 General Purpose Input 33 General Purpose Input 34 General Purpose Input 36 General Purpose Output 36 General Purpose Output 36 General Purpose Output  |
| 26         General Purpose Input           27         General Purpose Input           28         General Purpose Input           29         General Purpose Input           30         General Purpose Input           31         General Purpose Input           32         General Purpose Input           33         General Purpose Input           34         General Purpose Output           35         General Purpose Output           36         General Purpose Output   |
| 27         General Purpose Input           28         General Purpose Input           29         General Purpose Input           30         General Purpose Input           31         General Purpose Input           32         General Purpose Input           33         General Purpose Output           34         General Purpose Output           35         General Purpose Output           36         General Purpose Output   |
| 28         General Purpose Input           29         General Purpose Input           30         General Purpose Input           31         General Purpose Input           32         General Purpose Input           33         General Purpose Input           34         General Purpose Output           35         General Purpose Output           36         General Purpose Output   |
| 29 General Purpose Input 30 General Purpose Input 31 General Purpose Input 32 General Purpose Input 33 General Purpose Input 34 General Purpose Input 35 General Purpose Output 36 General Purpose Output 36 General Purpose Output   |
| 30         General Purpose Input           31         General Purpose Input           32         General Purpose Input           33         General Purpose Input           34         General Purpose Output           35         General Purpose Output           36         General Purpose Output   |
| 31         General Purpose Input           32         General Purpose Input           33         General Purpose Input           34         General Purpose Output           35         General Purpose Output           36         General Purpose Output  |
| 32         General Purpose Input           33         General Purpose Input           34         General Purpose Output           35         General Purpose Output           36         General Purpose Output   |
| 33         General Purpose Input           34         General Purpose Output           35         General Purpose Output           36         General Purpose Output  |
| 34         General Purpose Output           35         General Purpose Output           36         General Purpose Output   |
| 35 General Purpose Output 36 General Purpose Output   |
| 36 General Purpose Output   |
|   |
| 37 General Purpose Output   |
| 38 General Purpose Output   |
| 39 General Purpose Output   |
| 40 General Purpose Output   |
| 41 General Purpose Output   |
| 42 Output General Purpose Output  |
| 43 General Purpose Output   |
| 44 General Purpose Output   |
| 45 General Purpose Output   |
| 46 General Purpose Output   |
| 47 General Purpose Output   |
| 48 General Purpose Output   |
| 49 General Purpose Output   |
| 50 (J/P/Q type: 0V connection/K type: NC)   |

| Extension I/C | ) Signal T     | able (when N2 or P2 is selected)               |
|---------------|----------------|--|
| Pin No        | Classification | Standard Settings                              |
| 1             | Olassilloation | (J/P/Q type: 24V connection / K type: NC)      |
| 2             |                | General Purpose Input                          |
| 3             |                | General Purpose Input                          |
| 4             |                | General Purpose Input                          |
| 5             |                | General Purpose Input                          |
| 6             |                | General Purpose Input                          |
| 7             |                | General Purpose Input                          |
| 8             |                | General Purpose Input                          |
| 9             | Input          | General Purpose Input                          |
| 10            |                | General Purpose Input                          |
| 11            |                | General Purpose Input                          |
| 12            |                | General Purpose Input                          |
| 13            |                | General Purpose Input                          |
| 14            |                | General Purpose Input                          |
| 15            |                | General Purpose Input                          |
| 16            |                | General Purpose Input                          |
| 17            |                | General Purpose Input                          |
| 18            |                | General Purpose Output                         |
| 19            |                | General Purpose Output                         |
| 20            |                | General Purpose Output                         |
| 21            |                | General Purpose Output                         |
| 22            |                | General Purpose Output                         |
| 23            |                | General Purpose Output                         |
| 24            |                | General Purpose Output                         |
| 25            |                | General Purpose Output                         |
| 26            |                | General Purpose Output                         |
| 27            |                | General Purpose Output                         |
| 28            |                | General Purpose Output                         |
| 29            |                | General Purpose Output                         |
| 30            |                | General Purpose Output                         |
| 31            |                | General Purpose Output                         |
| 32            |                | General Purpose Output                         |
| 33            |                | General Purpose Output                         |
| 34            | Output         | General Purpose Output                         |
|               |                | General Purpose Output  General Purpose Output |
| 36<br>37      |                | General Purpose Output                         |
| 38            |                | General Purpose Output                         |
| 39            |                | General Purpose Output                         |
| 40            |                | General Purpose Output                         |
| 41            |                | General Purpose Output                         |
| 42            |                | General Purpose Output                         |
| 43            |                | General Purpose Output                         |
| 44            |                | General Purpose Output                         |
| 45            |                | General Purpose Output                         |
| 46            |                | General Purpose Output                         |
| 47            |                | General Purpose Output                         |
| 48            |                | General Purpose Output                         |
| 49            |                | General Purpose Output                         |
| 50            |                | (J/P/Q type: 0V connection/K type: NC)         |
|               |                |  |

Splash-Proof

Controllers

PMEC
/AMEC

PSEP
/ASEP

ROBO
NET

ERC2

PCON

ACON

SCON

PSEL

ASEL

SSEL

xsel **590** 

#### Table of specifications

#### ■ J (Compact) / K (General Purpose)

| Item                                   |  | Description   |                       |                        |  |                      |                       |                |
|--|--|---|-----------------------|------------------------|--|----------------------|-----------------------|----------------|
| Controller Series, Type                |  | J (Comp   | act) Type             |                        | K (General Purpose) Type / KE (CE Compatible) Type |                      |                       |                |
| Connecting actuator                    |  | RCS2 / ISA / ISPA / ISPA / ISDA / ISDACR / ISPDACR / IF / FS / RS |                       |                        |  |                      |                       |                |
| Compatible Motor Output (W)            |  |   | 20 / 3                | 0 / 60 / 100 / 150 / 2 | 200 / 300 / 400 / 600                              | 750                  |                       |                |
| Number of control axes                 | 1-axis   | 2-axis  | 3-axis                | 4-axis                 | 1-axis   | 2-axis               | 3-axis                | 4-axis         |
| Manifestore Commented Asses Outrot 000 | Ma   | x. 800 (When power  | supply voltage is 2   | 00V)                   | Max  | Max. 1600 (W         | hen power supply vo   | Itage is 200V) |
| Maximum Connected Axes Output (W)      | Ma   | x. 400 (When power  | supply voltage is 1   | 00V)                   | 800  | Max. 800 (Wh         | nen power supply vo   | Itage is 100V) |
| Land Wellson                           |  |   | 100                   | / Specification: Sing  | le-phase AC100 to                                  | 115V                 |                       |                |
| Input Voltage                          |  |   | 200                   | / Specification: Sing  | le-phase AC200 to 2                                | 230V                 |                       |                |
| Motor Power Input                      |  |   |                       | ±1(                    | 0%   |                      |                       |                |
| Power Supply Frequency                 |  |   |                       | 50Hz/                  | 60Hz   |                      |                       |                |
| D                                      |  | 10701/4   | Max                   | Max                    | Max  | Max                  | Max                   | Max            |
| Power Supply Capacity                  | iviax  | 1670VA  | 1720VA                | 1810VA                 | 1670VA   | 3120VA               | 3220VA                | 3310VA         |
| Position detection method              |  |   |                       | Incremental Encod      | er (Serial encoder)                                |                      |                       |                |
| Position detection method              |  |   | Absolute en           | coder with a rotation  | nal data backup (Se                                | rial encoder)        |                       |                |
| Speed setting                          |  | 1mm/sec and up, the maximum depends on actuator specifications    |                       |                        |  |                      |                       |                |
| Acceleration setting                   |  |   | 0.01G                 | and up, the maximu     | n depends on the a                                 | ctuator              |                       |                |
| Programming language                   |  |   |                       | Super SEL              | . language   |                      |                       |                |
| Number of programs                     |  |   |                       | 64 Pro                 | grams  |                      |                       |                |
| Number of program steps                |  |   |                       | 6,000 Ste              | ps (total)   |                      |                       |                |
| Number of multi-tasking programs       |  |   |                       | 16 Pro                 | grams  |                      |                       |                |
| Number of Positions                    |  |   |                       | 3,000 p                | ositions   |                      |                       |                |
| Data memory device                     |  |   |                       | FLASH ROM+SRA          | M Battery Backup                                   |                      |                       |                |
| Data input method                      |  |   |                       | Teaching pendar        | t or PC software                                   |                      |                       |                |
| Standard Input/Output                  | 32 p   | oints (total of dedica  | ated inputs + genera  | al-purpose inputs) / 1 | 6 points (total of de                              | dicated outputs +    | general-purpose out   | outs)          |
| Expansion Input/Output                 | None   | 48 point  | ts per unit (1 more u | nit can be installed)  | 48 p   | oints per unit (3 mo | re units can be insta | lled)          |
| Serial communications function         | Teaching Port (25-pin D-sub) Standard Equipment Teaching Pendant+ Expansion SIO Board Installable (optional) |   |                       |                        |  |                      | e (optional)          |                |
| Other Input/Output                     |  |   | System I/O (Eme       | ergency Stop Input,    | Enable Input, Syster                               | n Ready Output)      |                       |                |
| Protection function                    |  | Motor ov  | rercurrent, Motor dri | ver temperature che    | ck, Overload check                                 | Encoder open-circ    | cuit check            |                |
| FIOLECTION TUNCTION                    |  |   | so                    | ft limit over, system  | error, battery error, e                            | tc.                  |                       |                |
| Ambient Operating Temp./Humidity       |  |   | Te                    | emperature 0 to 40°C   | C, Humidity 30 to 85                               | %                    |                       |                |
| Ambient atmosphere                     |  |   | Free from corros      | ive gases. In particu  | lar, there shall be no                             | significant dust.    |                       |                |
| Weight                                 | 2.6kg  | 3.3kg   | 5.0                   | )kg                    | 6.0  | kg                   | 7.0                   | kg             |
| Accessory                              |  |   |                       | I/O Flat               | t Cable  |                      |                       |                |

#### ■ P (Large-Capacity Standard Type) / Q (Large-Capacity Global Type)

| Item   | Description  |  |               |              |               |                 |                 |                 |                |              |               |         |
|--|--|--|---------------|--------------|---------------|-----------------|-----------------|-----------------|----------------|--------------|---------------|---------|
| Controller Series, Type                      | P (Standard) Type Q (Global) Type  |  |               |              |               |                 |                 |                 |                |              |               |         |
| Connecting actuator                          |  | RCS2 / ISA / ISPA / ISPA / ISDA / ISDACR / ISPDACR / IF / FS / RS / LSA  |               |              |               |                 |                 |                 |                |              |               |         |
| Compatible Motor Output                      |  | 20 / 30 / 60 / 100 / 150 / 200 / 300 / 400 / 600 / 750   |               |              |               |                 |                 |                 |                |              |               |         |
| Number of Controlled Axes                    | 1-axis   | 2-axis   | 3-axis        | 4-axis       | 5-axis        | 6-axis          | 1-axis          | 2-axis          | 3-axis         | 4-axis       | 5-axis        | 6-axis  |
| Maximum Connected Axes Output (W)            |  |  |               | Max          | 2400W (The s  | ingle-phase     | AC200V speci    | fication is 16  | 00W)           |              |               |         |
| Control Power Input                          |  | Sin  | gle-phase A0  | 170V to AC2  | 53V           |                 |                 | Sin             | gle-phase AC   | 170V to AC2  | 53V           |         |
| Motor Power Input                            |  | Single-  | ohase/3-phas  | e AC180V to  | AC253V        |                 |                 | Single-         | ohase/3-phas   | e AC180V to  | AC253V        |         |
| Power Supply Frequency                       |  |  |               |              |               | 50 /            | 60Hz            |                 |                |              |               |         |
| Insulation Resistance                        |  | 10MΩ or n  | nore (betweer | the power-s  | upply termina | I and I/O terr  | ninals, and be  | tween all ext   | ternal termina | ls and case, | at 500VDC)    |         |
| Withstand Voltage                            |  |  | AC1500V       | (1 minute)   |               |                 |                 |                 | AC1500V        | (1 minute)   |               |         |
| Power Supply Capacity (*1)                   | Max  | Max  | Max           | Max          | Max           | Max             | Max             | Max             | Max            | Max          | Max           | Max     |
| - one cappy capacity ( 1)                    | 1744VA   | 3266VA   | 4787VA        | 4878VA       | 4931VA        | 4998VA          | 1744VA          | 3266VA          | 4787VA         | 4878VA       | 4931VA        | 4998VA  |
| Position detection method                    |  |  |               |              | Incre         | mental Encod    | ler (Serial enc | oder)           |                |              |               |         |
|  |  |  |               |              |               | with a rotation | nal data back   |                 | •              |              |               |         |
| Safety Circuit Configuration                 |  |  | Redundancy    | not supporte | d             |                 |                 |                 | Double Redur   | ndant Enable | d             |         |
| Drive Source Breaker System                  |  |  |               | utoff relay  |               |                 |                 |                 |                | fety Circuit |               |         |
| Enable Input                                 |  | B Contact  | Input (Intern |              |               |                 |                 | <u> </u>        | ernal Power S  | Supply Model | l, Double Red | undant) |
| Speed setting                                |  |  |               | 1mm/         |               |                 | epends on act   |                 | ations         |              |               |         |
| Acceleration/Deceleration Setting            |  |  |               |              | 0.01G and up  | , the maximu    | m depends on    | the actuator    |                |              |               |         |
| Programming language                         |  |  |               |              |               |                 | _ language      |                 |                |              |               |         |
| Number of programs                           |  |  |               |              |               |                 | ograms          |                 |                |              |               |         |
| Number of program steps                      |  |  |               |              |               | 9999 Ste        |                 |                 |                |              |               |         |
| Number of multi-tasking programs             |  |  |               |              |               | 16 Pro          | grams           |                 |                |              |               |         |
| Number of Positions                          |  |  |               |              |               | 20,000 Pos      | itions (Total)  |                 |                |              |               |         |
| Data memory device                           |  |  |               |              |               |                 | M Battery Bac   |                 |                |              |               |         |
| Data input method                            |  |  |               |              | Tea           | aching pendar   | nt or PC softwa | are             |                |              |               |         |
| Standard Input/Output                        |  |  |               |              | <u> </u>      |                 | PIO Board (NI   |                 |                |              |               |         |
| Expansion Input/Output                       |  |  | 48-point l    | /O PIO Board | (NPN/PNP), 9  | 6-point I/O PIO | Board (NPN/     | PNP), Up to 3   | boards can be  | e installed  |               |         |
| Serial communications function               |  |  |               | Teaching     | Pendant (25-p | in D-sub) Por   | t + 2ch RS2320  | C Port (9-pin l | D-sub x 2)     |              |               |         |
| Protection function                          | Motor overcurrent, overload, motor driver temperature check, overload check encoder open-circuit check, soft limit over, system error, battery error, etc. |  |               |              |               |                 |                 |                 |                |              |               |         |
| Ambient Operating Temp. Humidity, Atmosphere |  | 0 to 40°C, 10 to 95% (non-condensing). Free from corrosive gases. In particular, there shall be no significant dust. |               |              |               |                 |                 |                 |                |              |               |         |
| Weight (*2)                                  |  | 5.2kg  |               |              | 5.7k          |                 | J               | 4.5kg           |                | <u> </u>     | 5kg           |         |
| Accessory                                    |  |  |               |              |               |                 | t Cable         | •               |                |              |               |         |
|  |  | I/O Flat Cable   |               |              |               |                 |                 |                 |                |              |               |         |

591




ACCESSORY

"1 When the connected axes represent the maximum wattage.

"2 Including the absolute-data backup battery, brake mechanism and expansion I/O box.

#### External Dimensions

#### ■ J (Compact) Type / K (General Purpose) Type



#### ■ P (high-capacity standard type) / Q (high-capacity global type)

The XSEL-P/Q types have different shapes and dimensions in accordance with the controller specifications (encoder type, with/without brake, and with/without I/O expansion).

The 4 layouts below are available. Confirm dimensions to match the desired type and number of axes.

#### Caution

The specifications of the single phase 200V in Q type is the exterior dimension of P type.

#### [P Type]

| [г туре                       | 1                             |   |  |   |  |   |
|-------------------------------|-------------------------------|---|--|---|--|---|
|                               |                               | Basic Layout (Incremental Specification)  | With brake/absolute unit                                       | Basic Layout<br>+ I/O expansion base  | With brake/absolute unit + I/O expansion base                | Side View                               |
|                               | Encoder                       | Incremental   | Absolute   | Incremental   | Absolute   |   |
| Controllers<br>Specifications | Brake                         | None  | Yes  | None  | Yes  |   |
| opcomounciio                  | I/O                           | Standard only   | Standard only  | Standard + Expansion  | Standard + Expansion   |   |
| Single phase                  | 1 to 4 axis<br>Specifications | 49.5 75 75 49.5   | 59.5, 75 /5 59.5<br>59.8 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 | 41, 120, 120, 41, 41, 41, 41, 41, 41, 41, 41, 41, 41                        | 51 120 120 51<br>8 8 8 8 8 342 15<br>358                     |   |
| Specifications                | 5 to 6 axis<br>Specifications | 22<br>28<br>30<br>284<br>300  | 42 120 120 42<br>120 324 15<br>340                             | \$8.5 120 120 58.5<br>\$6.00 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0            | 78.5 120 120 78.5<br>8888 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9  | (80) 125.3<br>(80) 125.3                |
| 3 phases                      | 1 to 4 axis<br>Specifications | 49.5 75 75 49.5<br>49.5 75 75 49.5<br>49.5 75 75 49.5<br>49.5 75 75 49.5<br>49.5 75 75 49.5 | 59.5 75 78 59.5<br>59.5 75 78 59.5<br>269 1.5<br>285           | 41, 120 120 41 <sup>1</sup><br>98 88 88 332 15                              | 51 120 120 51<br>8 8 8 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9     | Battery Box (24) (Applies to ABS model) |
| Specifications                | 5 to 6 axis<br>Specifications | 22 120 120 22<br>3888 15<br>300   | \$ 8 8 8 1 120 120 42  | \$8.5 120 120 58.5<br>\$1.00 120 58.5<br>\$1.00 120 58.5<br>\$1.00 120 58.5 | 78.5 120 120 78.5<br>9 8 9 9 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 |   |



**SEL 592** 

## External dimensional drawing

#### [Q Type]

|                               |                               | Basic Layout (Incremental Specification)                      | With brake/absolute unit                                       | Basic Layout<br>+ I/O expansion base   | With brake/absolute unit + I/O expansion base                             | Side View                          |
|-------------------------------|-------------------------------|---|--|--|---|------------------------------------|
|                               | Encoder                       | Incremental   | Incremental Absolute   |  | Absolute  |                                    |
| Controllers<br>Specifications | Brake                         | None  | Yes  | None   | Yes   |                                    |
| .,                            | 1/0                           | Standard only   | Standard only  | Standard + Expansion   | Standard + Expansion  |                                    |
| Single phase                  | 1 to 4 axis<br>Specifications | 49.5, 75, 75 49.5<br>10,000 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 | 59.5, 75 76 59.5<br>59.8 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 | 41 120 120 41<br>55 85 85 85 85 85 85 85 85 85 85 85 85 8  | 51 120 120 51<br>98 88 342 15   |                                    |
| Specifications                | 5 to 6 axis<br>Specifications | 284 15  | 42 120 120 42<br>120 324 15                                    | \$8.5 120 120 58.5<br>\$6.00 120 58.5<br>\$6.00 120 120 58.5<br>\$6.00 120 120 120 120 120 120 120 120 120 1 | 78.5 120 120 78.5<br>8 8 8 9 9 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1              | (80) 125.3                         |
| 3 phase                       | 1 to 4 axis<br>Specifications | 28 75 75 28<br>8 8 8 9 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1        | 38 75 78 38<br>90 80 80 80 80 80 80 80 80 80 80 80 80 80       | 64.5 76 75 64.5<br>9 8 8 8 8 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9   | 29.5 120 120 29.5<br>29.5 120 120 29.5<br>29.5 120 120 29.5<br>315 15 315 | Battery Box (Applies to ABS model) |
| Specifications                | 5 to 6 axis<br>Specifications | 45.5 75 75 45.5<br>8 8 8 8 2 241 5                            | 20.5 120 120 20.5<br>988 261 15<br>297                         | 37 120 120 37<br>8 8 8 3 314 5<br>330  | 57 120 120 57<br>9 8 8 8 3 15<br>354 15                                   |                                    |

Pulse Motor

Servo Motor
(24V)


Servo Motor
(200V)

Linear
Servo Motor

**593** XSEL



#### J type (Compact)



#### 1 FG Connection Terminal

A terminal for connecting to the FG terminal on the enclosure. The PE of the AC input are connected to the enclosure inside the controller.

#### 2 Fuse Holder (K Type only)

This is the single-pole fuse holder for overcurrent protection in the AC input.

#### 3 Main Power Input Connector

This connector is for the AC100/200V single-phase input.

#### 4 Regeneration Resistance Unit Connector

This connector is for the regenerative resistance unit (optional/REU-1) that is connected when there is insufficient capacity with the built-in regenerative resistor for high-acceleration/high-loads, etc.

#### 5 Motor Cable Connector

A connector for the motor power-supply cable of the actuator.

#### 6 Actuator Sensor Input Connector

A connector for axis sensors such as LS, CREEP and OT.

#### 7 Absolute-data backup battery

This is the encoder backup battery unit when an absolute encoder is used. This battery is not connected for a non-absolute axis.

#### 8 Brake Release Switch (Brake-equipped specification only)

Locking toggle switch for releasing the axis brake. Pull the switch forward and then tilt it up or down.

Set the switch to the top position (RLS) to forcibly release the brake, or to the bottom position (NOM) to have the brake automatically controlled by the controller.

#### 9 Axis Driver Status LED

This LED is for monitoring the operating status of the driver CPU that controls the motor drive.


Features the following three LEDs..

| Name  | Color  | Function description                                     |
|---|--------|--|
| ALM   | Orange | Indicates when an error has been detected by the driver. |
| SVON Green Indicates that the servo is ON a |        | Indicates that the servo is ON and the motor is driven.  |
| BATT ALM                                    | Orange | Indicates low absolute battery charge.                   |

#### 10 Encoder sensor cable connector

15-pin D-sub connector for the actuator encoder cable.

#### K type (General)



#### 11 System I/O Connector

A connector for three input/output points including two inputs used to for the controller operation, and one system status output.

| Name |                           |  |
|------|---------------------------|--|
| EMG  | Emergency stop input      | ON=operation enabled, OFF=emergency stop           |
| ENB  | Safety Gate Input         | ON=operation enabled, OFF=servo OFF                |
| RDY  | System Ready Relay Output | This signal outputs the status of this controller. |
|      |                           | Cascade connection is supported.                   |
|      |                           | Short=ready, Open=not ready                        |

#### 12 I/O 24V Power Connector (K Type only)

16. 17 This connector is for supplying external I/O power to the insulator when DIs and DOs are installed in the I/O boards.

#### 13 Panel Window

This window has a 4-digit, 7-segment LED and five LED lamps showing the system status.

#### 14 Mode switch

This is a locking toggle switch for designating the controller operating mode. Pull the switch forward and then tilt it up or down.

The top position indicates the MANU (manual operation) mode, while the bottom position indicates the AUTO (automatic operation) mode.

Teaching can only be performed in manual operation,

and automatic operation using external I/Os is not possible in the MANU mode.

#### 15 Teaching Connector

This is a 25-pin D-sub connector for connecting a teaching pendant or PC cable to enter programmed positions.

#### 16 Standard I/O Slot (Slot 1)

A 32-point input / 16-point output PIO board is installed as standard equipment.

#### 17 Expansion I/O Slots (Slot 2, Slot 3, Slot 4)

Install an expansion I/O board. (Option)

Slider

Mini

Standard

Rod

Mini

Standard

Table/Arm FlatType

Mini

Standard

Gripper/ Rotary Type

Linear Servo Type

Туре

Splash-Proof

Controllers

PMEC /AMEC

ROBO

ERC2

ACON

DOEL

ASEL

SSEL

XSEL

Pulse Moto

Servo Mot


Servo Moto (200V)

Linear Servo Moto



#### **Part Names**

Type P (Standard 4-axis)



#### 1 FG Connection Terminal

A terminal for connecting to the FG terminal on the enclosure. The PE of the AC input are connected to the enclosure inside the controller.

#### 2 External regeneration unit connector

A connector for the regenerative resistor that must be connected when the built-in regenerative resistor alone does not offer sufficient capacity in high-acceleration/ high-load operation, etc. Whether or not an external regenerative resistor is necessary depends on the conditions of your specific application such as the axis configuration.

#### 3 AC Power Input Connector

AC200V 3-phase input connector. It consists of six terminals including motor power-supply, control power-supply and PE terminals. Standard equipment only includes a terminal block.

Due to risk of electrical shock, do not touch this connector while power is supplied.

#### 4 Control Power Monitor LED

A green light illuminates while the control power supply is properly generating internal controller power.

#### 5 Enable/Disable Switch for Absolute Battery

This switch is for enabling/disabling the encoder backup using the absolute data backup battery. The encoder backup has been disabled prior to shipment. After connecting the encoder/axis-sensor cables, turn on the power, and then set this switch to the top position.

#### 6 Encoder/Axis Sensor Connector

A connector for axis sensors such as LS, CREEP and OT. \*: LS, CREEP, and OT are options.

#### 7 Motor connector

PMEC /AMEC PSEP /ASEP ROBO NET ERC2

A connector for driving the motor in the actuator.

#### 8 Teaching Pendant Type Selection Switch

This switch is for selecting the type of teaching pendant to connect to the teaching connector. Switch between an IAI standard teaching pendant and the ANSI-compatible teaching pendant. Operate the switch on the front face of the board in accordance with the teaching pendant used.

#### 9 Teaching Connector

The teaching interface is used for connecting the IAI teaching pendant or the software on a PC to operate and configure the system, etc.

#### 10 System I/O connector


A connector for managing the safety operation functions of the controllers. Controllers of the global specification let you configure a safety circuit conforming to safety categories of up to 4 using this connector and an external safety circuit.

#### 11 Panel Window

This window consists of a 4-digit, 7-segment LED and five LED lamps showing the system status.

# 595 XSEL

#### Type Q (Absolute brake unit + expansion base, 6-axis)



#### Description of five LEDs

|   | Name | Status when LED is lit                                   |
|---|------|--|
| Π | RDY  | CPU Ready (programs can be run)                          |
| ı | ALM  | CPU Power (System Down Level Error) CPU Hardware Problem |
| Ī | EMG  | Emergency stop status, CPU hardware problem,             |
|   |      | or power system hardware problem                         |
| I | PSE  | Power supply hardware problem                            |
| П | CLK  | System clock problem                                     |

#### 12 Mode switch

This is a locking toggle switch for designating the controller operating mode. Pull the switch forward and then tilt it up or down. The top position indicates the MANU (manual operation) mode, while the bottom position indicates the AUTO (automatic operation) mode. Teaching can only be performed in manual operation, and automatic operation using external I/Os is not possible in the MANU mode.

#### 13 Standard I/O connector

50-pin flat connector structure, comprised of 32 input / 16 output DIOs.

Overview of Standard I/O Interface Specifications

| Item                 | Details  |
|----------------------|--|
| Connector Name       | 1/0  |
| Applicable connector | 50-Pins, Flat Connector                                    |
| Power Supply         | Power is supplied through connector pins No. 1 and No. 50. |
| Input                | 32 points (including general-purpose and dedicated inputs) |
| Output               | 16 points (including general-purpose and dedicated inputs) |
| Connected to         | External PLC, sensors, etc.                                |

#### 14 General-purpose RS232C Port Connector

This port is for connecting general-purpose RS232C equipment. (2-channels are available)

#### 15 Field network board slot

A slot that accepts a fieldbus interface module.

#### 16 Expansion I/O Board (optional)

Slots that accept optional expansion I/O boards.

#### 17 Brake Power Input Connector

A power input connector for driving the actuator brake. DC 24V must be supplied externally. If this power supply is not provided, the actuator brake cannot be released. Be certain that power is supplied to the brake-equipped axis. Use a shielded cable for the brake power cable, and connect the shielding on the 24V power supply side.

#### 18 Brake Release Switch Connector

A connector for the switch that releases the actuator brake externally to the controller. Shorting the COM terminal and BKMRL\* terminal of this connector will release the brake. Use this method if you wish to manually operate the actuator after the controller has experienced a power failure or malfunction.

#### 19 Brake Switch

Locking toggle switch for releasing the axis brake. Pull the switch forward and then tilt it up or down. Setting it to the top position (RLS side) forcibly releases the brake, while setting it to the bottom position (NOM side) causes the controller to automatically control the brake.

sales@electromate.com

#### Option

Main Unit Weight

Accessory


Built-in regenerative resistor

#### ■ Regenerative Resistance Unit



| 1  | Installation Standards     | Determin | ned by the t | otal motor ca            | apacit | y of v   | ertica    | al axe | s connected. |          |
|--|----------------------------|----------|--------------|--------------------------|--------|----------|-----------|--------|--------------|----------|
| •  | Horizontal Application     |          |              |                          | ø5     | _ 34     | -u        |        |              |          |
|  | Number of connecting units | P/Q Type | J Type       | К Туре                   | 17     | <b>*</b> | ٦,        |        |              | <b>-</b> |
|  | 0 pc                       | to 100W  | to 200W      | to 800W                  |        |          |           |        |              | - 1      |
| t the regenerative current produced when the motor   | 1 pc                       | to 600W  | to 800W      | to 1200W                 |        | 图-       |           | п      |              | - 1      |
| controller has a built-in regenerative resistor, its capacity axis is positioned vertically and the load is large. In this | 2 pc                       | to 1200W | -            | to 1600W                 | 9 2    |          |           | Ч      |              | - 1      |
| tive units will be required. (Refer to the table at right)   | 3 pc                       | to 1800W | -            | -                        | 8 28   | 屬.       | 175       |        |              | - 1      |
| are unite will be required. (Herer to the table at right)  | 4 pc                       | to 2400W | -            | -                        |        |          |           | L      |              | - 1      |
| Specifications   | Vertical Application       |          |              |                          |        | IA       | ,         |        |              |          |
| Specifications   |                            |          |              |                          | 1 *    | _```     | ٦ - "     |        |              | 7        |
| W34mm × H195mm × D126mm  | Number of connecting units | P/Q Type | J Type       | K Type                   |        | ***      | 5<br>16.6 | .      | 126          |          |
| 000-   | 0 pc                       | to 100W  | to 200W      | to 400W                  |        | +        | k10.0     | ا -    | 120          |          |
| 900g   | 1 pc                       | to 600W  | to 600W      | to 800W                  |        |          |           |        |              |          |
| 220Ω 80W   | 2 pc                       | to 1000W | to 800W      | to 1200W                 |        |          |           |        |              |          |
| Controller Connection Cable (Model No. CB-ST-REU010) 1m  | 3 pc                       | to 1400W | -            | When exceeding           |        |          |           |        |              |          |
| ,  | 4 pc                       | to 2000W | -            | 1200W,<br>please contact |        |          |           |        |              |          |

#### ■ Absolute Data Retention Battery (For XSEL-J/K/KE/KT/KET)



#### ■ Absolute Data Retention Battery (For XSEL-P/Q)



#### ■ Expansion PIO Board

An optional board for adding I/O (input/output) points. With the general-purpose and large-capacity types, up to three expansion PIO boards can be installed in the expansion slots. (With the compact types, only one expansion PIO board can be installed in the expansion slot, provided that the controller is of 3 or 4-axis specification.)

#### DeviceNet Connection Board


A board for connecting the XSEL controller to DeviceNet.

| Item                                      | Specifications   |   |                       |                     |  |  |  |  |  |  |
|---|--|---|-----------------------|---------------------|--|--|--|--|--|--|
| Number of I/O Points                      | 1 board, 256 input points / 256 output points *Only 1 can be installed |   |                       |                     |  |  |  |  |  |  |
| Communication                             | Interface module cer   | ertified under DeviceNet 2.0 (certification to be obtained) |                       |                     |  |  |  |  |  |  |
| Standard                                  | Group 2 Only Server  | Group 2 Only Server   |                       |                     |  |  |  |  |  |  |
|   | Insulated node opera   | Insulated node operating on network power supply            |                       |                     |  |  |  |  |  |  |
| Communication                             | Master-Slave connec  | Master-Slave connection Bit strobe                          |                       |                     |  |  |  |  |  |  |
| specifications                            |  |   | Polling               |                     |  |  |  |  |  |  |
|   |  | Cyclic  |                       |                     |  |  |  |  |  |  |
| Communication Rate                        | 500k/250k/125kbp   | 500k/250k/125kbps (Selectable by DIP switch)                |                       |                     |  |  |  |  |  |  |
| Communication                             | Communication Rate   | Maximum network length                                      | Maximum branch length | Total branch length |  |  |  |  |  |  |
| cable length                              | 500 kbps   | 100m  |                       | 39m                 |  |  |  |  |  |  |
|   | 250 kbps   | 250m  | 6m                    | 78m                 |  |  |  |  |  |  |
|   | 125 kbps   | 500m  |                       | 156m                |  |  |  |  |  |  |
|   | (Note) When a large  | DeviceNet cable is us                                       | ed                    |                     |  |  |  |  |  |  |
| Communication Power Supply                | 24VDC (supplied from   | n DeviceNet)  |                       |                     |  |  |  |  |  |  |
| Low Current Communication<br>Power Supply | 60mA or higher   |   |                       |                     |  |  |  |  |  |  |
| Number of Reserved Nodes                  | 1 node   |   |                       |                     |  |  |  |  |  |  |
| Connector                                 | MSTBA2.5/5-G.08AL  | JM by Phoenix Conta   | ct (*1)               | •                   |  |  |  |  |  |  |

#### Expansion SIO Board (General-Purpose Type)

to 2400W

4 pc 5 рс



#### CC-Link Connection Board

A board for connecting the XSEL controller to CC-Link.

| Number of I/O Points        | 1 board, 256 input points / 2    | 1 board, 256 input points / 256 output points *Only 1 can be installed |           |          |            |       |  |  |  |
|-----------------------------|----------------------------------|--|-----------|----------|------------|-------|--|--|--|
| Communication Standard      | CC-Link Ver1.10 (certified)      | CC-Link Ver1.10 (certified)  |           |          |            |       |  |  |  |
| Communication Rate          | 10M/5M/2.5M/625k/156kbp          | s (switch  | ed using  | a rotary | switch)    |       |  |  |  |
| Communication method        | Broadcast polling method         |  |           |          |            |       |  |  |  |
| Asynchronous                | Frame synchronization meth       | Frame synchronization method   |           |          |            |       |  |  |  |
| Encoding Format             | NRZI                             |  |           |          |            |       |  |  |  |
| Transmission path type      | Bus Format (EIA RS485 Compliant) |  |           |          |            |       |  |  |  |
| Transmission Format         | HDLC Compliant                   | HDLC Compliant   |           |          |            |       |  |  |  |
| Error control method        | CRC (X15+X12+X5+X1)              |  |           |          |            |       |  |  |  |
| Number of Reserved Stations | 1 to 3 Stations (Remote Dev      | ice Static   | ons)      |          |            |       |  |  |  |
| Communication               | Communication Rate (bps)         | 10M  | 5M        | 2.5M     | 625k       | 156k  |  |  |  |
| cable length                | Communication cable length       | 100  | 160       | 400      | 900        | 1200  |  |  |  |
| Connector (Controller-side) | MSTBA2.5/5-G.08AUM by F          | hoenix C   | ontact (* | 1))      |            |       |  |  |  |
| *1) The connector on the    | cable (SMSTB2.5/5-ST-5.0         | 8AU by   | Phoenix   | Contact  | ) is a sta | ndard |  |  |  |

xsel **596** 



Controllers

PMEC
/AMEC

PSEP
/ASEP

ROBO
NET

ERC2

PCON

ACON

SCON

PSEL



Teaching Pendant

#### Part Names

Model IA-T-X (standard)

IA-T-XD (with deadman switch)

Features • A teaching device that has program/position input, test operation, monitoring function, etc.

• Interactive, easy to operate.


• For higher safety, a deadman switch version is also available.

#### Specifications

| Item                             | Specifications   |
|----------------------------------|--|
| Ambient Operating Temp./Humidity | Temperature 0 to 40°C, Humidity: 85 %RH or lower                                     |
| Ambient Operating atmosphere     | Free from corrosive gases. In particular, there shall be no significant powder dust. |
| Weight                           | Approx. 650g   |
| Cable Length                     | 4m   |
| Indication                       | 20 characters x 4 lines LCD display  |

- \* Versions older than 1.13 cannot be used with XSEL-P/Q.
- Versions older than 1.08 cannot be used with SCARA.

Dimensions



#### ANSI standard / CE mark compatible teaching pendant (dedicated to general purpose type)

Model SEL-T

SEL-TD (Corresponding to ANSI)


**SEL-TG** (Corresponding to safety category)

Features Splash-proof type that corresponds to protection level IP54. Improved operationability with separate keys for different functions. In addition, SEL-TD / SEL-TG has a 3-position enable switch and corresponds to ANSI standard.

#### Specifications

| Item                             | Specifications   |
|----------------------------------|--|
| Ambient Operating Temp./Humidity | Temperature: 0 to 40°C Humidity: 30 to 85%RH or lower (non-condensing) |
| Protection mechanism             | IP54 (Cable connector excluded)  |
| Weight                           | 400g or lower (Cable connector excluded)                               |
| Cable Length                     | 5m   |
| Indication                       | 32 characters x 8 lines LCD display                                    |
| Safety Rating                    | CE mark, ANSI standard (*)   |

# Dimensions




| ght  | 00g or lower (Cable connector excluded) |  |  |  |  |  |  |  |
|--|---|--|--|--|--|--|--|--|
| le Length  | 5m                                      |  |  |  |  |  |  |  |
| cation   | 32 characters x 8 lines LCD display     |  |  |  |  |  |  |  |
| ty Rating CE mark, ANSI standard (*)                   |   |  |  |  |  |  |  |  |
| (*) only SEL-TD / SEL-TG corresponds to ANSI standard. |   |  |  |  |  |  |  |  |
| eaching pendant  | controller correspondence table         |  |  |  |  |  |  |  |

|             |                | IA-T-X     | IA-T-XD               | SEL-T      | SEL-TD                    | SEL-TG                    |
|-------------|----------------|------------|-----------------------|------------|---------------------------|---------------------------|
|             |                | Standard   | With a deadman switch | Standard   | Safety Category Compliant | Safety Category Compliant |
|             | PSEL/ASEL/SSEL | O (Note 1) | ○ (Note 1)            | ○ (Note 1) | ○ (Note 1)                | 0                         |
|             | XSEL-J         | 0          | 0                     | ×          | ×                         | ○ (Note 2)                |
|             | XSEL-K         | 0          | 0                     | 0          | 0                         | 0                         |
|             | XSEL-P         | Ó          | Ö                     | Ô          | Ó                         | 0                         |
| Program     | XSEL-Q         | ×          | ×                     | 0          | 0                         | 0                         |
| Controllers | XSEL-KT        | 0          | Ö                     | Ó          | Ö                         | 0                         |
| Controllers | XSEL-KE        | 0          | 0                     | 0          | 0                         | 0                         |
|             | XSEL-JX        | 0          | 0                     | ×          | ×                         | ○ (Note 2)                |


- XSEL-QX  $^{\star}\,\bigcirc$  correponds to safety category B to 4.
- does not corresond to safety category, but connection is available.
   (Note 1) To connect to PSEL/ASEL/SSEL, a conversion cable is necessary.
  - (Note 2) To connect SEL-TG to the XSEL-J/JX controller, DC24V needs to be applied to TP adaptor.


#### SEL-TG wiring drawing


XSEL-KX XSEL-PX



**597** XSEL










(200V)


**SEL** 598



When you need spare parts after purchasing the product, such as when replacing a cable, refer to the list of models below.

## 

 $^{\star}$  Enter the cable length (L) into  $\Box\Box\Box$  . Compatible to a maximum of 20 meters. Ex.: 080 = 8 m




| Wire   | Signal | No. |               | No. | Signal | Wire      |
|--------|--------|-----|---------------|-----|--------|-----------|
|        | PE     | 1   | $\overline{}$ | 1   | U      |           |
| 0.75   | U      | 2   | -             | 2   | V      | 0.75sq    |
| 0.75sq | ٧      | 3   |               | 3   | w      | (crimped) |
|        | W      | 4   | -             | 4   | PE     |           |


Min. bend radius r = 50 mm or larger (when movable type is used)

\* Only the robot cable is to be used in a cable track







Min. bend radius r = 50 mm or larger (when movable type is used) \* Only the robot cable is to be used in a cable track



#### Encoder cable/Encoder robot cable (for XSEL-P/Q)



Min. bend radius r = 50 mm or larger (when movable type is used)
\* Only the robot cable is to be used in a cable track



**599** XSEL




Servo Moto (200V


Linear Servo Motor

#### Rotary Dedicated Encoder Cable / Encoder Robot Cable

\* Enter the cable length (L) into  $\square\square\square$  . Compatible to a maximum of 30 meters. Ex.: 080 = 8 m CB-RCS2-PLA ] / CB-X2-PLA [ Model



Min. bend radius r = 50 mm or larger (when movable type is used) \* Only the robot cable is to be used in a cable track





CB-RCBC-PLA Model

\* Enter the cable length (L) into \( \sum \subseteq \). Compatible to a maximum of 20 meters. Ex.: 080 = 8 m



\*This cable is a standard type.


| 9 18 |                   | Black<br>Red                                      | A+<br>A-<br>B+<br>B-   | 6<br>5<br>4<br>3<br>2                            | White/Green<br>White/Crange<br>Brown/Blue<br>Brown/Yellow<br>Brown/Pilack | v.   |               |          | 1 | <u> </u> | XMP-<br>No.<br>1<br>2<br>3<br>4<br>5<br>6                    | 18V<br>Signal<br>A<br>A<br>B<br>B<br>Z<br>Z<br>LS+                | Color<br>White/Size<br>White/Felow<br>White/Fed<br>White/Grape<br>White/Grape | Wire               |
|------|-------------------|---|--|--|---|------|---------------|----------|---|----------|--|---|---|--------------------|
|      | (crimped) The shi | Green Purple Gray Red Black Blue Yellow eld is co | SRD-<br>BAT+<br>BAT-<br>VCC<br>GND<br>BKR-<br>BKR-<br>nnected<br>a clamp | 8<br>9<br>10<br>11<br>12<br>13<br>14<br>15<br>16 | Groun   | d wi | re and shield | braiding |   |          | 8<br>9<br>10<br>11<br>12<br>13<br>14<br>15<br>16<br>17<br>18 | FG<br>SD<br>SD<br>BAT+<br>BAT-<br>VCC<br>GND<br>LS-<br>BK-<br>BK+ | Ground Orange Green Purple Gray Red Black White/Green Blue Yellow             | AWG26<br>(crimped) |
|      |                   |   |  |  |   |      |               |          |   |          |  |   |   |                    |

MC1.5/6-ST-3.5

#### I/O flat cable (for XSEL-J/K/P/Q)

Model CB-X-PIO

| * Enter the cable length (L) into $\Box \Box \Box$ . Compatible to a maximum of 10 meters Ex.: 080 = 8 m |
|--|
|--|



| 1  | Brown 1   |  | 18  | Gray 2  |  | 35   | Green 4   |  |
|----|---|--|---|---|--|--|---|--|
| 2  | Red 1   |  | 19  | White 2   |  | 36   | Blue 4  |  |
| 3  | Orange 1  |  | 20  | Black 2   | l l  | 37   | Purple 4  |  |
| 4  | Yellow 1  |  | 21  | Brown-3   |  | 38   | Gray 4  |  |
| 5  | Green 1   |  | 22  | Red 3   |  | 39   | White 4   |  |
| 6  | Blue1   | l  | 23  | Orange 3  |  | 40   | Black 4   |  |
| 7  | Purple 1  |  | 24  | Yellow 3  |  | 41   | Brown-5   | Flat   |
| 8  | Gray 1  | Flat   | 25  | Green 3   | Flat   | 42   | Red 5   |  |
| 9  | White 1   | cable  | 26  | Blue 3  |  | 43   | Orange 5  | cable<br>crimped   |
| 10 | Black 1   | crimped  | 27  | Purple 3  |  | 44   | Yellow 5  | crimpeu  |
| 11 | Brown-2   | ,  | 28  | Gray 3  |  | 45   | Green 5   |  |
| 12 | Red 2   | l  | 29  | White 3   |  | 46   | Blue 5  |  |
| 13 | Orange 2  |  | 30  | Black 3   |  | 47   | Purple 5  |  |
| 14 | Yellow 2  |  | 31  | Brown-4   |  | 48   | Gray 5  |  |
| 15 | Green 2   | l  | 32  | Red 4   |  | 49   | White 5   |  |
| 16 | Blue 2  |  | 33  | Orange 4  |  | 50   | Black 5   |  |
| 17 | Purple 2  |  | 34  | Yellow 4  |  |  |   |  |
|    | 1<br>2<br>3<br>4<br>5<br>6<br>7<br>8<br>9<br>10<br>11<br>12<br>13<br>14<br>15 | 1 Brown 1 2 Red 1 3 Orange 1 4 Yellow 1 5 Green 1 6 Blue1 7 Purple 1 9 White 1 10 Black 1 11 Brown-2 12 Red 2 13 Orange 2 14 Yellow 2 15 Green 2 16 Blue 2 | 1 Brown 1 2 Red 1 3 Orange 1 4 Yellow 1 5 Green 1 6 Blue1 7 Purple 1 8 Gray 1 9 White 1 10 Black 1 11 Brown-2 12 Red 2 13 Orange 2 14 Yellow 2 15 Green 2 16 Blue 2 | 1 Brown 1   18   18   19   20   19   19   20   14   Yellow 1   21   22   20   20   20   20   20 | 1 Brown 1   18 Gray 2   2 Red 1   19 White 2   3 Orange 1   2 0 Black 2   2 1 Brown 3   6 Blue 1   2 2 Red 3   6 Blue 1   2 3 Orange 3   6 Blue 1   2 3 Orange 3   6 Blue 3   2 4 Yellow 3   8 Gray 1   1 Brown 3   2 6 Blue 3   2 6 Blue 3   1 1 Brown 3   2 7 Purple 1   2 8 Gress 3   2 8 Gray 3   2 9 White 3   3 Orange 4   3 1 Brown 4   3 1 Brown 4   3 1 Brown 4   3 1 Brown 4   3 1 Brown 4   3 1 Brown 4   3 1 Brown 4   3 1 Brown 4   3 3 1 Brown 4   6 Blue 2   3 3 3 Orange 4   3 3 0range    Brown 1   2   Red 1   9   White 2   3   Grang 2   2   Black 2   3   Brown 3   5   Green 1   6   Blue1   23   Grange 3   7   Purple 1   8   Gray 1   Flat   9   White 3   1   Brown 3   5   Green 3   Flat   6   Blue1   23   Grange 3   Grange 3   Grange 3   Grange 3   Grange 3   Grange 3   Grange 3   Grange 3   Grange 3   Grange 3   Grange 3   Grange 4   Gran | 1   Brown 1   2   Red 2   35   36   37   37   37   37   37   38   37   37 | 1   Brown 1   2   Red 2   35   Green 4   37   Purple 4   37   Purple 4   37   Purple 4   37   Purple 4   38   Gray 4   39   White 2   38   Gray 4   39   White 3   39   White 4   37   Purple 4   38   Gray 4   40   Black 5   40   Black 5   40   B |

xsel **600** 

